

県営第一工業用水道 水質試験結果表

2019年6月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	22.1	19.1	0.7	6.4						18.1	1	
2	曇	22.2	19.3	0.3	6.4						18.1	0	
3	晴	24.5	19.6	0.4	6.4						18.8	0	
4	晴	26.4	20.4	0.5	6.4						20.1	1	
5	曇	25.6	21.1	0.5	6.4	31.7	45.1	117.5	17.3	0.10	19.7	3	
6	曇	24.2	21.4	0.4	6.4						21.9	0	
7	雨	21.3	21.3	0.4	6.4						21.9	0	
8	雨	20.0	20.6	0.5	6.4						18.6	0	
9	曇	20.4	19.8	0.3	6.3						15.8	0	
10	雨	21.0	19.3	0.5	6.3						15.5	0	
11	曇	21.8	19.3	0.7	6.3						15.3	1	
12	雨	20.8	19.6	0.8	6.4						16.8	3	
13	晴	22.9	20.0	0.8	6.4						18.2	3	
14	曇	25.3	21.1	0.5	6.4	32.1	47.0	122.5	16.7	0.10	20.6	1	
15	曇	21.2	21.4	0.3	6.4						22.0	0	
16	雨	18.6	20.8	0.8	6.4						21.4	1	
17	曇	19.7	20.3	0.9	6.4						14.4	1	
18	晴	23.4	20.3	0.8	6.4						13.4	1	
19	曇	24.1	20.9	1.0	6.4						13.3	3	
20	晴	24.4	21.4	0.8	6.4						13.6	1	
21	曇	25.0	21.7	0.7	6.4						15.5	1	
22	雨	22.9	21.9	0.9	6.4						18.6	1	
23	曇	22.5	21.8	0.8	6.4						16.3	1	
24	曇	22.8	21.0	0.7	6.3	28.1	35.8	93.0	11.7	0.10	15.4	1	
25	晴	24.0	20.9	0.8	6.3						16.6	1	
26	晴	27.6	21.5	0.6	6.4						18.5	0	
27	曇	26.5	21.9	0.6	6.4						19.6	1	
28	雨	24.3	21.7	0.9	6.4						18.8	1	
29	曇	24.6	21.3	0.8	6.3						15.0	1	
30	曇	24.4	21.1	1.0	6.3						14.8	1	
最大	——	27.6	21.9	1.0	6.4	32.1	47.0	122.5	17.3	0.10	22.0	3	——
最小	——	18.6	19.1	0.3	6.3	28.1	35.8	93.0	11.7	0.10	13.3	0	
平均	——	23.2	20.7	0.7	6.4	30.6	42.6	111.0	15.2	0.10	17.6	1	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定