

県営第一工業用水道 水質試験結果表

2020年4月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	12.9	10.8	0.8	6.9						10.4	3	
2	曇	9.3	10.9	1.8	6.9						10.1	3	
3	晴	11.0	10.7	0.9	6.9						10.2	1	
4	晴	12.0	10.8	0.7	6.9						10.4	1	
5	曇	8.5	10.9	0.6	6.8						10.6	1	
6	晴	9.0	10.8	0.8	6.8						10.8	1	
7	晴	10.5	10.8	0.9	6.9						11.5	1	
8	曇	12.1	10.9	1.1	7.0	22.0	26.6	65.0	8.8	0.10	10.3	1	
9	晴	10.5	11.6	1.3	7.1						9.8	2	
10	雨	8.7	11.4	1.3	7.1						9.9	2	
11	晴	9.3	10.9	1.2	7.0						10.4	2	
12	曇	8.9	10.9	1.2	7.0						10.8	2	
13	雨	9.6	10.8	2.7	6.9						10.9	7	
14	曇	9.7	10.8	2.8	6.9						10.9	7	
15	晴	12.1	10.9	1.1	6.8	23.1	30.1	68.5	9.5	0.10	11.2	2	
16	曇	12.9	11.5	1.0	6.8						11.4	3	
17	晴	14.9	11.8	1.5	7.0						9.9	2	
18	雨	14.1	12.3	3.1	6.9						10.0	9	
19	曇	13.5	12.2	3.1	6.8						11.4	6	
20	雨	14.4	12.1	1.9	6.8						10.3	10	
21	曇	13.2	12.0	1.5	6.8						10.1	3	
22	雨	9.5	11.8	1.1	6.8						10.5	2	
23	雨	7.6	11.4	1.1	6.8						10.7	2	
24	晴	9.0	11.0	1.7	6.7	21.9	27.1	71.0	9.3	0.10	10.8	7	
25	晴	13.8	10.9	2.6	6.8						9.6	7	
26	曇	15.3	11.4	2.0	6.8						9.4	4	
27	晴	13.2	12.1	2.5	6.9						9.4	4	
28	曇	11.6	12.0	2.4	6.9						9.5	5	
29	晴	14.8	12.1	2.0	6.9						9.8	3	
30	晴	18.3	12.8	1.6	6.8						10.3	3	
最大	———	18.3	12.8	3.1	7.1	23.1	30.1	71.0	9.5	0.10	11.5	10	———
最小	———	7.6	10.7	0.6	6.7	21.9	26.6	65.0	8.8	0.10	9.4	1	
平均	———	11.7	11.4	1.6	6.9	22.3	27.9	68.2	9.2	0.10	10.4	4	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定