

県営第一工業用水道 水質試験結果表

2020年8月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	27.5	22.2	2.0	7.2						8.7	4	
2	晴	28.4	22.6	1.5	7.3						8.8	2	
3	晴	30.2	23.2	1.5	7.2						9.1	3	
4	晴	30.0	23.8	1.7	7.2						9.3	3	
5	晴	29.7	24.1	1.7	7.1						9.7	3	
6	晴	30.7	24.7	1.7	7.2						10.1	4	
7	曇	27.4	24.3	1.8	7.2	27.8	27.6	64.5	7.3	0.10	10.0	5	
8	曇	28.1	23.5	2.0	7.2						9.5	6	
9	晴	31.6	24.5	1.2	7.3						9.8	2	
10	晴	33.5	25.6	1.4	7.3						9.8	3	
11	晴	32.7	26.7	1.7	7.1						10.4	5	
12	晴	29.4	26.6	2.7	7.0						9.3	6	
13	曇	27.9	25.5	3.3	6.9						9.7	9	
14	晴	30.5	25.3	2.7	6.9						10.1	7	
15	曇	29.4	25.9	2.5	7.2						9.9	5	
16	晴	30.0	26.3	2.4	7.3						10.0	6	
17	晴	29.3	26.6	2.8	7.2	29.0	28.4	66.5	6.9	0.10	10.3	7	
18	晴	29.1	26.2	2.6	7.1						10.7	9	
19	晴	30.0	26.3	2.3	7.1						10.9	4	
20	晴	31.1	27.0	2.2	7.1						10.8	5	
21	晴	29.9	26.9	2.0	7.0						11.6	4	
22	晴	29.1	26.6	2.4	7.2						10.8	4	
23	晴	28.7	26.1	1.7	7.2						10.9	3	
24	晴	29.2	26.6	1.6	7.1	29.6	30.2	71.5	7.2	0.10	10.8	3	
25	晴	31.3	26.8	1.5	7.0						11.3	4	
26	晴	30.6	27.0	1.5	7.0						11.3	3	
27	晴	30.6	26.7	1.6	6.9						11.7	3	
28	曇	29.6	26.3	1.7	7.1						10.9	3	
29	晴	31.0	26.4	1.8	7.2						10.3	3	
30	晴	30.3	26.8	1.7	7.2						10.6	3	
31	晴	28.5	26.5	2.1	7.2						10.7	5	
最大	———	33.5	27.0	3.3	7.3	29.6	30.2	71.5	7.3	0.10	11.7	9	———
最小	———	27.4	22.2	1.2	6.9	27.8	27.6	64.5	6.9	0.10	8.7	2	
平均	———	29.8	25.6	2.0	7.1	28.8	28.7	67.5	7.1	0.10	10.3	4	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定