

県営第一工業用水道 水質試験結果表

2020年12月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	8.8	12.4	1.0	6.7						11.6	2	
2	晴	9.1	12.3	1.0	6.7	27.2	31.3	81.0	8.6	0.10	11.6	4	
3	曇	10.2	12.4	0.7	6.7						11.7	1	
4	晴	7.8	11.8	1.2	7.0						11.7	3	
5	曇	7.0	10.2	1.7	7.3						9.8	4	
6	晴	7.5	10.6	1.1	7.2						9.9	2	
7	曇	8.0	10.6	1.0	7.0						10.5	2	
8	雨	9.5	11.3	1.5	6.9						10.9	5	
9	曇	8.9	11.5	3.5	6.9						11.1	85	7時間53分
10	晴	9.4	11.4	3.1	6.8						11.4	69	10時間13分
11	曇	10.0	11.7	3.9	6.8						11.7	58	7時間51分
12	雨	10.0	11.9	4.2	6.7						12.0	33	9時間05分
13	曇	9.1	11.9	1.7	6.6						12.2	4	
14	雨	5.4	11.6	2.4	6.6						12.1	7	
15	雪	3.0	10.8	1.7	6.6	24.5	30.0	75.0	9.7	0.10	11.8	4	
16	雪	1.7	9.8	1.3	6.6						11.9	5	
17	雪	1.9	8.9	0.8	6.6						12.3	1	
18	雨	2.6	8.4	0.7	6.6						12.5	1	
19	雪	2.3	8.1	1.4	6.6						11.6	3	
20	雪	2.0	8.0	0.8	6.6						11.4	1	
21	雪	2.8	8.2	0.9	6.6						11.7	2	
22	晴	4.9	8.5	0.9	6.6						12.1	2	
23	晴	5.5	8.8	0.9	6.6	23.6	30.1	68.0	10.6	0.10	11.8	1	
24	曇	5.8	8.8	0.6	6.6						11.1	1	
25	雨	5.7	9.0	0.6	6.6						11.1	1	
26	雨	4.1	8.8	0.7	6.6						10.6	1	
27	晴	6.8	8.8	0.6	6.6						10.5	1	
28	曇	7.5	9.1	0.4	6.6						10.7	0	
29	晴	7.6	9.2	0.4	6.6						10.7	0	
30	雨	4.9	9.2	1.4	6.6						10.8	33	7時間23分
31	雪	1.4	8.6	3.0	6.6						9.7	12	0時間27分
最大	——	10.2	12.4	4.2	7.3	27.2	31.3	81.0	10.6	0.10	12.5	85	——
最小	——	1.4	8.0	0.4	6.6	23.6	30.0	68.0	8.6	0.10	9.7	0	——
平均	——	6.2	10.1	1.5	6.7	25.1	30.5	74.7	9.6	0.10	11.3	11	42時間52分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定