

県営第一工業用水道 水質試験結果表

2021年1月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	雪	2.3	8.1	0.8	6.6						10.0	1	
2	雪	2.3	7.7	0.6	6.6						10.7	1	
3	雨	3.1	7.4	0.5	6.6						11.2	0	
4	曇	3.2	7.3	0.4	6.6						11.3	0	
5	曇	3.9	7.4	0.8	6.6						11.1	2	
6	雨	4.0	7.7	0.6	6.6						11.0	0	
7	曇	1.9	7.8	0.5	6.6						10.9	0	
8	雪	-1.3	7.3	0.9	6.6	20.8	28.4	55.0	11.9	0.10	11.6	3	
9	雪	-1.3	7.0	0.4	6.5						12.5	0	
10	雪	1.0	5.0	1.6	6.9						9.5	24	1時間33分
11	曇	2.2	5.3	0.9	6.6						12.2	1	
12	雨	2.7	6.0	0.5	6.6						12.7	1	
13	雪	2.2	5.9	1.8	6.9						14.1	6	
14	曇	3.3	5.9	1.5	6.7						12.6	4	
15	晴	2.8	6.4	1.0	6.7	23.0	33.0	83.5	13.8	0.10	14.0	3	
16	雨	3.2	6.4	0.8	6.6						12.8	1	
17	雪	2.7	6.2	1.1	6.6						11.5	2	
18	雪	2.6	5.9	2.0	6.8						12.0	7	
19	雪	1.2	5.3	3.7	7.0						11.5	12	
20	曇	1.3	5.6	1.8	6.8						11.3	6	
21	晴	2.1	5.5	2.0	7.0						10.9	13	
22	雨	5.0	5.8	2.2	6.9						10.2	5	
23	雨	4.4	6.2	1.2	6.7						10.9	2	
24	雨	4.7	6.3	1.0	6.6						10.8	1	
25	晴	5.5	6.8	1.1	6.7	18.8	25.0	60.5	10.7	0.10	10.3	3	
26	曇	6.3	7.2	0.8	6.7						10.0	2	
27	曇	7.6	7.5	1.9	6.6						9.6	5	
28	曇	5.1	7.5	1.6	6.6						9.3	3	
29	曇	2.2	7.4	0.8	6.6						9.7	1	
30	雪	2.3	6.9	0.5	6.6						10.3	1	
31	曇	4.0	6.7	0.4	6.6						10.8	0	
最大	———	7.6	8.1	3.7	7.0	23.0	33.0	83.5	13.8	0.10	14.1	24	———
最小	———	-1.3	5.0	0.4	6.5	18.8	25.0	55.0	10.7	0.10	9.3	0	
平均	———	3.0	6.6	1.2	6.7	20.9	28.8	66.3	12.1	0.10	11.2	4	1時間33分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定