

県営第一工業用水道 水質試験結果表

2021年5月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	15.4	13.5	1.1	6.4						10.6	4	
2	雨	11.1	13.4	1.5	6.3						10.9	4	
3	曇	13.4	13.0	1.0	6.3						9.8	1	
4	晴	18.2	12.9	0.8	6.4						9.7	1	
5	雨	16.6	13.1	0.8	6.4						9.8	1	
6	晴	17.6	13.4	1.3	6.4						9.6	4	
7	曇	17.6	13.6	1.0	6.4	21.0	24.4	63.5	8.1	0.10	9.9	1	
8	晴	20.1	13.8	0.9	6.4						9.9	1	
9	曇	18.1	14.1	0.7	6.4						10.3	1	
10	晴	14.7	14.2	0.9	6.4						10.3	2	
11	曇	16.0	14.4	1.1	6.4						10.6	1	
12	曇	18.3	14.6	1.1	6.4	22.4	27.4	75.5	9.0	0.10	10.8	2	
13	晴	22.0	15.0	1.0	6.4						11.1	2	
14	曇	22.3	15.6	0.9	6.4						11.3	2	
15	晴	24.0	16.2	0.7	6.4						11.3	1	
16	雨	21.0	16.7	0.8	6.4						11.2	2	
17	雨	20.3	16.8	2.8	6.4						10.5	10	
18	曇	20.0	16.7	1.8	6.4						10.3	4	
19	曇	19.0	16.2	1.3	6.4	22.4	26.6	71.5	8.7	0.10	10.3	3	
20	曇	17.3	15.7	1.0	6.4						10.4	2	
21	雨	19.7	15.6	2.1	6.3						10.3	8	
22	曇	18.0	15.5	1.5	6.4						9.2	4	
23	曇	19.7	15.4	1.0	6.4						9.3	1	
24	曇	19.7	15.4	1.5	6.4						9.3	3	
25	曇	20.3	15.5	1.2	6.4						9.5	2	
26	曇	18.6	15.6	0.9	6.4						10.1	1	
27	雨	16.3	15.5	1.0	6.4						10.7	2	
28	晴	22.3	15.5	1.0	6.4						10.0	2	
29	晴	19.8	15.8	0.7	6.4						10.1	1	
30	晴	19.9	16.1	0.6	6.4						10.1	1	
31	晴	19.9	16.6	1.0	6.4						10.1	2	
最大	——	24.0	16.8	2.8	6.4	22.4	27.4	75.5	9.0	0.10	11.3	10	——
最小	——	11.1	12.9	0.6	6.3	21.0	24.4	63.5	8.1	0.10	9.2	1	
平均	——	18.6	15.0	1.1	6.4	21.9	26.1	70.2	8.6	0.10	10.2	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定