

県営第一工業用水道 水質試験結果表

2021年7月分

| 日 | 天候 | 気温 [°C] | 水温 [°C] | 日平均濁度 [mg/L] | pH | 酸消費量 [mg/L] | 全硬度 [mg/L] | 全蒸発残留物 [mg/L] | 塩化物イオン [mg/L] | 鉄 [mg/L] | 電気伝導率 [mS/m] | 原水最高濁度 [mg/L] | ろ過装置 運転時間 |
|----|----|------------|------------|-----------------|-----|----------------|---------------|------------------|------------------|-------------|-----------------|------------------|--------------|
| 1 | 晴 | 26.3 | 21.9 | 1.2 | 6.3 | | | | | | 15.5 | 2 | |
| 2 | 曇 | 27.2 | 22.1 | 1.2 | 6.2 | | | | | | 15.8 | 3 | |
| 3 | 曇 | 26.5 | 21.9 | 3.5 | 6.2 | | | | | | 17.9 | 15 | |
| 4 | 雨 | 27.1 | 21.7 | 1.1 | 6.2 | | | | | | 14.8 | 2 | |
| 5 | 雨 | 24.3 | 21.7 | 1.9 | 6.2 | | | | | | 13.6 | 5 | |
| 6 | 雨 | 25.4 | 21.2 | 2.4 | 6.2 | | | | | | 12.9 | 7 | |
| 7 | 曇 | 25.1 | 20.6 | 2.9 | 6.1 | 25.1 | 28.1 | 70.5 | 8.3 | 0.10 | 11.8 | 9 | |
| 8 | 雨 | 25.0 | 19.8 | 1.9 | 6.1 | | | | | | 10.4 | 4 | |
| 9 | 曇 | 26.1 | 19.4 | 1.5 | 6.1 | | | | | | 10.2 | 3 | |
| 10 | 曇 | 26.0 | 19.5 | 1.1 | 6.1 | | | | | | 10.4 | 8 | |
| 11 | 曇 | 26.6 | 19.6 | 1.6 | 6.1 | | | | | | 10.5 | 7 | |
| 12 | 曇 | 26.3 | 19.7 | 1.4 | 6.1 | | | | | | 10.5 | 3 | |
| 13 | 晴 | 27.7 | 20.0 | 1.2 | 6.2 | | | | | | 10.8 | 2 | |
| 14 | 晴 | 27.1 | 20.7 | 1.0 | 6.2 | 24.6 | 28.2 | 67.0 | 8.4 | 0.10 | 10.9 | 2 | |
| 15 | 晴 | 27.3 | 21.2 | 0.7 | 6.3 | | | | | | 11.1 | 1 | |
| 16 | 曇 | 27.8 | 21.6 | 0.7 | 6.3 | | | | | | 11.3 | 1 | |
| 17 | 晴 | 29.1 | 22.2 | 0.6 | 6.3 | | | | | | 11.5 | 1 | |
| 18 | 晴 | 29.9 | 23.0 | 0.9 | 6.5 | | | | | | 10.6 | 1 | |
| 19 | 晴 | 30.3 | 23.3 | 0.9 | 6.4 | | | | | | 11.1 | 2 | |
| 20 | 晴 | 30.7 | 23.5 | 0.8 | 6.5 | | | | | | 11.8 | 1 | |
| 21 | 晴 | 30.6 | 23.9 | 0.6 | 6.6 | | | | | | 12.1 | 1 | |
| 22 | 晴 | 30.3 | 24.3 | 0.6 | 6.5 | | | | | | 12.3 | 1 | |
| 23 | 晴 | 29.9 | 24.4 | 0.4 | 6.5 | | | | | | 12.4 | 0 | |
| 24 | 晴 | 30.1 | 25.0 | 0.6 | 6.7 | | | | | | 11.4 | 2 | |
| 25 | 雨 | 29.0 | 25.0 | 0.8 | 6.7 | | | | | | 11.3 | 2 | |
| 26 | 晴 | 29.6 | 25.1 | 0.7 | 6.7 | 29.0 | 31.6 | 75.5 | 8.4 | 0.10 | 11.7 | 2 | |
| 27 | 晴 | 28.4 | 24.8 | 0.6 | 6.6 | | | | | | 12.5 | 1 | |
| 28 | 曇 | 27.1 | 24.5 | 0.6 | 6.7 | | | | | | 12.3 | 0 | |
| 29 | 曇 | 26.3 | 24.2 | 1.6 | 6.5 | | | | | | 11.8 | 3 | |
| 30 | 晴 | 28.2 | 24.1 | 0.8 | 6.6 | | | | | | 12.1 | 1 | |
| 31 | 晴 | 28.8 | 24.2 | 0.5 | 6.5 | | | | | | 12.8 | 1 | |
| 最大 | —— | 30.7 | 25.1 | 3.5 | 6.7 | 29.0 | 31.6 | 75.5 | 8.4 | 0.10 | 17.9 | 15 | —— |
| 最小 | —— | 24.3 | 19.4 | 0.4 | 6.1 | 24.6 | 28.1 | 67.0 | 8.3 | 0.10 | 10.2 | 0 | |
| 平均 | —— | 27.7 | 22.4 | 1.2 | 6.4 | 26.2 | 29.3 | 71.0 | 8.4 | 0.10 | 12.1 | 3 | |

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定