

県営第一工業用水道 水質試験結果表

2021年9月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	25.0	22.9	0.9	6.8						11.0	3	
2	曇	24.1	22.7	2.0	6.6						10.9	4	
3	曇	23.4	22.1	1.2	6.6	26.0	27.4	71.5	7.1	0.10	10.5	2	
4	曇	23.8	21.7	0.7	6.6						10.8	1	
5	晴	24.5	22.0	1.2	6.7						10.3	7	
6	晴	23.9	22.1	1.1	6.7						10.4	2	
7	晴	24.8	22.0	1.1	6.7						10.4	3	
8	曇	23.4	21.8	1.1	6.7						10.7	3	
9	曇	23.6	21.6	1.5	6.6						10.8	3	
10	晴	23.5	21.6	1.0	6.7						10.6	1	
11	雨	23.6	21.7	0.8	6.7						10.9	1	
12	曇	23.2	21.5	0.7	6.7						11.0	1	
13	晴	23.2	21.5	0.9	6.7						11.1	1	
14	曇	22.1	21.2	1.0	6.7						11.3	2	
15	晴	23.4	21.6	1.1	6.7						11.6	2	
16	晴	24.1	21.9	0.8	6.7	30.2	31.8	71.0	8.1	0.10	11.7	1	
17	曇	24.9	21.8	0.7	6.7						11.8	1	
18	雨	23.8	21.7	0.7	6.7						11.9	1	
19	曇	24.1	21.7	0.9	6.7						11.4	2	
20	晴	25.1	22.0	0.6	6.7						11.5	1	
21	晴	25.6	22.4	0.9	6.7						11.5	2	
22	雨	23.6	22.1	1.1	6.7						11.6	4	
23	晴	23.3	21.8	1.8	6.7						11.5	4	
24	晴	22.5	22.0	0.9	6.7						11.9	1	
25	晴	22.8	21.9	0.8	6.7						12.0	1	
26	雨	22.7	22.0	1.5	6.7						11.6	6	
27	晴	22.2	21.7	1.4	6.7	30.2	30.2	70.5	7.4	0.10	11.3	4	
28	曇	23.3	21.7	0.7	6.7						11.6	1	
29	晴	25.2	22.0	0.8	6.7						12.1	5	
30	晴	24.7	22.1	0.7	6.7						12.2	1	
最大	——	25.6	22.9	2.0	6.8	30.2	31.8	71.5	8.1	0.10	12.2	7	——
最小	——	22.1	21.2	0.6	6.6	26.0	27.4	70.5	7.1	0.10	10.3	1	
平均	——	23.8	21.9	1.0	6.7	28.8	29.8	71.0	7.5	0.10	11.3	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、pH（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定