

県営第一工業用水道 水質試験結果表

2021年10月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	23.4	21.9	0.7	6.7						12.3	1	
2	晴	22.1	21.6	0.7	6.7						11.9	3	
3	晴	21.9	21.7	0.8	6.8						11.8	2	
4	晴	23.6	21.8	0.8	6.8						12.2	2	
5	晴	22.9	21.8	0.8	6.7						12.2	1	
6	雨	21.1	21.6	0.8	6.7	32.0	34.7	74.5	8.9	0.10	12.6	1	
7	晴	23.2	21.5	0.7	6.7						12.5	1	
8	晴	24.0	21.9	0.6	6.7						12.4	2	
9	晴	23.4	22.2	0.8	6.8						12.5	4	
10	晴	24.1	22.1	0.9	6.7						12.6	2	
11	晴	23.5	22.0	0.8	6.7						12.7	1	
12	曇	21.4	21.5	0.9	6.6						13.1	1	
13	雨	21.2	21.3	0.8	6.7						13.0	1	
14	晴	19.7	21.1	0.8	6.7						13.2	1	
15	晴	18.9	20.8	0.8	6.7	32.1	35.5	75.5	9.7	0.10	13.1	1	
16	晴	20.3	20.5	0.8	6.7						13.3	1	
17	曇	14.8	19.7	1.0	6.8						11.8	1	
18	晴	13.4	18.6	1.0	6.8						12.4	1	
19	晴	15.9	18.7	0.9	6.7						13.1	2	
20	曇	13.0	18.2	3.0	6.7						13.2	14	
21	晴	12.1	17.4	2.9	6.7						12.1	3	
22	晴	13.2	17.0	0.6	6.7						12.4	1	
23	晴	12.3	16.7	0.4	6.7						12.7	1	
24	晴	11.9	16.3	0.3	6.7						12.7	0	
25	曇	12.7	16.3	0.5	6.7	31.2	36.1	74.0	9.5	0.10	13.1	1	
26	晴	15.1	16.4	0.7	6.7						13.0	1	
27	曇	14.7	16.6	0.5	6.7						13.2	1	
28	晴	15.0	16.7	0.4	6.7						13.4	0	
29	晴	13.2	16.4	0.5	6.7						13.5	0	
30	晴	13.3	16.1	0.4	6.7						13.8	1	
31	曇	15.7	16.5	0.3	6.7						13.7	0	
最大	——	24.1	22.2	3.0	6.8	32.1	36.1	75.5	9.7	0.10	13.8	14	——
最小	——	11.9	16.1	0.3	6.6	31.2	34.7	74.0	8.9	0.10	11.8	0	
平均	——	18.1	19.4	0.8	6.7	31.8	35.4	74.7	9.4	0.10	12.8	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定