

県営第一工業用水道 水質試験結果表

2021年11月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	15.6	16.7	0.5	6.7						13.9	0	
2	晴	15.2	16.9	0.6	6.7						14.2	1	
3	晴	14.2	16.8	0.6	6.7						14.2	1	
4	晴	13.1	16.5	0.6	6.7						14.1	1	
5	晴	12.6	16.3	0.6	6.7	31.9	39.2	85.5	10.8	0.10	14.3	1	
6	晴	12.3	16.0	0.5	6.7						14.6	2	
7	晴	13.3	16.0	0.7	6.7						14.3	2	
8	晴	16.6	16.1	0.8	6.7						14.2	1	
9	雨	14.8	16.1	1.9	6.7						13.9	4	
10	晴	12.6	15.6	1.9	6.7						13.1	3	
11	晴	12.6	15.2	0.9	6.7						13.1	1	
12	雨	9.3	14.7	0.9	6.7						13.2	1	
13	晴	9.9	14.2	1.4	6.7						12.4	9	
14	晴	11.1	13.7	1.2	6.7						11.8	1	
15	晴	12.0	13.9	0.9	6.7	28.3	33.0	68.5	8.7	0.10	12.2	2	
16	晴	10.7	13.9	0.6	6.7						12.6	1	
17	雨	9.7	13.8	0.6	6.7						12.9	0	
18	晴	11.2	13.7	0.6	6.6						13.2	0	
19	晴	11.6	13.8	0.5	6.6						13.4	0	
20	晴	11.3	13.8	0.4	6.6						13.5	0	
21	晴	11.5	13.8	0.3	6.6						13.6	0	
22	雨	12.4	13.8	1.1	6.7						13.5	5	
23	雨	8.0	13.6	2.5	6.6						12.3	4	
24	雨	7.9	12.9	1.4	6.6	25.0	32.1	74.5	9.9	0.10	12.3	3	
25	雨	9.7	12.4	0.9	6.6						11.8	1	
26	雨	10.1	12.3	0.8	6.6						11.5	6	
27	晴	6.5	12.1	2.3	6.6						11.0	7	
28	晴	6.0	11.7	0.8	6.6						10.9	1	
29	晴	6.0	11.3	0.8	6.6						10.9	1	
30	晴	10.9	11.1	0.7	6.6						11.1	1	
最大	——	16.6	16.9	2.5	6.7	31.9	39.2	85.5	10.8	0.10	14.6	9	——
最小	——	6.0	11.1	0.3	6.6	25.0	32.1	68.5	8.7	0.10	10.9	0	
平均	——	11.3	14.3	0.9	6.7	28.4	34.8	76.2	9.8	0.10	12.9	2	

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定