

県営第一工業用水道 水質試験結果表

2022年4月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	7.7	9.7	5.9	6.6						7.9	11	
2	晴	6.9	9.3	3.5	6.6						8.2	5	
3	晴	9.3	9.4	2.8	6.6						8.4	9	
4	晴	10.4	9.9	2.8	6.5						8.8	8	
5	晴	12.5	10.2	2.0	6.5						9.2	4	
6	晴	13.6	10.7	1.5	6.4	18.5	23.5	50.0	8.3	0.10	9.3	2	
7	晴	14.2	11.1	1.2	6.4						9.4	2	
8	晴	12.4	11.5	1.0	6.3						9.7	1	
9	晴	15.8	11.6	0.7	6.3						9.9	1	
10	晴	18.4	12.1	0.7	6.3						9.7	0	
11	曇	19.8	12.6	1.1	6.3						9.5	2	
12	晴	20.6	13.1	1.3	6.3						9.4	2	
13	曇	19.9	13.1	1.3	6.3	17.8	21.6	55.0	8.1		9.3	2	
14	曇	15.6	13.0	1.2	6.2						9.2	2	
15	曇	12.6	12.7	1.2	6.2						9.4	1	
16	雨	10.7	12.3	0.9	6.2						10.1	1	
17	晴	11.5	12.0	0.7	6.3						10.0	0	
18	晴	14.2	12.1	1.1	6.3						10.1	2	
19	晴	13.3	12.6	1.9	6.3						11.0	20	1時間26分
20	晴	15.7	12.7	2.4	6.4						9.7	3	
21	曇	16.2	13.1	2.2	6.4						10.0	3	
22	曇	17.7	13.6	2.5	6.4						10.5	3	
23	曇	16.6	13.7	1.8	6.3						11.1	3	
24	曇	18.0	13.8	1.0	6.3						11.7	1	
25	晴	20.5	14.2	1.5	6.3						11.4	10	
26	曇	20.7	14.8	1.3	6.3						12.6	4	
27	雨	16.6	15.2	5.0	6.3	20.2	27.0	64.5	9.8		11.3	11	
28	晴	15.0	14.7	2.3	6.3						11.1	4	
29	曇	11.7	14.4	1.4	6.3						11.6	3	
30	晴	13.0	13.9	2.2	6.3						10.9	9	
最大	——	20.7	15.2	5.9	6.6	20.2	27.0	64.5	9.8	0.10	12.6	20	——
最小	——	6.9	9.3	0.7	6.2	17.8	21.6	50.0	8.1	0.10	7.9	0	
平均	——	14.7	12.4	1.9	6.4	18.8	24.0	56.5	8.7	0.10	10.0	4	1時間26分

標準値  
 測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定