

県営第一工業用水道 水質試験結果表

2022年5月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	雨	12.3	13.6	3.0	6.3						10.5	6	
2	晴	12.5	13.4	3.1	6.3						10.4	6	
3	晴	13.0	13.3	1.5	6.3						10.7	2	
4	晴	17.7	13.5	1.3	6.3						11.0	2	
5	晴	20.2	14.0	1.2	6.3						11.2	1	
6	晴	20.6	14.7	1.1	6.3						11.5	2	
7	晴	20.1	15.2	0.9	6.3						11.8	2	
8	晴	15.4	15.5	0.7	6.3						12.2	1	
9	曇	12.6	15.1	2.5	6.4						12.7	26	1時間35分
10	晴	16.0	14.5	5.1	6.5						10.8	8	
11	曇	19.0	15.4	2.8	6.4	23.5	30.2	72.0	10.9	0.10	12.4	4	
12	曇	21.2	15.9	2.3	6.4						14.2	16	
13	曇	20.4	16.3	3.2	6.4						12.2	5	
14	雨	17.4	16.3	3.9	6.3						13.1	6	
15	曇	15.9	15.9	2.4	6.3						12.6	6	
16	曇	16.5	15.7	2.3	6.4						11.9	6	
17	曇	16.8	15.8	2.3	6.5						13.6	6	
18	晴	18.6	15.9	4.2	6.6						10.9	7	
19	晴	20.2	16.4	2.1	6.4						12.9	3	
20	晴	20.3	16.5	1.3	6.3	25.1	36.7	87.5	13.9	0.10	15.7	2	
21	曇	19.7	16.6	0.6	6.2						17.5	1	
22	晴	21.4	16.8	0.5	6.2						16.4	0	
23	晴	20.8	17.5	0.9	6.3						14.5	1	
24	晴	22.2	18.1	1.2	6.3						16.6	3	
25	晴	24.8	19.0	1.4	6.3	26.2	35.3	86.5	14.5	0.10	15.5	3	
26	曇	23.8	19.3	1.5	6.4						14.8	2	
27	曇	21.6	19.1	1.5	6.3						18.7	2	
28	曇	21.5	18.9	0.7	6.3						16.7	1	
29	晴	23.5	18.9	0.3	6.3						19.2	0	
30	晴	24.1	19.5	0.7	6.4						22.6	1	
31	曇	20.2	19.3	1.0	6.4						20.8	2	
最大	——	24.8	19.5	5.1	6.6	26.2	36.7	87.5	14.5	0.10	22.6	26	——
最小	——	12.3	13.3	0.3	6.2	23.5	30.2	72.0	10.9	0.10	10.4	0	
平均	——	19.0	16.3	1.9	6.3	24.9	34.1	82.0	13.1	0.10	14.1	4	1時間35分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟
 他項目は日野川地区水道管理事務所にて測定