

県営第一工業用水道 水質試験結果表

2022年7月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	30.4	25.2	1.0	6.6						47.1	2	
2	晴	30.8	25.2	1.0	6.6						39.2	2	
3	雨	26.2	25.0	0.9	6.6						32.4	3	
4	曇	28.2	24.6	1.9	6.4						24.0	3	
5	曇	28.3	24.5	1.3	6.5						18.4	2	
6	曇	28.4	25.0	1.1	6.4	33.9	37.3	101.5	16.8	0.10	18.5	1	
7	曇	27.9	25.5	1.0	6.4						22.7	1	
8	曇	28.1	25.5	1.1	6.4						31.9	1	
9	曇	26.5	25.4	1.0	6.4						36.8	1	
10	曇	27.6	25.2	3.5	6.4						19.2	9	
11	晴	29.2	25.4	1.7	6.4						19.6	2	
12	曇	27.1	25.5	4.9	6.3						19.0	72	10時間10分
13	曇	26.2	24.8	3.2	6.4	30.2	31.8	88.5	13.9	0.10	16.8	52	3時間47分
14	曇	24.8	24.0	1.4	6.4						17.5	4	
15	曇	26.6	23.6	3.0	6.4						15.1	5	
16	曇	27.8	23.5	1.4	6.4						14.2	2	
17	曇	27.4	23.6	0.9	6.4						14.1	1	
18	曇	27.4	23.8	0.9	6.4						13.9	1	
19	雨	26.1	23.8	3.9	6.4						13.2	11	
20	曇	27.4	23.6	5.3	6.4						13.1	13	
21	曇	25.6	23.4	1.8	6.4						12.9	3	
22	雨	25.7	23.3	1.5	6.4						13.1	2	
23	雨	24.6	23.1	1.3	6.4						13.3	1	
24	晴	27.7	23.0	0.9	6.4						13.0	1	
25	晴	29.4	23.6	0.8	6.4	27.9	29.0	65.5	10.0	0.10	13.2	1	
26	晴	29.0	24.0	0.8	6.4						14.2	1	
27	曇	28.9	24.4	0.6	6.4						15.3	1	
28	晴	29.9	24.7	3.8	6.4						15.0	11	
29	晴	30.7	25.0	1.2	6.4						15.1	2	
30	晴	31.6	25.2	0.6	6.4						17.0	1	
31	晴	32.2	25.7	0.5	6.5						19.9	0	
最大	——	32.2	25.7	5.3	6.6	33.9	37.3	101.5	16.8	0.10	47.1	72	——
最小	——	24.6	23.0	0.5	6.3	27.9	29.0	65.5	10.0	0.10	12.9	0	
平均	——	28.0	24.5	1.7	6.4	30.7	32.7	85.2	13.6	0.10	19.6	7	13時間57分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定