

県営第一工業用水道 水質試験結果表

2023年8月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	32.3	26.8	1.8	6.5						12.1	9	
2	晴	32.5	27.0	1.6	6.5	27.7	30.2	64.5	7.9	0.10	12.3	2	
3	晴	33.3	27.0	1.6	6.5						12.5	2	
4	晴	33.3	27.2	1.4	6.5						12.7	2	
5	晴	33.4	27.3	1.3	6.4						12.8	4	
6	晴	32.7	27.2	1.1	6.4						13.3	2	
7	晴	31.5	27.1	1.5	6.4						13.1	4	
8	曇	32.0	26.3	1.7	6.5						13.0	4	
9	晴	32.2	26.4	1.7	6.5						13.0	4	
10	晴	33.4	26.8	1.8	6.4						13.4	4	
11	晴	31.7	27.0	1.4	6.3						15.0	3	
12	晴	30.5	26.9	1.1	6.3						16.4	4	
13	晴	30.3	27.0	0.9	6.3						14.6	2	
14	曇	29.1	26.5	1.0	6.4						13.8	3	
15	曇	28.4	25.2	1.5	6.5						13.4	6	
16	曇	28.8	24.6	3.9	6.4	25.3	29.9	64.0	7.7	0.10	11.9	123	18時間53分
17	曇	28.8	25.3	4.4	6.5						12.5	91	5時間50分
18	曇	29.4	25.2	4.0	6.6						13.0	8	
19	晴	30.7	25.7	3.4	6.4						13.5	7	
20	晴	30.6	26.2	2.6	6.3						14.2	13	
21	晴	31.3	26.8	2.7	6.3						19.1	11	
22	晴	31.3	26.7	4.9	6.4						13.0	22	1時間32分
23	晴	30.8	26.7	4.0	6.4	28.9	32.8	71.5	8.2	0.10	13.4	6	
24	曇	29.3	26.0	3.9	6.4						13.3	5	
25	晴	30.8	26.0	3.9	6.4						12.8	5	
26	晴	29.7	26.1	3.3	6.3						13.8	4	
27	晴	29.0	26.1	1.8	6.2						15.6	1	
28	晴	29.1	26.1	3.0	6.4						13.2	12	
29	晴	30.9	26.4	2.9	6.3						13.9	17	
30	曇	30.2	26.2	2.1	6.3						18.8	4	
31	晴	31.7	25.9	1.8	6.3						14.7	3	
最大	——	33.4	27.3	4.9	6.6	28.9	32.8	71.5	8.2	0.10	19.1	123	——
最小	——	28.4	24.6	0.9	6.2	25.3	29.9	64.0	7.7	0.10	11.9	1	
平均	——	30.9	26.4	2.4	6.4	27.3	31.0	66.7	7.9	0.10	13.8	12	26時間15分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場  
 水温、濁度、pH（3項目ともに日平均）は配水池管理棟  
 他項目は日野川地区水道管理事務所にて測定