

水質試験結果表(取水分)

2011年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	25.4	22.2	3.6	7.0	27.4	32.0	52.8	9.9	0.28	ND	84.4
2	土	29.1	22.0	6.6	7.3	24.1	27.1	52.4	8.2	0.32	0.02	77.2
3	日	29.0	22.1	3.5	7.2	27.0	31.2	53.2	9.5	0.22	0.01	85.2
4	月	31.3	22.4	3.6	7.1	26.5	31.2	56.4	9.9	0.24	0.01	86.6
5	火	26.0	21.8	20.2	6.8	16.4	23.1	70.0	8.3	0.91	0.04	66.0
6	水	28.3	20.2	9.1	7.1	21.4	25.1	56.8	9.7	0.41	0.03	71.0
7	木	25.1	21.2	5.4	7.1	25.2	27.1	51.2	8.8	0.29	0.02	74.5
8	金	30.1	20.2	332.0	6.6	11.0	18.7	413.6	10.0	1.76	0.06	50.4
9	土	32.8	21.0	20.0	7.2	24.0	25.9	84.4	14.3	1.08	0.04	99.9
10	日	31.6	23.0	10.4	7.3	26.7	29.5	74.8	17.4	0.56	0.01	115.4
11	月	33.2	25.0	10.4	7.2	27.4	32.8	88.0	19.2	0.62	0.02	131.6
12	火	33.5	25.2	8.3	7.2	31.9	35.0	88.4	20.6	0.47	ND	143.7
13	水	32.2	25.0	11.1	7.1	30.4	37.6	106.8	24.8	0.80	0.03	159.1
14	木	31.7	23.3	6.4	7.2	26.7	28.1	48.8	10.1	0.41	0.01	76.7
15	金	33.4	23.7	5.7	7.2	29.8	29.5	52.0	7.7	0.38	0.03	76.0
16	土	32.8	24.5	3.9	7.3	33.3	29.7	52.8	9.7	0.33	ND	81.3
17	日	33.4	25.5	4.0	7.4	29.7	34.6	56.0	9.3	0.38	ND	92.4
18	月	31.2	26.0	4.2	7.4	32.5	36.0	62.4	10.0	0.37	0.01	94.1
19	火	28.3	24.0	3.9	7.3	31.3	35.4	64.4	11.4	0.37	0.01	92.8
20	水	30.3	23.0	5.1	7.3	28.2	29.9	56.0	7.6	0.35	0.02	81.1
21	木	28.7	23.7	4.1	7.3	27.5	28.1	48.0	7.2	0.31	0.01	79.3
22	金	24.7	22.0	5.5	7.4	27.8	28.1	46.8	7.3	0.28	0.01	76.4
23	土	28.5	22.0	2.0	7.4	28.7	33.6	54.0	6.9	0.13	0.01	80.7
24	日	26.4	22.5	2.2	7.4	30.1	32.8	52.0	8.3	0.24	0.01	83.5
25	月	31.8	23.3	2.8	7.3	30.4	34.8	64.0	11.3	0.34	0.01	86.3
26	火	28.8	22.9	3.5	7.3	28.4	34.8	52.0	8.0	0.30	0.01	79.5
27	水	30.3	23.4	2.8	7.3	29.2	32.0	44.4	8.5	0.26	0.01	83.1
28	木	26.5	23.0	3.7	7.3	28.7	32.0	44.8	8.6	0.29	0.01	79.8
29	金	27.9	22.2	8.4	7.3	26.0	28.5	50.4	8.9	0.40	0.02	73.3
30	土	26.6	22.0	3.9	7.4	28.6	28.7	52.8	7.6	0.29	0.01	77.5
31	日	27.8	23.0	4.6	7.4	27.9	30.6	47.2	9.5	0.32	0.02	76.8
最大値		33.5	26.0	332.0	7.4	33.3	37.6	413.6	24.8	1.76	0.06	159.1
最小値		24.7	20.2	2.0	6.6	11.0	18.7	44.4	6.9	0.13	ND	50.4
平均値		29.6	22.9	16.8	7.2	27.2	30.4	70.9	10.6	0.44	0.02	87.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2011年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	25.4	22.4	0.7	7.2	26.8	31.4	44.8	11.4	0.05	ND	83.0
2	土	29.1	22.2	1.2	7.4	23.0	26.1	44.0	9.3	0.06	0.01	75.3
3	日	29.0	22.4	0.6	7.4	27.0	29.1	41.6	10.1	0.04	ND	83.3
4	月	31.3	22.8	0.5	7.4	25.5	30.4	50.8	11.2	0.03	ND	85.7
5	火	26.0	22.2	2.6	7.0	16.8	21.1	38.0	9.0	0.09	0.01	65.7
6	水	28.3	20.9	2.0	7.2	20.9	24.1	41.2	10.7	0.07	ND	69.8
7	木	25.1	21.5	0.7	7.3	28.0	30.2	40.0	9.9	0.03	ND	73.6
8	金	30.1	21.0	9.4	7.1	17.3	21.5	42.8	10.9	0.28	0.04	67.7
9	土	32.8	22.0	1.9	7.2	23.5	24.9	60.0	19.3	0.09	ND	110.7
10	日	31.6	23.2	1.2	7.3	27.5	31.2	62.0	18.8	0.07	ND	119.8
11	月	33.2	24.7	0.9	7.2	28.0	33.2	75.2	20.6	0.04	ND	135.3
12	火	33.5	25.5	0.9	7.1	29.6	35.8	83.2	22.9	0.04	ND	149.2
13	水	32.2	25.2	0.1	7.1	28.9	37.0	88.4	26.0	0.02	ND	165.7
14	木	31.7	23.5	1.0	7.2	27.2	28.3	46.0	10.5	0.04	ND	79.4
15	金	33.4	24.0	0.4	7.2	28.7	29.9	44.4	11.1	0.03	ND	79.8
16	土	32.8	24.7	0.5	7.3	32.6	29.5	46.0	10.6	0.03	ND	82.0
17	日	33.4	26.0	1.2	7.4	30.7	35.0	52.4	10.7	0.08	ND	92.1
18	月	31.2	26.2	0.7	7.4	29.7	34.0	54.8	13.1	0.03	ND	95.8
19	火	28.3	24.4	0.7	7.3	29.8	34.8	54.8	13.6	0.03	ND	95.2
20	水	30.3	22.8	1.1	7.3	27.6	32.2	48.0	10.0	0.05	ND	84.7
21	木	28.7	23.9	0.7	7.2	29.3	28.7	43.2	9.0	0.04	ND	80.4
22	金	24.7	22.0	1.0	7.3	26.9	29.5	43.6	9.4	0.07	ND	79.0
23	土	28.5	22.0	0.2	7.4	26.9	28.7	49.6	9.7	0.03	ND	80.1
24	日	26.4	22.8	0.1	7.4	28.5	34.8	48.0	9.7	0.02	ND	84.4
25	月	31.8	23.7	0.1	7.3	29.4	32.6	56.0	10.3	0.02	ND	87.1
26	火	28.8	23.0	0.3	7.3	25.7	35.0	44.0	10.3	0.03	ND	80.7
27	水	30.3	23.3	0.3	7.4	28.3	31.6	41.2	11.1	0.03	ND	84.8
28	木	26.5	23.0	0.5	7.3	29.0	32.4	40.0	12.3	0.02	ND	82.9
29	金	27.9	22.4	2.2	7.2	24.0	28.3	45.2	12.6	0.08	0.01	76.0
30	土	26.6	22.0	0.6	7.4	28.0	30.6	48.4	10.0	0.03	ND	81.3
31	日	27.8	23.0	0.5	7.3	27.0	33.0	40.0	10.1	0.03	ND	78.0
最大値		33.5	26.2	9.4	7.4	32.6	37.0	88.4	26.0	0.28	0.04	165.7
最小値		24.7	20.9	0.1	7.0	16.8	21.1	38.0	9.0	0.02	ND	65.7
平均値		29.6	23.2	1.1	7.3	26.8	30.5	50.2	12.4	0.05	ND	90.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所