

水質試験結果表(取水分)

2011年12月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	10.0	11.5	1.8	7.6	29.1	31.2	58.0	10.0	0.16	ND	86.9
2	金	11.4	10.6	1.4	7.5	30.4	33.0	56.0	10.5	0.13	ND	91.4
3	土	9.8	10.5	1.4	7.7	29.9	35.0	65.2	11.8	0.12	0.02	91.7
4	日	11.7	11.3	7.3	7.6	28.0	30.2	56.0	11.1	0.36	0.03	78.6
5	月	10.5	11.0	3.0	7.6	26.1	27.5	54.8	10.5	0.21	ND	76.1
6	火	7.2	9.9	2.1	7.6	26.0	28.3	56.0	11.1	0.15	ND	76.2
7	水	8.2	9.6	1.8	7.4	25.7	28.5	54.4	9.9	0.13	ND	74.8
8	木	9.3	10.6	2.6	7.5	25.5	26.7	52.0	9.4	0.16	ND	73.7
9	金	3.0	9.9	2.8	7.4	24.6	25.3	48.4	9.5	0.16	0.01	72.8
10	土	7.0	9.0	1.6	7.5	27.0	27.3	48.0	9.2	0.14	ND	74.0
11	日	6.0	9.1	2.8	7.5	29.8	28.5	46.0	10.4	0.16	ND	76.3
12	月	8.0	8.9	2.3	7.5	29.6	29.7	50.8	11.6	0.19	0.01	80.3
13	火	17.5	9.4	2.7	7.5	24.7	26.9	52.8	10.0	0.18	ND	73.4
14	水	11.3	9.0	3.2	7.5	26.5	27.5	52.0	10.4	0.18	ND	74.3
15	木	9.4	9.3	2.1	7.4	24.9	28.3	50.8	10.6	0.16	0.01	73.3
16	金	6.6	9.4	3.1	7.5	25.1	26.3	54.0	10.4	0.19	0.01	73.5
17	土	3.1	7.5	2.7	7.5	25.8	26.1	57.6	10.6	0.19	0.01	74.5
18	日	4.1	7.9	1.5	7.6	27.8	28.1	55.2	13.1	0.16	ND	77.6
19	月	4.2	7.3	2.4	7.6	30.3	28.5	49.6	14.2	0.16	ND	76.2
20	火	4.8	7.7	3.3	7.5	24.1	26.3	59.2	12.0	0.18	ND	73.1
21	水	3.9	7.3	6.7	7.3	23.3	28.7	74.0	17.3	0.39	0.04	105.6
22	木	5.3	8.0	15.9	7.2	21.0	26.9	76.0	17.4	0.70	0.04	96.0
23	金	4.3	7.8	11.9	7.4	20.2	28.5	74.0	18.4	0.65	0.05	98.8
24	土	1.7	7.3	5.7	7.3	23.2	30.2	71.2	18.4	0.39	0.03	103.8
25	日	1.4	7.2	4.5	7.3	25.2	31.8	73.2	20.2	0.31	0.02	114.7
26	月	1.9	5.0	3.7	7.4	25.9	32.8	63.2	20.5	0.29	0.02	115.7
27	火	4.8	5.2	4.0	7.3	26.1	33.0	72.0	21.6	0.28	ND	124.7
28	水	11.6	6.0	4.6	7.3	28.1	33.8	88.0	20.4	0.25	0.01	121.3
29	木	4.3	6.5	2.7	7.4	29.3	34.4	89.2	19.9	0.20	0.02	121.5
30	金	3.9	6.2	5.6	7.4	29.0	32.6	76.8	25.9	0.41	0.02	111.3
31	土	6.5	6.0	3.2	7.4	30.2	30.4	78.0	24.5	0.30	0.02	111.7
最大値		17.5	11.5	15.9	7.7	30.4	35.0	89.2	25.9	0.70	0.05	124.7
最小値		1.4	5.0	1.4	7.2	20.2	25.3	46.0	9.2	0.12	ND	72.8
平均値		6.9	8.4	3.9	7.5	26.5	29.4	61.7	14.2	0.25	0.01	89.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2011年12月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	10.0	11.3	0.8	7.5	29.0	32.2	57.6	11.9	0.10	ND	87.5
2	金	11.4	10.5	0.9	7.5	29.6	33.4	58.0	12.4	0.09	ND	90.7
3	土	9.8	10.5	1.3	7.6	29.9	33.6	62.4	13.0	0.10	ND	92.1
4	日	11.7	11.1	0.8	7.4	27.2	28.7	48.4	13.9	0.04	ND	86.2
5	月	10.5	11.2	0.4	7.4	24.8	26.3	52.0	12.2	0.03	ND	79.5
6	火	7.2	10.0	0.9	7.4	24.7	29.5	55.6	11.8	0.07	ND	78.0
7	水	8.2	9.6	1.1	7.4	25.8	29.3	52.4	11.1	0.07	ND	76.6
8	木	9.3	10.3	1.3	7.4	23.8	28.7	50.4	12.3	0.07	ND	76.1
9	金	3.0	10.0	1.0	7.3	25.6	26.9	42.8	11.6	0.05	ND	84.1
10	土	7.0	9.0	0.9	7.4	26.9	27.7	45.6	10.9	0.06	ND	75.5
11	日	6.0	8.9	1.1	7.4	29.0	29.3	46.0	12.6	0.06	ND	79.5
12	月	8.0	8.6	0.8	7.4	27.1	28.7	49.2	13.3	0.04	ND	82.1
13	火	17.5	9.5	0.8	7.4	24.3	27.5	48.8	11.1	0.05	ND	76.4
14	水	11.3	9.1	1.2	7.4	24.2	27.9	47.2	12.1	0.05	ND	75.0
15	木	9.4	9.2	0.9	7.4	24.9	27.5	52.0	12.0	0.05	ND	75.3
16	金	6.6	9.5	1.1	7.4	24.7	27.3	52.0	11.8	0.05	ND	76.4
17	土	3.1	7.6	1.2	7.5	25.0	27.9	57.2	12.9	0.04	ND	77.1
18	日	4.1	7.8	0.9	7.5	27.1	28.5	49.2	13.8	0.06	ND	79.7
19	月	4.2	7.2	1.2	7.5	29.8	28.9	51.2	14.9	0.04	ND	80.6
20	火	4.8	7.3	1.2	7.3	23.0	26.7	56.0	13.8	0.05	ND	76.0
21	水	3.9	7.2	1.2	7.1	20.4	28.7	68.4	18.3	0.05	ND	107.6
22	木	5.3	7.9	2.4	7.0	17.5	26.5	60.0	18.8	0.10	ND	101.0
23	金	4.3	7.9	1.7	7.1	17.9	27.7	64.0	20.5	0.08	ND	103.3
24	土	1.7	7.1	1.2	7.2	19.4	28.1	62.0	19.2	0.06	0.01	106.0
25	日	1.4	7.5	1.3	7.3	23.5	31.4	70.4	21.6	0.07	ND	115.6
26	月	1.9	5.0	1.0	7.2	21.8	31.8	60.0	21.7	0.06	ND	119.3
27	火	4.8	5.1	1.3	7.2	25.9	33.0	71.2	22.9	0.08	ND	125.9
28	水	11.6	5.6	1.2	7.2	27.3	33.4	85.2	22.8	0.07	ND	127.1
29	木	4.3	6.3	1.5	7.4	28.9	33.8	88.4	23.6	0.08	ND	123.4
30	金	3.9	6.3	1.2	7.4	28.5	31.2	77.2	26.7	0.07	0.01	125.4
31	土	6.5	5.8	1.5	7.2	29.5	29.9	84.8	26.9	0.06	0.01	112.9
最大値		17.5	11.3	2.4	7.6	29.9	33.8	88.4	26.9	0.10	0.01	127.1
最小値		1.4	5.0	0.4	7.0	17.5	26.3	42.8	10.9	0.03	ND	75.0
平均値		6.9	8.4	1.1	7.3	25.4	29.4	58.9	15.9	0.06	ND	92.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所