

水質試験結果表(取水分)

2013年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	12.9	12.6	13.8	7.1	23.8	29.9	73.6	9.9	0.57	0.06	90.9
2	木	14.0	11.9	12.9	7.2	25.1	30.6	78.0	12.3	0.63	0.09	99.6
3	金	14.8	12.3	12.8	7.5	28.2	34.0	88.0	18.1	0.73	0.08	109.3
4	土	16.6	13.0	14.8	7.4	30.3	36.4	114.0	26.9	0.84	0.09	159.2
5	日	17.9	12.4	6.2	7.4	26.0	27.9	58.4	10.9	0.36	0.02	74.9
6	月	21.3	13.3	6.9	7.5	28.0	26.7	60.0	9.2	0.40	0.04	75.8
7	火	16.3	13.1	8.3	7.3	28.4	29.3	52.8	7.6	0.47	0.03	74.3
8	水	18.2	12.2	6.1	7.3	24.7	26.5	54.4	7.4	0.28	0.01	71.1
9	木	17.9	12.5	5.8	7.3	25.0	26.6	48.8	8.0	0.28	0.02	72.6
10	金	18.7	13.4	5.6	7.3	25.8	26.1	55.2	7.3	0.28	0.01	70.4
11	土	17.8	13.5	4.9	7.3	23.3	25.3	49.2	5.5	0.27	0.03	69.1
12	日	18.5	16.0	12.0	7.2	19.4	23.7	50.4	6.2	0.46	0.06	61.9
13	月	24.7	14.8	6.1	7.2	21.3	24.5	55.6	6.7	0.34	0.04	65.2
14	火	23.6	15.2	5.1	7.1	23.6	24.7	46.4	7.1	0.26	0.01	65.9
15	水	26.4	16.0	4.4	7.2	26.9	25.3	42.0	8.0	0.22	0.02	67.2
16	木	18.6	17.0	3.2	7.1	23.5	26.7	50.0	7.2	0.18	0.01	67.4
17	金	19.8	14.8	4.6	7.2	27.3	25.3	53.6	7.7	0.24	0.01	68.5
18	土	23.3	15.7	3.3	7.3	26.1	25.7	50.0	7.1	0.22	0.01	72.0
19	日	21.6	16.8	3.3	7.3	25.2	26.1	56.8	6.9	0.23	0.01	74.2
20	月	20.6	15.5	4.0	7.2	24.0	27.9	52.8	7.0	0.24	ND	70.8
21	火	24.9	16.2	4.2	7.2	23.1	27.1	53.6	6.9	0.24	0.01	67.3
22	水	26.8	16.9	3.8	7.2	24.9	26.1	44.4	6.9	0.24	0.01	71.5
23	木	26.1	17.0	3.0	7.2	26.4	28.3	46.4	7.2	0.19	0.01	72.8
24	金	22.9	17.0	2.5	7.2	26.9	28.9	49.6	7.4	0.24	0.02	75.3
25	土	25.3	17.5	2.7	7.3	26.4	28.3	54.0	7.1	0.21	ND	78.3
26	日	25.8	18.7	2.0	7.3	27.0	28.5	52.4	9.3	0.17	ND	78.4
27	月	26.6	18.9	2.8	7.3	27.0	29.1	56.0	8.5	0.29	0.01	79.2
28	火	24.0	18.3	2.4	7.2	28.1	29.1	57.2	7.2	0.19	0.01	79.3
29	水	19.6	17.8	2.4	7.1	28.2	29.1	54.8	7.7	0.16	0.01	79.0
30	木	19.7	17.2	4.5	7.0	26.2	26.7	56.0	7.1	0.25	0.01	72.6
31	金	24.9	16.4	4.0	7.2	25.5	27.9	53.6	6.5	0.25	0.01	74.7
最大値		26.8	18.9	14.8	7.5	30.3	36.4	114.0	26.9	0.84	0.09	159.2
最小値		12.9	11.9	2.0	7.0	19.4	23.7	42.0	5.5	0.16	ND	61.9
平均値		21.0	15.3	5.8	7.2	25.7	27.7	57.0	8.7	0.32	0.02	77.7

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2013年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	12.9	13.7	1.2	6.9	21.4	29.3	65.2	13.9	0.03	ND	100.4
2	木	14.0	12.2	1.4	7.0	22.0	29.7	66.8	14.7	0.03	ND	101.2
3	金	14.8	12.5	1.2	7.2	24.7	30.4	68.4	17.1	0.05	0.01	108.8
4	土	16.6	13.2	1.0	7.1	28.5	32.2	70.4	17.8	0.05	0.01	116.5
5	日	17.9	13.0	0.8	7.2	29.6	27.1	54.4	11.7	0.06	ND	83.1
6	月	21.3	13.7	0.8	7.2	27.9	28.3	50.4	10.0	0.03	ND	79.1
7	火	16.3	14.0	0.7	7.2	25.7	29.9	45.6	9.3	0.02	ND	77.4
8	水	18.2	13.1	1.7	7.1	23.3	27.3	52.0	8.8	0.05	ND	73.8
9	木	17.9	13.2	1.2	7.2	23.7	25.5	48.0	8.6	0.04	ND	74.7
10	金	18.7	14.0	1.1	7.1	23.5	26.9	55.2	8.3	0.05	ND	73.5
11	土	17.8	14.0	1.1	7.2	19.3	26.3	48.0	8.1	0.04	0.01	72.3
12	日	18.5	16.5	1.1	7.1	17.7	22.9	46.4	8.9	0.04	0.01	67.5
13	月	24.7	15.2	0.9	7.1	21.3	25.7	42.8	8.4	0.04	ND	67.8
14	火	23.6	16.0	1.0	7.0	22.5	25.5	38.4	8.5	0.03	ND	67.6
15	水	26.4	16.2	2.0	7.1	25.4	27.3	36.4	8.2	0.10	ND	67.9
16	木	18.6	17.0	1.1	7.0	22.6	25.3	48.0	8.4	0.04	ND	68.4
17	金	19.8	15.2	1.3	7.1	26.7	25.3	48.0	8.9	0.04	ND	70.2
18	土	23.3	16.3	1.3	7.2	25.0	25.9	52.4	9.7	0.05	ND	73.9
19	日	21.6	17.4	1.0	7.2	23.9	27.7	51.6	8.5	0.05	ND	76.4
20	月	20.6	16.3	1.5	7.2	22.3	25.9	46.8	7.8	0.08	ND	71.6
21	火	24.9	16.8	1.5	7.1	22.6	27.1	42.4	8.1	0.06	ND	68.3
22	水	26.8	18.0	1.2	7.1	25.3	27.3	40.0	8.2	0.04	ND	72.3
23	木	26.1	18.0	1.3	7.2	25.4	27.5	48.0	8.7	0.07	ND	74.6
24	金	22.9	18.0	1.4	7.1	25.6	27.9	51.2	8.7	0.07	ND	76.3
25	土	25.3	18.0	1.3	7.3	26.4	27.7	53.2	8.8	0.08	ND	79.8
26	日	25.8	19.4	1.1	7.3	25.8	28.1	53.2	10.1	0.09	ND	80.1
27	月	26.6	20.3	1.1	7.3	26.7	29.5	50.8	8.8	0.12	ND	80.3
28	火	24.0	19.3	1.1	7.2	26.0	29.7	50.8	8.9	0.09	ND	80.5
29	水	19.6	18.2	1.2	7.2	26.5	29.3	43.2	9.2	0.10	ND	79.8
30	木	19.7	18.2	0.9	7.0	24.4	26.5	53.6	7.8	0.04	ND	75.8
31	金	24.9	16.3	1.2	7.1	24.3	27.9	52.8	7.9	0.07	ND	76.0
最大値		26.8	20.3	2.0	7.3	29.6	32.2	70.4	17.8	0.12	0.01	116.5
最小値		12.9	12.2	0.7	6.9	17.7	22.9	36.4	7.8	0.02	ND	67.5
平均値		21.0	15.9	1.2	7.1	24.4	27.5	50.8	9.7	0.06	ND	78.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所