

水質試験結果表(取水分)

2014年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	16.8	13.9	10.5	7.2	20.7	22.7	52.0	7.8	0.51	0.06	63.8
2	金	21.6	13.2	7.9	7.1	24.6	26.3	48.4	7.8	0.36	0.03	67.8
3	土	22.1	15.0	3.5	7.4	23.3	28.3	52.0	7.2	0.26	0.01	71.1
4	日	17.3	15.3	3.1	7.4	25.0	27.9	48.8	8.0	0.29	0.01	73.1
5	月	16.5	13.8	3.8	7.4	25.2	28.5	50.4	8.4	0.26	0.01	74.8
6	火	14.5	12.8	4.8	7.4	23.8	29.5	49.2	7.3	0.24	0.01	73.6
7	水	16.8	13.0	8.6	7.2	22.2	29.1	55.2	8.9	0.48	0.02	73.7
8	木	22.1	13.3	5.8	7.2	24.9	27.3	58.4	7.3	0.30	0.03	73.1
9	金	20.3	15.0	10.7	7.2	25.6	28.5	56.0	7.6	0.46	0.04	73.1
10	土	20.4	14.3	5.0	7.4	24.4	27.3	59.2	7.9	0.33	0.02	74.5
11	日	19.5	14.7	4.8	7.3	25.3	28.9	53.6	8.3	0.30	0.02	74.9
12	月	21.9	15.7	5.1	7.2	25.3	30.4	56.4	8.4	0.33	0.02	75.3
13	火	23.5	14.4	7.8	7.3	25.5	26.3	56.8	7.3	0.34	0.02	72.4
14	水	22.9	15.3	8.5	7.1	25.0	26.1	57.6	7.0	0.38	ND	70.4
15	木	21.8	15.2	5.2	7.2	26.5	26.9	56.4	7.1	0.28	0.01	73.8
16	金	18.8	14.5	6.7	7.2	25.0	26.9	48.0	7.2	0.32	0.02	71.8
17	土	20.2	15.2	3.5	7.3	26.4	28.7	56.0	7.3	0.26	0.01	79.4
18	日	20.4	15.6	4.2	7.4	27.3	29.7	60.0	7.8	0.29	0.01	82.2
19	月	21.6	16.4	3.2	7.2	27.8	30.6	57.2	8.5	0.26	ND	81.5
20	火	23.5	16.4	3.6	7.2	28.0	31.4	56.8	8.8	0.28	0.01	80.3
21	水	17.4	16.1	7.4	7.1	24.1	29.5	56.0	8.4	0.38	0.02	71.5
22	木	18.7	15.6	6.7	7.1	25.1	27.9	56.0	6.6	0.31	0.03	73.5
23	金	17.0	15.3	4.5	7.1	27.6	29.9	60.4	7.1	0.26	0.02	78.8
24	土	20.5	15.6	2.6	7.3	27.7	29.9	58.4	7.6	0.24	0.01	82.8
25	日	25.0	17.0	2.1	7.3	29.6	32.0	55.2	7.8	0.21	0.01	82.4
26	月	21.7	17.8	3.4	7.1	29.4	30.2	62.8	7.4	0.30	0.01	81.6
27	火	22.2	15.8	14.6	7.2	20.0	22.3	63.2	5.4	0.78	0.06	59.9
28	水	24.6	16.2	5.1	7.1	24.5	25.3	54.8	6.9	0.20	0.02	67.7
29	木	26.4	17.2	4.0	7.2	25.6	29.7	56.8	7.4	0.27	0.01	74.2
30	金	27.7	18.0	3.4	7.2	27.4	28.7	58.4	7.9	0.30	0.01	77.5
31	土	28.0	18.8	2.3	7.4	27.2	31.2	52.4	7.6	0.25	0.01	80.9
最大値		28.0	18.8	14.6	7.4	29.6	32.0	63.2	8.9	0.78	0.06	82.8
最小値		14.5	12.8	2.1	7.1	20.0	22.3	48.0	5.4	0.20	ND	59.9
平均値		21.0	15.4	5.6	7.2	25.5	28.3	55.6	7.6	0.32	0.02	74.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2014年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	16.8	13.7	1.3	6.9	18.9	23.9	46.8	10.5	0.05	ND	67.8
2	金	21.6	13.1	1.2	6.9	23.1	24.5	46.4	9.3	0.03	ND	70.5
3	土	22.1	14.9	0.7	7.2	20.4	26.7	48.0	9.9	0.04	ND	74.6
4	日	17.3	13.6	0.9	7.2	22.2	26.1	45.2	10.3	0.04	ND	74.8
5	月	16.5	14.0	0.8	7.3	22.0	27.9	48.4	10.0	0.03	ND	77.3
6	火	14.5	13.0	1.1	7.3	22.1	27.7	45.2	9.5	0.05	ND	77.1
7	水	16.8	13.2	0.7	7.1	21.1	27.7	46.8	10.2	0.03	ND	76.1
8	木	22.1	13.4	1.2	7.0	22.8	27.5	54.8	9.2	0.05	ND	77.0
9	金	20.3	15.0	1.0	6.9	22.8	27.5	46.0	10.3	0.03	ND	75.6
10	土	20.4	14.4	1.1	7.1	21.6	27.7	56.8	10.3	0.06	ND	77.3
11	日	19.5	14.8	0.8	7.2	23.2	30.2	49.6	10.1	0.04	ND	78.5
12	月	21.9	16.1	0.6	7.2	23.1	29.1	50.8	9.4	0.03	ND	78.0
13	火	23.5	14.3	1.1	7.1	22.9	25.9	46.0	9.9	0.04	ND	75.9
14	水	22.9	15.3	1.0	7.0	22.1	27.9	50.0	8.8	0.04	ND	73.7
15	木	21.8	15.2	1.1	7.1	24.2	27.9	50.0	9.7	0.04	ND	76.6
16	金	18.8	14.5	1.3	7.0	23.7	25.7	52.0	10.3	0.04	ND	75.5
17	土	20.2	15.3	1.2	7.2	23.0	28.9	56.0	10.4	0.06	ND	80.7
18	日	20.4	15.9	0.9	7.2	25.0	29.9	55.2	10.0	0.06	ND	84.7
19	月	21.6	17.0	0.9	7.2	25.5	32.4	58.8	9.4	0.05	ND	83.7
20	火	23.5	16.9	0.8	7.1	27.0	30.6	58.0	9.9	0.04	ND	83.1
21	水	17.4	16.1	1.1	7.1	26.0	29.9	56.0	11.0	0.05	ND	83.5
22	木	18.7	15.5	1.1	7.0	23.5	27.5	52.8	10.2	0.04	ND	76.1
23	金	17.0	15.5	1.0	7.0	24.6	28.7	56.8	9.5	0.05	ND	80.9
24	土	20.5	15.6	1.1	7.3	26.8	30.2	58.8	8.6	0.06	ND	84.5
25	日	25.0	17.0	0.7	7.3	29.4	32.0	54.8	8.6	0.06	ND	84.6
26	月	21.7	18.0	0.3	7.1	28.5	31.0	56.8	9.0	0.04	ND	83.9
27	火	22.2	16.0	1.0	6.9	19.1	25.3	52.0	10.3	0.04	ND	70.0
28	水	24.6	16.2	1.3	7.2	24.0	27.7	48.4	9.2	0.05	ND	72.3
29	木	26.4	17.1	0.7	7.1	25.2	27.1	50.4	9.3	0.04	ND	76.4
30	金	27.7	18.0	0.6	7.1	27.1	29.5	56.4	9.4	0.04	ND	79.6
31	土	28.0	18.8	0.6	7.3	26.0	28.9	55.2	9.9	0.05	ND	82.1
最大値		28.0	18.8	1.3	7.3	29.4	32.4	58.8	11.0	0.06	ND	84.7
最小値		14.5	13.0	0.3	6.9	18.9	23.9	45.2	8.6	0.03	ND	67.8
平均値		21.0	15.4	0.9	7.1	23.8	28.2	51.9	9.8	0.04	ND	77.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所