

水質試験結果表(取水分)

2014年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	水	27.8	18.7	2.6	7.2	29.7	30.8	54.4	7.4	0.20	0.01	82.3
2	木	26.9	19.2	2.2	7.2	31.1	32.4	63.6	6.9	0.18	ND	86.8
3	金	21.9	19.3	1.9	7.2	30.9	32.6	62.8	8.2	0.17	0.01	87.3
4	土	24.3	18.2	1.6	7.3	29.9	32.8	60.8	7.3	0.17	0.01	87.9
5	日	18.7	18.5	1.2	7.3	30.4	32.2	56.8	8.2	0.18	ND	87.9
6	月	20.0	18.0	3.1	7.2	30.4	33.0	65.6	7.7	0.28	0.01	87.3
7	火	25.3	17.1	16.4	7.2	21.0	23.5	70.4	6.3	0.65	0.05	65.5
8	水	22.8	16.7	4.8	7.2	25.1	25.1	56.8	7.3	0.29	0.02	70.7
9	木	25.1	16.9	3.0	7.2	24.7	26.7	52.0	5.7	0.19	ND	70.4
10	金	29.6	17.4	2.8	7.2	25.4	29.3	52.0	7.4	0.17	ND	71.1
11	土	25.8	17.7	2.6	7.3	26.1	27.1	51.2	7.2	0.18	ND	71.4
12	日	22.4	17.7	2.0	7.3	27.0	28.1	48.4	7.7	0.18	ND	77.1
13	月	18.4	17.6	1.7	7.3	29.5	31.0	48.4	8.1	0.16	ND	82.0
14	火	17.8	17.3	8.0	7.3	26.9	27.5	60.0	7.6	0.37	0.02	73.4
15	水	22.4	15.4	8.6	7.2	20.5	20.9	54.8	6.8	0.40	0.02	60.6
16	木	19.3	15.4	3.3	7.3	24.0	25.7	48.0	7.9	0.17	0.01	68.1
17	金	17.5	15.9	3.3	7.2	24.7	24.9	48.0	6.9	0.20	0.01	69.8
18	土	16.9	15.0	2.0	7.2	25.3	26.3	52.0	6.5	0.16	0.01	69.7
19	日	19.2	15.5	1.8	7.2	28.8	27.7	56.8	7.8	0.18	0.01	75.1
20	月	19.3	15.9	2.1	7.2	27.7	29.4	60.8	9.6	0.20	ND	79.6
21	火	20.9	15.5	3.2	7.2	26.4	28.1	50.8	7.1	0.22	0.01	73.5
22	水	17.1	16.0	3.9	7.2	25.7	26.7	54.0	6.9	0.26	0.01	73.2
23	木	20.5	15.3	3.4	7.2	27.7	27.5	54.8	6.8	0.25	0.01	75.6
24	金	19.3	15.2	2.2	7.3	27.1	28.3	56.8	6.6	0.24	0.02	78.0
25	土	21.5	15.3	1.3	7.3	28.2	29.5	53.6	6.5	0.13	ND	80.2
26	日	24.6	15.9	1.4	7.4	30.5	32.4	54.8	7.0	0.14	ND	86.7
27	月	24.4	16.5	1.8	7.3	30.6	33.0	60.0	6.9	0.16	ND	86.5
28	火	20.2	15.0	2.1	7.2	30.9	32.2	55.6	6.6	0.17	0.01	87.2
29	水	16.8	13.9	1.5	7.3	31.3	33.0	58.8	7.3	0.16	ND	90.2
30	木	16.5	13.7	1.5	7.3	31.0	33.6	62.8	7.3	0.14	ND	89.9
31	金	19.7	14.3	1.4	7.2	30.5	32.0	62.0	6.9	0.14	ND	86.5
最大値		29.6	19.3	16.4	7.4	31.3	33.6	70.4	9.6	0.65	0.05	90.2
最小値		16.5	13.7	1.2	7.2	20.5	20.9	48.0	5.7	0.13	ND	60.6
平均値		21.4	16.5	3.2	7.2	27.7	29.1	56.4	7.2	0.22	0.01	78.4

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2014年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	27.8	18.8	1.0	7.2	30.5	32.2	53.6	8.6	0.05	ND	83.5
2	木	26.9	19.0	1.0	7.3	30.2	32.4	61.6	8.2	0.06	ND	87.7
3	金	21.9	19.1	0.9	7.2	30.4	32.2	59.2	9.2	0.06	ND	89.4
4	土	24.3	18.5	0.7	7.3	30.4	33.0	60.0	7.8	0.06	ND	89.4
5	日	18.7	19.0	0.6	7.4	29.8	33.2	60.4	8.5	0.08	ND	89.6
6	月	20.0	17.8	0.5	7.3	30.3	32.6	60.0	8.0	0.06	ND	89.7
7	火	25.3	17.4	1.4	7.0	19.9	26.3	56.0	9.3	0.04	ND	74.8
8	水	22.8	16.7	1.3	7.1	22.3	25.9	50.4	8.7	0.06	ND	72.7
9	木	25.1	16.9	1.2	7.1	23.1	26.5	48.0	7.6	0.04	ND	71.8
10	金	29.6	17.2	1.2	7.1	23.7	26.9	49.2	8.3	0.04	ND	72.2
11	土	25.8	17.5	1.1	7.2	24.2	26.1	46.0	8.6	0.04	ND	72.3
12	日	22.4	17.9	0.8	7.3	25.8	27.5	41.6	9.2	0.04	ND	78.2
13	月	18.4	17.2	0.9	7.3	27.9	30.4	52.0	9.4	0.05	ND	81.4
14	火	17.8	17.0	0.9	7.2	26.4	29.7	49.2	8.9	0.04	ND	81.0
15	水	22.4	15.3	1.8	7.1	18.4	20.3	48.0	8.8	0.07	ND	66.0
16	木	19.3	15.2	1.3	7.1	21.8	24.5	48.8	8.5	0.04	ND	69.1
17	金	17.5	15.7	1.0	7.1	24.5	24.3	45.6	8.4	0.04	ND	71.8
18	土	16.9	15.0	1.2	7.2	26.5	25.3	52.0	8.6	0.05	ND	70.9
19	日	19.2	15.2	0.7	7.2	29.4	25.3	52.4	9.4	0.05	ND	73.1
20	月	19.3	15.7	0.8	7.2	27.3	30.2	57.2	10.3	0.06	ND	80.6
21	火	20.9	15.3	1.2	7.1	25.9	27.7	48.0	8.4	0.06	ND	75.2
22	水	17.1	15.6	1.2	7.2	28.7	28.3	53.2	8.8	0.07	ND	78.1
23	木	20.5	15.1	1.7	7.2	27.1	26.1	53.6	8.9	0.07	ND	76.4
24	金	19.3	15.1	1.4	7.2	26.1	28.9	56.0	8.9	0.07	ND	78.3
25	土	21.5	15.2	0.9	7.4	26.8	28.3	51.6	6.7	0.07	ND	80.3
26	日	24.6	15.9	0.7	7.4	29.5	31.6	52.8	7.6	0.08	ND	86.6
27	月	24.4	16.4	1.0	7.3	29.7	33.2	58.4	7.4	0.08	ND	87.7
28	火	20.2	15.0	1.2	7.2	31.0	32.4	51.2	7.4	0.10	ND	87.6
29	水	16.8	13.9	1.3	7.3	30.7	32.0	60.8	7.9	0.10	ND	90.4
30	木	16.5	13.7	1.1	7.3	31.2	33.0	66.0	8.3	0.10	ND	90.8
31	金	19.7	14.2	1.2	7.2	29.9	32.8	58.0	8.2	0.10	ND	88.8
最大値		29.6	19.1	1.8	7.4	31.2	33.2	66.0	10.3	0.10	ND	90.8
最小値		16.5	13.7	0.5	7.0	18.4	20.3	41.6	6.7	0.04	ND	66.0
平均値		21.4	16.4	1.1	7.2	27.1	29.0	53.6	8.5	0.06	ND	80.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所