

水質試験結果表(取水分)

2015年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
1	土	31.4	22.0	1.7	7.1	24.8	25.7	41.6	7.1	0.16	0.01	69.5
2	日	32.6	22.7	2.4	7.1	25.8	25.1	44.0	7.4	0.21	0.01	70.7
3	月	35.0	23.5	3.0	7.1	27.6	26.1	50.0	8.2	0.29	0.01	73.3
4	火	32.8	23.1	2.3	7.1	24.9	26.3	46.4	8.3	0.22	ND	69.8
5	水	33.6	23.1	2.8	7.1	25.8	26.1	35.6	6.9	0.20	0.01	66.7
6	木	33.3	23.3	3.1	7.0	25.1	25.3	40.4	7.6	0.21	0.01	69.0
7	金	32.8	23.7	2.1	7.0	26.6	26.9	42.4	7.6	0.17	ND	72.2
8	土	33.1	23.9	1.5	7.2	26.9	26.5	46.0	8.2	0.16	ND	75.3
9	日	31.3	24.8	1.4	7.1	30.7	29.7	45.6	8.6	0.18	ND	82.0
10	月	30.6	24.9	2.8	7.0	30.3	29.5	46.4	7.3	0.29	0.01	81.7
11	火	28.8	24.3	1.8	7.0	30.4	29.1	52.4	8.5	0.17	ND	83.0
12	水	27.5	23.8	1.8	7.0	30.3	29.2	49.2	9.2	0.19	ND	83.3
13	木	27.8	23.0	1.8	7.0	29.8	30.4	50.4	8.8	0.16	ND	83.1
14	金	28.8	22.9	1.8	7.1	31.0	29.3	52.4	8.3	0.17	ND	81.6
15	土	29.2	23.3	1.2	7.2	29.3	29.1	54.4	9.0	0.18	ND	82.5
16	日	30.0	23.9	1.3	7.0	29.6	32.4	51.2	9.5	0.21	ND	84.8
17	月	26.6	24.2	1.6	7.1	30.2	31.0	49.2	8.6	0.23	ND	84.0
18	火	28.9	22.8	4.7	6.9	25.8	24.9	48.8	6.7	0.26	0.01	70.5
19	水	29.7	22.9	4.1	7.0	27.6	26.5	48.0	8.3	0.21	ND	74.5
20	木	25.7	22.6	2.7	7.0	27.0	27.3	46.4	8.1	0.20	ND	72.8
21	金	26.2	22.5	4.5	7.0	27.8	26.9	45.2	9.6	0.25	ND	75.0
22	土	27.5	22.5	1.9	7.2	27.2	26.5	54.8	9.3	0.18	ND	74.9
23	日	30.1	22.5	2.6	7.1	26.8	27.3	47.2	8.5	0.22	ND	75.8
24	月	30.6	22.6	3.5	7.0	28.9	28.9	55.2	8.4	0.19	0.01	79.1
25	火	28.5	22.6	2.3	7.1	28.5	29.1	48.4	11.7	0.23	0.01	76.6
26	水	30.5	22.0	2.6	7.0	28.2	27.7	48.0	9.0	0.21	ND	73.9
27	木	29.4	21.8	2.4	7.0	28.2	28.3	50.0	9.3	0.20	ND	77.8
28	金	30.5	22.6	1.9	7.0	29.3	29.5	52.4	11.2	0.20	ND	83.5
29	土	24.0	22.9	1.3	7.2	30.6	30.2	50.4	9.0	0.16	ND	84.4
30	日	23.3	22.6	1.8	7.1	28.9	31.6	46.0	8.7	0.18	ND	80.7
31	月	25.8	21.8	5.9	7.1	26.2	27.3	56.0	8.5	0.41	0.01	74.1
最大値		35.0	24.9	5.9	7.2	31.0	32.4	56.0	11.7	0.41	0.01	84.8
最小値		23.3	21.8	1.2	6.9	24.8	24.9	35.6	6.7	0.16	ND	66.7
平均値		29.5	23.1	2.5	7.1	28.1	28.1	48.2	8.6	0.21	ND	77.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2015年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	31.4	22.2	0.5	7.2	24.4	25.7	40.4	9.0	0.03	ND	70.8
2	日	32.6	22.8	0.5	7.1	28.8	25.3	38.8	8.6	0.04	ND	72.3
3	月	35.0	23.8	0.5	7.1	26.6	26.5	52.0	9.4	0.04	ND	74.3
4	火	32.8	23.2	0.8	7.1	26.4	26.1	42.0	9.8	0.05	ND	72.7
5	水	33.6	23.2	0.8	7.0	25.9	26.3	35.2	8.8	0.05	ND	70.6
6	木	33.3	23.3	1.1	7.0	25.0	25.1	44.8	9.7	0.05	ND	70.5
7	金	32.8	23.7	0.9	7.0	25.8	27.3	40.4	8.8	0.04	ND	73.4
8	土	33.1	24.0	0.7	7.2	26.6	28.1	40.8	9.5	0.06	ND	74.2
9	日	31.3	25.3	0.5	7.2	30.4	29.7	40.8	9.6	0.05	ND	82.0
10	月	30.6	25.3	0.7	7.2	29.7	29.3	44.0	9.4	0.08	ND	81.7
11	火	28.8	24.5	0.8	7.1	29.8	30.2	49.2	10.0	0.05	ND	84.5
12	水	27.5	24.0	1.4	7.1	30.0	29.9	47.2	11.0	0.09	ND	85.2
13	木	27.8	23.2	1.0	7.0	29.0	31.0	54.0	11.5	0.05	ND	85.8
14	金	28.8	22.8	1.8	7.1	28.8	29.1	46.8	10.0	0.10	ND	84.1
15	土	29.2	23.2	0.5	7.2	29.0	29.9	54.0	10.3	0.11	ND	81.9
16	日	30.0	24.0	0.5	7.2	29.7	32.2	48.0	9.9	0.10	ND	84.6
17	月	26.6	24.6	0.5	7.1	29.2	29.7	50.0	10.7	0.07	ND	84.4
18	火	28.9	22.9	1.2	7.0	25.5	25.9	44.0	9.9	0.05	ND	75.0
19	水	29.7	22.9	1.3	7.0	25.9	27.9	45.2	9.6	0.07	ND	75.9
20	木	25.7	22.5	1.0	6.9	26.3	28.1	45.6	10.3	0.05	ND	75.1
21	金	26.2	22.5	1.0	6.9	26.0	27.1	52.8	11.5	0.05	ND	77.2
22	土	27.5	22.8	0.7	7.2	26.6	27.7	50.8	9.4	0.05	ND	76.0
23	日	30.1	22.5	1.0	7.1	26.0	27.3	46.0	9.9	0.05	ND	76.8
24	月	30.6	23.1	0.6	7.1	28.4	29.3	46.8	10.2	0.05	ND	80.0
25	火	28.5	22.6	0.6	7.1	27.2	28.5	40.8	12.8	0.05	ND	79.2
26	水	30.5	22.0	0.8	7.0	27.4	28.1	48.0	11.3	0.05	ND	77.3
27	木	29.4	21.7	0.8	7.0	28.9	28.9	46.0	11.7	0.04	ND	79.0
28	金	30.5	22.6	0.7	7.0	29.9	29.9	52.0	10.5	0.04	ND	84.9
29	土	24.0	22.8	0.4	7.1	31.4	32.8	50.0	9.7	0.04	ND	86.3
30	日	23.3	22.5	0.5	7.1	29.4	30.2	48.0	9.8	0.04	ND	84.3
31	月	25.8	21.8	1.0	7.1	28.0	28.5	48.0	9.9	0.08	ND	79.9
最大値		35.0	25.3	1.8	7.2	31.4	32.8	54.0	12.8	0.11	ND	86.3
最小値		23.3	21.7	0.4	6.9	24.4	25.1	35.2	8.6	0.03	ND	70.5
平均値		29.5	23.2	0.8	7.1	27.8	28.4	46.2	10.1	0.06	ND	78.7

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。