

水質試験結果表(取水分)

2016年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
1	金	19.0	10.3	1.5	7.3	26.0	30.2	47.2	8.3	0.12	ND	75.6
2	土	21.1	10.2	1.2	7.3	24.2	26.9	45.2	7.0	0.10	ND	71.3
3	日	19.5	12.0	1.0	7.1	25.5	25.7	40.8	7.2	0.12	ND	73.3
4	月	12.5	11.7	1.8	7.0	23.5	25.1	41.6	6.8	0.13	ND	68.9
5	火	14.8	10.2	3.6	7.0	19.2	21.1	39.6	6.8	0.22	0.02	58.4
6	水	15.7	10.2	2.5	7.2	20.6	23.1	42.0	7.6	0.16	0.01	62.1
7	木	12.7	11.0	1.8	7.1	22.0	22.7	40.0	8.0	0.17	ND	64.9
8	金	18.0	10.4	38.9	7.0	13.2	18.1	76.4	5.4	1.34	0.07	44.2
9	土	17.0	12.0	9.1	7.0	20.6	25.9	72.0	16.0	0.25	0.04	101.5
10	日	17.0	11.9	5.9	7.1	24.0	29.5	70.4	17.3	0.38	0.03	104.6
11	月	11.5	12.6	8.2	7.0	25.4	30.6	74.4	16.9	0.51	0.05	114.8
12	火	11.7	11.5	5.2	7.0	25.4	30.8	76.0	18.4	0.33	0.02	116.6
13	水	17.8	12.0	6.8	7.0	28.1	32.0	80.8	17.0	0.40	0.04	125.5
14	木	19.0	12.0	3.2	7.0	23.9	25.1	48.8	7.4	0.22	0.01	70.6
15	金	17.1	13.0	3.5	7.0	22.9	25.1	47.2	7.1	0.24	0.02	69.6
16	土	17.6	12.1	2.3	7.3	27.5	25.5	46.0	7.2	0.15	0.01	71.9
17	日	20.4	13.2	2.1	7.2	26.9	26.5	40.8	7.1	0.18	0.01	73.5
18	月	17.5	13.7	3.0	6.9	26.1	24.9	47.2	7.1	0.25	ND	73.2
19	火	13.7	12.0	2.7	6.9	25.5	25.7	45.6	7.7	0.21	0.01	75.4
20	水	14.9	11.7	2.9	7.1	25.1	30.6	44.8	7.6	0.22	0.01	77.9
21	木	20.0	13.0	3.2	7.0	27.1	28.3	54.0	8.8	0.19	0.01	79.0
22	金	15.4	12.4	22.1	7.0	18.3	21.3	56.4	5.5	0.78	0.11	54.8
23	土	22.3	12.0	6.0	7.3	20.2	21.5	48.0	6.3	0.30	0.05	60.0
24	日	21.9	13.8	5.7	7.1	22.2	24.9	52.8	6.7	0.21	0.03	70.0
25	月	16.8	13.6	5.8	7.1	24.0	27.5	56.0	6.6	0.32	0.03	72.0
26	火	22.0	14.0	6.7	7.1	23.9	27.5	45.6	8.3	0.37	0.03	71.3
27	水	20.6	14.5	6.8	7.0	25.0	26.5	50.0	8.2	0.29	0.03	71.7
28	木	14.0	14.6	6.2	7.1	25.2	25.7	48.8	6.5	0.38	0.04	73.6
29	金	14.0	13.1	8.8	7.2	24.7	24.5	56.8	5.7	0.49	0.08	63.0
30	土	14.6	12.3	6.5	7.1	26.2	26.3	48.8	6.1	0.33	0.03	69.7
最大値		22.3	14.6	38.9	7.3	28.1	32.0	80.8	18.4	1.34	0.11	125.5
最小値		11.5	10.2	1.0	6.9	13.2	18.1	39.6	5.4	0.10	ND	44.2
平均値		17.0	12.2	6.2	7.1	23.7	26.0	52.8	8.8	0.31	0.03	76.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

