

水質試験結果表(取水分)

2018年2月

| 項目 | | 気温 [°C] | 水温 [°C] | 濁度 [度] | pH [-logH] | 酸消費量 [mg/L] | 全硬度 [mg/L] | 全蒸発残留物 [mg/L] | 塩化物イオン [mg/L] | 鉄 [mg/L] | マンガン [mg/L] | 電気伝導度 [μ S/cm] |
|-----|----|------------|------------|-----------|---------------|----------------|---------------|------------------|------------------|-------------|----------------|-------------------|
| 日付 | 曜日 | | | | | | | | | | | |
| 1 | 木 | 2.2 | 4.0 | 4.6 | 7.0 | 28.0 | 33.4 | 78.8 | 19.5 | 0.18 | 0.01 | 135.7 |
| 2 | 金 | 0.1 | 4.4 | 4.1 | 7.0 | 27.7 | 33.4 | 73.6 | 18.0 | 0.15 | 0.01 | 124.9 |
| 3 | 土 | 3.0 | 5.2 | 3.6 | 6.9 | 26.4 | 34.4 | 66.4 | 15.1 | 0.18 | ND | 112.5 |
| 4 | 日 | 2.2 | 4.5 | 3.4 | 7.1 | 26.7 | 33.0 | 67.2 | 16.5 | 0.08 | ND | 117.8 |
| 5 | 月 | 0.4 | 4.0 | 3.3 | 7.2 | 27.7 | 35.8 | 78.0 | 17.3 | 0.10 | 0.01 | 124.9 |
| 6 | 火 | -2.4 | 1.3 | 3.6 | 6.9 | 30.3 | 37.6 | 68.0 | 17.0 | 0.16 | ND | 124.0 |
| 7 | 水 | -1.8 | 1.0 | 4.6 | 7.0 | 32.4 | 41.2 | 92.8 | 19.0 | 0.26 | ND | 155.3 |
| 8 | 木 | -0.9 | 1.1 | 3.8 | 7.0 | 35.2 | 42.2 | 86.4 | 21.4 | 0.27 | ND | 151.6 |
| 9 | 金 | 3.5 | 2.0 | 3.3 | 7.1 | 34.8 | 39.2 | 90.4 | 17.4 | 0.31 | ND | 142.4 |
| 10 | 土 | 3.7 | 3.7 | 1.7 | 7.1 | 30.1 | 37.8 | 66.4 | 17.6 | 0.13 | 0.01 | 126.1 |
| 11 | 日 | 3.5 | 3.5 | 3.0 | 7.1 | 29.5 | 36.6 | 82.4 | 19.5 | 0.16 | 0.01 | 137.9 |
| 12 | 月 | 1.6 | 2.8 | 5.3 | 7.0 | 21.1 | 30.6 | 68.0 | 19.2 | 0.21 | 0.01 | 117.1 |
| 13 | 火 | 1.5 | 1.5 | 4.1 | 7.0 | 25.4 | 37.2 | 62.8 | 19.7 | 0.27 | 0.01 | 129.4 |
| 14 | 水 | 5.7 | 1.7 | 4.3 | 7.0 | 29.9 | 37.8 | 87.2 | 20.1 | 0.21 | 0.01 | 140.6 |
| 15 | 木 | 4.0 | 3.9 | 4.5 | 7.0 | 27.8 | 32.2 | 60.8 | 20.1 | 0.30 | 0.01 | 127.0 |
| 16 | 金 | 3.0 | 4.0 | 4.6 | 6.9 | 26.5 | 33.8 | 79.2 | 18.1 | 0.28 | 0.01 | 125.3 |
| 17 | 土 | 4.9 | 4.6 | 3.2 | 7.0 | 28.4 | 34.0 | 82.8 | 16.2 | 0.15 | 0.01 | 118.8 |
| 18 | 日 | 4.2 | 3.5 | 4.3 | 7.1 | 27.5 | 32.8 | 74.8 | 18.2 | 0.14 | 0.01 | 124.7 |
| 19 | 月 | 0.2 | 4.0 | 2.9 | 7.1 | 27.6 | 33.2 | 72.0 | 17.0 | 0.24 | ND | 115.6 |
| 20 | 火 | 5.9 | 4.8 | 4.1 | 7.1 | 27.2 | 33.8 | 79.2 | 16.2 | 0.25 | ND | 127.2 |
| 21 | 水 | 4.4 | 5.2 | 4.4 | 7.0 | 27.6 | 34.0 | 70.0 | 17.7 | 0.13 | ND | 127.8 |
| 22 | 木 | 5.4 | 4.8 | 3.9 | 7.1 | 27.2 | 33.8 | 65.2 | 18.3 | 0.29 | 0.01 | 126.6 |
| 23 | 金 | 3.9 | 5.4 | 6.0 | 7.0 | 28.0 | 35.0 | 72.0 | 18.1 | 0.38 | 0.01 | 129.0 |
| 24 | 土 | 4.5 | 4.9 | 3.3 | 7.0 | 26.0 | 33.2 | 60.0 | 18.5 | 0.17 | 0.01 | 120.7 |
| 25 | 日 | 1.1 | 4.2 | 3.5 | 7.1 | 26.9 | 36.8 | 70.0 | 19.2 | 0.23 | 0.01 | 131.0 |
| 26 | 月 | 5.8 | 5.2 | 6.8 | 7.2 | 27.0 | 38.6 | 66.8 | 14.9 | 0.47 | 0.02 | 124.8 |
| 27 | 火 | 5.6 | 5.6 | 5.4 | 7.0 | 26.5 | 33.4 | 80.0 | 17.4 | 0.35 | 0.02 | 123.3 |
| 28 | 水 | 4.0 | 5.9 | 5.7 | 7.0 | 23.8 | 34.6 | 65.2 | 16.7 | 0.40 | 0.03 | 119.7 |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| 最大値 | | 5.9 | 5.9 | 6.8 | 7.2 | 35.2 | 42.2 | 92.8 | 21.4 | 0.47 | 0.03 | 155.3 |
| 最小値 | | -2.4 | 1.0 | 1.7 | 6.9 | 21.1 | 30.6 | 60.0 | 14.9 | 0.08 | ND | 112.5 |
| 平均値 | | 2.8 | 3.8 | 4.1 | 7.0 | 28.0 | 35.3 | 73.8 | 18.0 | 0.23 | 0.01 | 127.9 |

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

