

水質試験結果表(取水分)

2018年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	17.0	10.2	5.0	7.0	21.2	26.5	54.8	10.6	0.25	0.01	87.0
2	月	16.2	10.2	5.2	7.0	22.3	28.7	63.2	10.3	0.28	0.01	80.3
3	火	20.1	11.0	6.5	6.9	20.3	24.7	51.6	10.5	0.31	0.01	81.7
4	水	20.8	11.4	7.1	7.0	19.7	22.1	53.2	10.2	0.15	0.02	75.0
5	木	13.8	11.1	8.7	7.0	19.3	22.1	54.8	9.9	0.38	0.03	77.6
6	金	20.4	11.0	6.5	6.8	19.2	28.9	50.8	9.4	0.33	0.02	77.5
7	土	8.3	11.2	22.7	6.9	19.0	26.9	56.0	9.2	0.29	0.03	75.0
8	日	4.9	9.1	9.3	6.8	18.5	30.8	72.8	10.7	1.00	0.10	80.9
9	月	11.4	8.2	12.2	6.7	19.3	27.9	60.0	10.4	0.58	0.05	82.8
10	火	11.9	9.0	8.2	6.9	21.0	26.5	68.0	12.9	0.22	0.03	91.6
11	水	18.8	11.0	8.6	7.0	22.0	26.1	59.2	11.3	0.09	0.03	88.4
12	木	14.6	11.8	30.7	6.9	19.2	27.9	80.4	10.9	0.46	0.10	83.7
13	金	19.3	11.3	10.7	6.9	19.7	28.3	65.6	10.0	0.26	0.03	76.8
14	土	17.9	11.1	6.2	7.0	21.4	26.3	58.0	9.3	0.42	0.02	83.1
15	日	11.0	11.7	12.2	6.9	20.9	25.9	62.0	10.0	0.66	0.05	86.4
16	月	15.9	10.5	23.6	6.9	17.4	22.9	78.0	8.7	1.11	0.09	74.6
17	火	14.1	11.0	11.5	6.9	20.9	25.1	59.2	10.4	0.44	0.03	78.8
18	水	15.8	11.7	11.5	6.9	22.2	25.5	78.4	12.7	0.52	0.03	88.6
19	木	17.0	11.8	15.8	6.9	20.5	25.3	64.8	9.7	0.68	0.04	76.8
20	金	19.7	12.5	9.8	6.9	21.7	24.5	60.0	10.3	0.46	0.02	81.2
21	土	21.7	13.0	6.7	7.0	21.6	26.3	56.4	10.0	0.21	0.01	83.4
22	日	23.4	13.7	7.5	7.0	23.1	25.9	49.6	9.6	0.10	0.01	79.7
23	月	23.1	14.0	8.8	6.9	22.2	26.9	50.8	9.4	0.08	0.02	77.4
24	火	17.7	13.9	10.0	6.9	21.7	23.3	61.2	10.5	0.47	0.04	78.8
25	水	14.9	14.4	36.9	6.8	18.7	21.9	84.8	9.5	1.05	0.15	72.4
26	木	21.3	12.7	37.1	6.8	18.6	21.1	84.4	10.4	1.24	0.13	73.7
27	金	20.6	13.2	18.0	6.9	19.6	26.1	56.4	10.3	0.78	0.07	75.4
28	土	16.4	13.6	7.6	6.9	20.8	24.7	54.8	10.0	0.49	0.02	81.8
29	日	23.0	14.1	8.8	7.1	21.1	25.3	56.0	9.5	0.26	0.01	82.5
30	月	22.8	14.8	6.9	7.0	21.5	24.5	63.2	10.5	0.40	0.01	82.2
最大値		23.4	14.8	37.1	7.1	23.1	30.8	84.8	12.9	1.24	0.15	91.6
最小値		4.9	8.2	5.0	6.7	17.4	21.1	49.6	8.7	0.08	0.01	72.4
平均値		17.1	11.8	12.7	6.9	20.5	25.6	62.3	10.2	0.47	0.04	80.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2018年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	17.0	10.3	1.0	7.0	21.7	25.9	49.6	12.8	0.03	ND	90.4
2	月	16.2	10.2	1.5	7.0	21.8	28.9	56.0	12.4	0.03	ND	86.8
3	火	20.1	11.3	1.9	6.9	20.0	27.1	44.8	12.1	0.07	ND	80.6
4	水	20.8	11.8	2.0	6.9	19.3	23.5	46.8	11.6	0.07	ND	80.9
5	木	13.8	11.5	2.1	6.9	19.0	23.3	48.8	11.9	0.07	ND	82.1
6	金	20.4	11.1	1.8	6.7	19.1	26.5	47.6	10.3	0.07	ND	81.0
7	土	8.3	11.5	3.0	6.8	18.1	25.7	46.8	11.3	0.06	0.01	83.1
8	日	4.9	9.5	1.6	7.0	20.1	29.1	55.2	13.2	0.14	0.01	88.1
9	月	11.4	8.3	2.6	6.9	19.7	26.7	51.6	12.8	0.12	0.01	87.1
10	火	11.9	9.0	1.6	6.8	19.8	29.1	52.0	14.8	0.06	ND	90.1
11	水	18.8	11.1	1.2	6.9	20.6	27.1	53.2	12.9	0.06	ND	91.4
12	木	14.6	11.8	1.9	6.9	20.2	26.5	49.6	13.3	0.08	ND	96.2
13	金	19.3	11.6	2.0	6.9	18.2	27.9	44.8	12.0	0.07	0.01	80.6
14	土	17.9	11.3	1.7	7.0	19.9	26.1	42.0	11.0	0.07	ND	84.0
15	日	11.0	11.4	1.1	6.9	22.0	27.1	47.2	11.8	0.05	ND	94.1
16	月	15.9	11.0	2.0	6.7	15.3	21.9	45.2	11.5	0.06	ND	76.9
17	火	14.1	11.1	1.8	6.9	19.0	24.3	48.4	11.7	0.06	ND	81.8
18	水	15.8	11.4	1.9	6.9	21.0	27.9	55.2	13.9	0.08	ND	91.8
19	木	17.0	12.0	2.0	6.8	19.2	27.3	42.4	11.4	0.09	ND	80.0
20	金	19.7	13.0	1.4	6.9	20.3	25.1	42.8	12.4	0.06	ND	86.8
21	土	21.7	13.2	1.1	7.0	22.8	26.1	48.8	11.2	0.03	ND	88.4
22	日	23.4	14.0	1.1	7.0	24.8	25.3	40.8	11.0	0.05	ND	87.2
23	月	23.1	14.3	1.2	7.0	21.5	27.1	60.8	11.3	0.03	ND	82.3
24	火	17.7	14.2	1.7	6.9	20.3	24.3	50.8	12.8	0.07	ND	83.1
25	水	14.9	14.2	1.7	6.7	17.3	21.9	44.0	13.1	0.06	ND	82.3
26	木	21.3	13.0	3.1	6.7	15.4	23.1	48.8	12.3	0.12	0.01	79.9
27	金	20.6	13.5	2.1	6.8	17.3	24.9	42.8	13.3	0.07	ND	81.8
28	土	16.4	13.7	1.7	6.9	19.4	25.3	48.8	12.2	0.07	ND	87.5
29	日	23.0	14.2	1.2	7.0	20.8	24.9	40.4	12.6	0.05	ND	88.1
30	月	22.8	15.0	1.0	7.1	21.3	26.7	43.2	11.9	0.04	ND	88.3
最大値		23.4	15.0	3.1	7.1	24.8	29.1	60.8	14.8	0.14	0.01	96.2
最小値		4.9	8.3	1.0	6.7	15.3	21.9	40.4	10.3	0.03	ND	76.9
平均値		17.1	12.0	1.7	6.9	19.8	25.9	48.0	12.2	0.07	ND	85.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。