

水質試験結果表(取水分)

2019年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	木	29.5	22.7	3.5	6.9	27.0	26.3	46.0	6.8	0.16	0.01	73.2
2	金	32.6	22.7	3.3	6.9	25.7	27.5	56.0	6.8	0.27	0.01	73.2
3	土	32.4	23.5	1.7	6.9	27.1	29.5	54.4	6.3	0.17	ND	78.8
4	日	34.9	24.7	2.0	7.0	30.0	30.8	56.8	7.4	0.25	ND	84.7
5	月	35.8	25.2	4.4	6.8	30.7	31.2	58.8	6.3	0.41	0.01	84.5
6	火	34.4	24.9	2.9	7.0	28.9	30.4	52.4	7.1	0.22	0.01	79.9
7	水	33.6	24.3	3.4	6.9	27.2	28.5	48.8	5.9	0.31	0.01	74.0
8	木	32.9	24.8	2.7	6.9	27.6	28.3	56.0	6.7	0.26	ND	73.6
9	金	33.6	24.6	2.6	6.9	27.0	28.1	52.0	6.6	0.25	ND	74.4
10	土	33.1	24.8	1.2	7.0	29.3	29.9	53.2	7.6	0.19	ND	81.2
11	日	32.2	25.8	1.5	7.0	31.0	30.8	52.0	6.9	0.19	ND	85.5
12	月	33.0	26.0	1.6	7.0	31.7	31.4	54.4	6.2	0.22	ND	85.4
13	火	35.8	26.0	2.3	7.0	33.8	32.4	55.6	7.1	0.26	ND	85.2
14	水	35.1	26.2	2.2	6.9	28.4	31.8	47.2	7.6	0.25	0.01	80.5
15	木	33.4	26.0	2.0	6.9	29.4	29.9	58.8	7.4	0.23	ND	81.7
16	金	27.5	26.3	2.3	7.0	28.7	29.1	54.4	7.3	0.23	ND	80.0
17	土	32.8	22.9	8.9	6.9	18.9	20.1	54.8	4.9	0.38	0.04	56.2
18	日	33.1	23.5	5.1	7.0	25.1	28.7	50.8	6.3	0.31	0.01	72.0
19	月	32.7	24.0	15.6	7.0	28.1	30.2	65.6	6.4	1.03	0.05	78.0
20	火	26.5	23.1	9.0	7.1	26.0	28.5	54.8	6.9	0.47	0.04	71.4
21	水	28.1	22.9	8.0	6.9	25.8	27.1	63.2	6.3	0.45	0.03	71.3
22	木	25.2	23.0	9.1	6.9	24.9	29.1	55.2	5.7	0.15	0.04	67.4
23	金	26.6	21.9	10.6	7.0	21.5	23.9	58.0	5.3	0.54	0.05	63.0
24	土	25.7	20.9	5.4	7.1	21.5	29.1	56.0	6.4	0.46	0.01	63.3
25	日	26.3	21.2	4.4	7.1	26.9	28.3	52.4	7.0	0.36	0.01	74.7
26	月	30.0	21.2	8.1	7.0	27.5	28.7	61.2	5.6	0.64	0.02	74.7
27	火	26.2	21.3	5.0	7.0	25.7	28.5	52.4	6.7	0.33	0.01	72.1
28	水	25.2	21.1	4.7	7.0	26.2	27.3	53.6	6.4	0.31	0.02	70.0
29	木	28.1	20.6	32.1	6.9	17.7	19.1	83.2	4.9	1.36	0.15	52.2
30	金	24.2	20.2	7.4	6.9	21.1	22.5	52.8	5.9	0.15	0.03	61.1
31	土	27.2	19.0	2.9	7.1	22.9	23.5	57.6	5.9	0.20	ND	66.7
最大値		35.8	26.3	32.1	7.1	33.8	32.4	83.2	7.6	1.36	0.15	85.5
最小値		24.2	19.0	1.2	6.8	17.7	19.1	46.0	4.9	0.15	ND	52.2
平均値		30.6	23.4	5.7	7.0	26.6	28.1	55.8	6.5	0.36	0.02	73.9

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2019年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	29.5	23.0	0.5	6.8	25.0	28.1	44.0	7.2	0.03	ND	75.2
2	金	32.6	23.0	0.6	7.0	25.5	27.5	48.0	7.0	0.03	ND	74.6
3	土	32.4	23.5	0.4	7.0	26.8	28.5	43.6	7.4	0.03	ND	79.6
4	日	34.9	25.0	0.4	7.1	31.3	31.4	50.0	7.6	0.07	ND	85.1
5	月	35.8	25.7	0.4	7.0	30.0	32.6	53.2	7.2	0.06	ND	86.5
6	火	34.4	25.2	0.5	6.9	27.6	29.9	56.0	7.6	0.04	ND	81.9
7	水	33.6	24.5	0.7	7.1	27.3	28.3	46.4	7.3	0.06	ND	77.6
8	木	32.9	25.0	0.6	7.1	26.3	27.7	50.4	7.3	0.05	ND	77.5
9	金	33.6	25.0	0.7	7.0	26.6	28.1	44.8	6.8	0.06	ND	76.0
10	土	33.1	25.0	0.7	7.2	29.0	29.3	54.0	6.4	0.06	ND	78.9
11	日	32.2	26.2	0.6	7.2	32.0	30.2	43.6	7.4	0.08	ND	84.7
12	月	33.0	26.5	0.5	7.1	31.1	30.4	55.2	6.8	0.10	ND	84.6
13	火	35.8	26.5	0.5	7.1	33.4	33.2	46.8	7.3	0.09	ND	84.3
14	水	35.1	26.8	0.8	7.1	28.7	30.4	51.2	8.3	0.10	ND	83.2
15	木	33.4	26.2	0.8	7.0	28.7	29.7	61.2	7.8	0.10	ND	81.2
16	金	27.5	26.7	0.7	7.2	28.9	30.4	52.4	8.4	0.13	ND	82.0
17	土	32.8	23.5	0.7	6.9	18.4	21.9	42.0	9.2	0.02	ND	67.8
18	日	33.1	23.2	0.3	6.9	23.9	25.1	41.6	8.4	0.02	ND	73.0
19	月	32.7	24.1	0.5	6.9	25.5	29.1	51.2	8.3	0.02	ND	79.3
20	火	26.5	23.3	0.8	6.8	23.2	26.1	49.2	8.3	0.04	ND	75.4
21	水	28.1	23.1	0.8	6.7	22.4	26.1	45.6	7.3	0.04	ND	72.6
22	木	25.2	23.0	0.8	6.7	22.8	26.7	48.0	7.4	0.03	ND	73.0
23	金	26.6	22.0	1.0	6.8	19.7	22.5	42.0	7.8	0.04	ND	67.7
24	土	25.7	21.0	1.1	6.9	19.8	25.7	46.8	7.9	0.04	ND	66.3
25	日	26.3	21.4	0.7	7.0	24.7	28.5	42.0	8.1	0.04	ND	75.5
26	月	30.0	21.6	0.6	7.0	26.1	29.7	46.4	7.0	0.04	ND	75.7
27	火	26.2	21.7	0.7	6.9	24.8	27.7	47.2	7.2	0.04	ND	74.2
28	水	25.2	21.2	0.8	6.9	24.1	26.1	48.0	8.1	0.05	ND	73.0
29	木	28.1	20.5	1.3	6.6	15.9	20.7	40.8	8.9	0.10	ND	63.9
30	金	24.2	20.4	1.2	6.7	18.3	21.5	40.8	7.0	0.05	ND	63.5
31	土	27.2	19.1	0.9	6.9	20.9	23.5	52.0	6.8	0.04	ND	68.3
最大値		35.8	26.8	1.3	7.2	33.4	33.2	61.2	9.2	0.13	ND	86.5
最小値		24.2	19.1	0.3	6.6	15.9	20.7	40.8	6.4	0.02	ND	63.5
平均値		30.6	23.6	0.7	7.0	25.4	27.6	47.9	7.6	0.05	ND	76.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所