

水質試験結果表(取水分)

2020年2月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	3.2	6.9	3.1	7.3	23.1	28.5	42.0	7.6	0.10	0.01	69.1
2	日	4.6	7.0	1.8	7.3	26.0	25.9	36.0	8.3	0.13	ND	76.1
3	月	6.1	7.4	1.9	7.2	26.4	27.9	44.0	8.4	0.10	ND	73.5
4	火	6.1	7.1	1.6	7.1	24.8	26.7	44.8	7.2	0.11	ND	76.2
5	水	3.5	7.4	1.9	7.1	25.8	29.1	42.4	8.4	0.13	ND	74.3
6	木	0.0	6.0	2.5	7.1	25.0	26.9	46.8	8.2	0.16	ND	74.6
7	金	1.4	5.5	1.7	7.1	25.5	26.3	40.8	6.0	0.12	ND	76.0
8	土	3.8	6.2	0.8	7.3	26.3	27.1	52.8	8.4	0.09	ND	77.0
9	日	1.4	6.5	1.0	7.3	28.0	28.5	50.0	8.2	0.12	ND	84.3
10	月	2.2	6.3	1.4	7.2	28.6	30.4	59.2	10.2	0.14	ND	86.3
11	火	4.1	5.5	1.6	7.1	28.5	27.5	49.2	7.2	0.14	ND	84.7
12	水	7.6	6.5	1.5	7.1	27.9	26.5	49.2	8.5	0.14	ND	86.3
13	木	12.0	7.8	7.8	7.1	26.8	25.9	51.2	7.8	0.09	ND	78.7
14	金	9.9	7.3	4.4	7.1	22.3	21.7	39.6	7.4	0.21	0.01	70.0
15	土	9.4	7.9	1.6	7.2	24.9	24.5	40.0	7.3	0.11	ND	71.1
16	日	11.3	8.2	1.4	7.3	26.4	24.3	37.2	7.2	0.11	ND	72.1
17	月	5.2	8.4	22.4	7.1	17.0	17.1	59.6	6.3	0.99	0.10	54.0
18	火	3.0	6.0	5.0	6.9	18.6	19.7	42.8	7.4	0.28	0.01	60.6
19	水	5.1	6.0	2.9	7.2	22.2	24.1	40.0	7.1	0.18	0.01	69.1
20	木	6.4	6.9	15.4	7.0	23.6	24.1	53.6	7.0	0.61	0.04	71.4
21	金	6.5	7.0	3.2	7.0	24.6	26.1	39.6	7.2	0.20	0.01	74.5
22	土	8.8	7.8	1.6	7.1	25.4	26.9	45.2	8.1	0.15	ND	74.8
23	日	6.5	7.7	3.1	7.2	23.0	27.1	34.4	7.9	0.15	ND	72.6
24	月	7.7	7.0	1.7	7.1	24.3	25.1	46.4	9.3	0.13	ND	76.7
25	火	7.7	8.1	1.9	7.0	25.3	26.1	52.8	8.8	0.14	ND	78.1
26	水	8.2	7.9	2.6	7.3	25.6	27.1	45.2	7.1	0.19	ND	76.7
27	木	4.9	7.9	1.9	7.1	24.7	30.4	36.8	8.2	0.16	ND	74.2
28	金	5.0	7.0	1.7	7.1	27.0	25.7	35.2	8.6	0.10	ND	75.8
29	土	8.6	7.8	1.3	7.2	26.0	28.3	38.4	9.8	0.09	ND	77.7
最大値		12.0	8.4	22.4	7.3	28.6	30.4	59.6	10.2	0.99	0.10	86.3
最小値		0.0	5.5	0.8	6.9	17.0	17.1	34.4	6.0	0.09	ND	54.0
平均値		5.9	7.1	3.5	7.1	25.0	26.1	44.7	7.9	0.19	0.01	74.7

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

