

水質試験結果表(取水分)

2021年1月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	2.5	5.8	1.2	7.0	24.3	29.7	43.6	8.8	0.13	ND	85.2
2	土	1.9	5.2	1.1	6.9	26.2	32.2	52.4	10.7	0.19	ND	91.3
3	日	2.6	5.0	0.9	7.1	27.8	32.2	53.6	10.9	0.18	ND	95.8
4	月	3.5	6.0	1.4	6.9	27.6	32.8	59.2	10.1	0.21	ND	94.4
5	火	4.4	6.0	1.8	6.8	26.1	30.8	52.0	7.6	0.14	ND	85.5
6	水	7.1	6.9	2.7	7.0	25.9	28.7	42.0	8.0	0.17	ND	83.8
7	木	4.3	6.5	2.4	6.9	26.2	30.2	40.0	8.0	0.12	ND	83.3
8	金	-0.5	5.2	6.1	6.7	24.7	33.4	76.8	17.4	0.26	0.02	125.7
9	土	-0.8	2.0	1.7	6.8	28.7	34.4	90.0	16.2	0.24	ND	126.7
10	日	0.7	1.6	2.1	7.0	31.0	37.6	79.6	17.6	0.30	ND	132.5
11	月	1.9	2.0	2.0	6.9	32.6	40.4	80.0	16.4	0.14	ND	132.7
12	火	2.2	3.8	6.5	6.8	32.5	41.4	75.6	18.4	0.30	ND	142.6
13	水	2.5	4.4	3.2	7.0	30.1	39.6	76.8	17.9	0.12	0.01	134.3
14	木	4.4	4.5	5.2	6.8	27.9	35.4	70.0	17.8	0.16	0.01	130.0
15	金	2.3	4.4	3.0	6.8	28.9	36.4	82.8	17.4	0.25	ND	133.4
16	土	5.0	6.0	1.9	6.8	30.5	36.0	88.0	17.9	0.12	ND	133.5
17	日	2.4	5.0	8.4	6.7	23.4	28.7	82.4	16.8	0.52	0.02	109.3
18	月	1.1	5.3	4.7	6.7	21.6	30.6	72.0	17.8	0.12	0.01	115.9
19	火	2.1	5.0	5.5	6.6	25.1	37.2	66.8	18.5	0.36	0.01	128.4
20	水	1.9	4.9	3.5	6.8	26.1	34.6	73.2	18.2	0.27	0.01	131.8
21	木	3.7	5.3	3.9	7.0	26.5	37.2	84.8	18.7	0.29	ND	133.0
22	金	4.0	5.8	2.5	7.1	27.2	35.0	50.0	9.6	0.05	ND	85.2
23	土	3.4	5.9	1.2	7.1	25.7	29.7	42.4	7.9	0.05	ND	79.4
24	日	4.8	6.0	1.7	7.0	25.0	30.6	36.8	8.7	0.03	ND	83.1
25	月	8.0	6.0	2.4	6.9	21.7	29.5	50.4	8.5	0.11	ND	80.5
26	火	8.8	6.4	2.7	7.0	23.7	29.5	41.6	7.9	0.08	0.01	78.5
27	水	9.8	6.7	5.5	6.9	22.4	29.9	45.6	9.5	0.23	ND	79.5
28	木	2.6	6.0	11.0	6.7	17.8	23.5	49.6	8.1	0.24	0.04	69.5
29	金	2.2	6.3	5.9	6.7	19.8	26.1	52.0	8.8	0.09	ND	78.5
30	土	3.4	5.0	2.4	6.8	26.2	32.2	56.8	11.0	0.08	ND	92.2
31	日	7.7	5.5	2.0	6.9	27.5	28.7	52.8	10.1	0.11	ND	92.3
最大値		9.8	6.9	11.0	7.1	32.6	41.4	90.0	18.7	0.52	0.04	142.6
最小値		-0.8	1.6	0.9	6.6	17.8	23.5	36.8	7.6	0.03	ND	69.5
平均値		3.5	5.2	3.4	6.9	26.2	32.7	61.9	12.9	0.18	ND	104.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2021年1月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	2.5	6.0	0.4	6.8	21.8	29.3	38.0	9.3	0.08	ND	84.0
2	土	1.9	5.5	0.3	6.9	24.9	32.8	49.6	10.0	0.10	ND	92.8
3	日	2.6	5.0	0.4	7.2	26.5	33.2	48.8	12.2	0.12	ND	93.6
4	月	3.5	6.0	0.4	6.9	26.9	36.2	47.6	10.3	0.12	ND	96.2
5	火	4.4	6.2	0.7	7.0	26.3	32.4	48.4	8.4	0.06	ND	89.4
6	水	7.1	6.6	1.0	6.8	26.1	29.3	39.6	8.4	0.06	ND	85.0
7	木	4.3	6.9	1.1	6.8	24.5	30.2	41.2	8.1	0.07	ND	84.2
8	金	-0.5	5.6	1.8	6.6	22.6	30.8	77.2	17.0	0.10	ND	122.9
9	土	-0.8	2.0	1.1	6.7	26.7	34.8	83.6	19.2	0.12	ND	126.4
10	日	0.7	1.8	0.7	6.8	29.2	37.4	76.4	18.3	0.04	ND	134.0
11	月	1.9	2.1	0.5	6.9	30.7	39.4	81.6	18.2	0.03	ND	135.8
12	火	2.2	3.3	1.5	6.9	31.1	39.6	67.6	19.6	0.12	ND	143.7
13	水	2.5	4.5	1.1	7.0	29.8	37.6	79.6	17.4	0.07	ND	130.3
14	木	4.4	4.9	1.4	6.8	26.2	34.8	66.4	18.0	0.10	ND	128.5
15	金	2.3	4.8	1.6	6.9	28.1	37.8	80.4	17.8	0.11	ND	129.4
16	土	5.0	6.0	1.1	6.7	31.5	35.8	82.0	19.3	0.06	ND	133.2
17	日	2.4	5.1	1.7	6.6	21.5	28.5	69.2	19.6	0.05	ND	117.1
18	月	1.1	5.8	1.5	6.6	19.4	31.6	64.0	18.1	0.10	ND	115.3
19	火	2.1	5.0	1.8	6.8	23.1	34.8	56.0	19.6	0.10	ND	127.7
20	水	1.9	5.0	2.0	6.7	24.3	35.8	66.0	20.3	0.13	ND	133.3
21	木	3.7	5.8	1.7	6.8	25.7	37.2	76.4	18.9	0.07	ND	133.3
22	金	4.0	6.0	1.6	7.0	26.4	30.4	50.8	8.5	0.02	ND	85.9
23	土	3.4	6.0	1.1	7.0	25.4	30.8	35.6	8.3	0.03	ND	82.9
24	日	4.8	6.1	0.9	7.2	25.0	28.9	40.0	8.9	0.01	ND	85.5
25	月	8.0	6.1	1.0	6.9	23.0	32.0	41.2	8.1	0.07	ND	80.3
26	火	8.8	6.9	1.1	7.0	24.0	29.3	34.4	8.4	0.04	ND	80.5
27	水	9.8	7.0	1.5	6.8	20.8	28.1	40.8	9.7	0.05	ND	83.3
28	木	2.6	6.2	1.6	6.6	15.2	22.1	40.0	9.6	0.02	ND	74.6
29	金	2.2	6.5	1.7	6.7	17.9	24.3	42.4	9.5	0.04	ND	79.5
30	土	3.4	5.2	1.5	6.8	25.5	30.6	48.4	12.9	0.08	ND	95.1
31	日	7.7	5.9	1.0	6.8	28.0	29.9	44.0	11.7	0.04	ND	95.3
最大値		9.8	7.0	2.0	7.2	31.5	39.6	83.6	20.3	0.13	ND	143.7
最小値		-0.8	1.8	0.3	6.6	15.2	22.1	34.4	8.1	0.01	ND	74.6
平均値		3.5	5.3	1.2	6.8	25.1	32.4	56.7	13.7	0.07	ND	105.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所