

水質試験結果表(取水分)

2021年2月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	月	6.5	6.2	2.2	7.0	26.4	28.3	46.8	8.6	0.11	ND	81.1
2	火	7.8	6.2	4.7	6.9	24.0	28.3	46.0	9.3	0.28	0.01	87.5
3	水	3.9	6.0	10.4	6.7	18.5	27.7	54.4	10.1	0.23	0.04	77.4
4	木	3.6	5.9	3.6	6.8	21.6	26.3	40.0	8.6	0.16	0.01	80.4
5	金	5.6	6.4	2.7	6.9	23.7	27.7	45.6	8.5	0.16	ND	78.5
6	土	7.5	6.5	1.6	7.1	25.4	27.5	42.4	7.7	0.08	ND	76.7
7	日	7.4	7.0	1.5	7.1	28.3	28.5	41.2	6.3	0.08	ND	79.9
8	月	2.9	6.8	2.1	6.9	25.5	29.9	42.8	6.9	0.15	ND	81.2
9	火	1.7	6.3	2.0	7.1	24.1	28.9	48.4	7.2	0.13	ND	78.1
10	水	3.5	6.0	1.7	7.1	24.9	29.1	47.6	7.2	0.10	ND	79.8
11	木	7.0	6.8	1.4	7.0	25.2	31.4	41.2	6.6	0.07	ND	77.7
12	金	3.7	7.2	2.3	6.8	25.1	31.6	39.6	7.7	0.14	ND	81.8
13	土	14.8	7.2	1.3	7.3	26.1	28.7	46.8	6.3	0.05	ND	77.4
14	日	15.4	8.0	2.0	7.1	24.0	26.7	40.4	6.3	0.14	ND	75.2
15	月	10.6	8.7	5.0	7.0	20.5	25.5	44.0	8.4	0.19	0.01	77.2
16	火	6.1	7.5	92.3	6.8	13.4	24.1	156.4	9.9	3.07	0.21	69.4
17	水	1.9	6.6	30.4	6.8	18.1	25.1	83.6	12.3	1.24	0.13	89.3
18	木	2.8	3.1	13.4	6.8	21.9	28.3	76.8	13.4	0.69	0.04	103.0
19	金	1.6	4.9	3.9	6.9	22.6	27.1	48.4	7.1	0.24	0.01	77.1
20	土	6.0	5.8	1.7	7.1	23.1	27.3	43.2	7.6	0.07	ND	74.6
21	日	12.2	6.9	2.4	7.2	24.3	28.3	43.2	10.2	0.10	ND	85.0
22	月	14.7	7.8	3.2	7.0	22.0	25.9	40.4	7.4	0.25	ND	77.6
23	火	8.1	8.5	3.6	7.0	21.8	26.1	44.0	8.6	0.14	ND	80.1
24	水	10.2	7.0	3.3	6.9	19.6	24.1	43.2	8.0	0.21	ND	69.7
25	木	6.6	6.9	2.4	6.9	21.3	26.5	40.8	6.9	0.07	ND	71.1
26	金	5.7	7.0	2.1	6.8	22.1	27.7	44.8	6.6	0.13	ND	72.6
27	土	7.1	7.0	1.8	7.1	24.5	26.3	38.8	5.7	0.05	ND	70.9
28	日	9.3	7.1	1.9	7.1	23.3	26.7	40.0	6.0	0.12	ND	73.2
最大値		15.4	8.7	92.3	7.3	28.3	31.6	156.4	13.4	3.07	0.21	103.0
最小値		1.6	3.1	1.3	6.7	13.4	24.1	38.8	5.7	0.05	ND	69.4
平均値		6.9	6.7	7.4	7.0	22.9	27.5	50.4	8.1	0.30	0.02	78.7

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2021年2月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	6.5	6.2	0.8	6.9	25.4	29.1	46.0	7.8	0.04	ND	82.5
2	火	7.8	6.3	1.1	6.9	22.8	28.9	36.8	9.7	0.05	ND	89.3
3	水	3.9	6.3	1.9	6.7	16.6	23.5	42.4	11.0	0.07	ND	80.0
4	木	3.6	6.1	1.2	6.7	20.0	27.1	36.4	9.5	0.05	ND	79.2
5	金	5.6	6.6	1.2	6.8	21.5	28.5	36.0	8.8	0.06	ND	80.9
6	土	7.5	6.1	0.7	7.0	25.3	29.1	34.8	7.0	0.02	ND	78.0
7	日	7.4	7.0	0.7	7.0	28.3	29.9	36.0	9.0	0.02	ND	82.5
8	月	2.9	7.0	0.9	7.0	24.4	31.2	36.0	8.3	0.03	ND	84.5
9	火	1.7	6.8	1.1	7.0	23.3	29.7	44.8	7.8	0.02	ND	79.2
10	水	3.5	6.3	1.1	7.0	23.7	27.7	42.4	8.2	0.06	ND	81.9
11	木	7.0	6.1	0.9	7.1	25.8	27.7	38.8	8.7	0.03	ND	82.8
12	金	3.7	7.4	0.9	7.1	24.8	30.2	38.8	7.9	0.06	ND	83.6
13	土	14.8	7.3	0.9	7.2	25.6	28.5	40.8	7.2	0.05	ND	78.0
14	日	15.4	7.9	0.7	7.2	25.1	29.5	39.2	7.7	0.05	ND	76.6
15	月	10.6	8.6	1.7	7.0	20.4	25.9	38.0	8.7	0.05	ND	76.6
16	火	6.1	8.0	3.9	6.6	12.1	20.9	41.6	13.0	0.15	0.01	80.6
17	水	1.9	7.2	1.4	6.7	16.3	25.9	51.2	16.3	0.06	ND	101.1
18	木	2.8	4.8	0.9	7.0	20.5	27.9	55.6	13.4	0.06	ND	113.2
19	金	1.6	5.2	1.2	6.8	21.8	26.1	42.8	8.9	0.06	ND	83.7
20	土	6.0	6.0	0.8	6.9	22.6	26.9	36.0	8.3	0.04	ND	77.3
21	日	12.2	7.0	0.7	6.8	22.9	30.2	42.0	10.6	0.04	ND	90.9
22	月	14.7	8.0	0.7	6.8	21.6	28.7	38.4	9.3	0.04	ND	85.1
23	火	8.1	8.7	2.0	6.8	20.2	26.5	39.2	10.4	0.12	ND	85.2
24	水	10.2	7.8	1.3	6.6	17.3	24.9	41.2	9.2	0.06	ND	76.9
25	木	6.6	7.2	1.1	6.8	19.6	26.5	34.8	7.9	0.04	ND	71.5
26	金	5.7	7.3	1.1	7.0	21.4	26.3	36.0	7.1	0.05	ND	71.3
27	土	7.1	7.0	1.0	6.9	22.4	25.9	38.4	6.6	0.04	ND	71.9
28	日	9.3	7.0	0.7	7.1	22.3	26.3	39.2	7.4	0.04	ND	72.5
最大値		15.4	8.7	3.9	7.2	28.3	31.2	55.6	16.3	0.15	0.01	113.2
最小値		1.6	4.8	0.7	6.6	12.1	20.9	34.8	6.6	0.02	ND	71.3
平均値		6.9	6.9	1.2	6.9	21.9	27.5	40.1	9.1	0.05	ND	82.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所