

水質試験結果表(取水分)

2021年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	31.3	24.2	1.2	7.0	31.7	32.4	45.2	4.6	0.11	ND	85.9
2	月	32.5	24.5	2.5	7.0	31.0	34.4	53.6	4.6	0.09	ND	82.1
3	火	32.1	24.3	2.5	6.9	30.0	30.8	55.2	3.9	0.26	ND	80.4
4	水	32.5	23.7	2.8	6.9	29.2	28.9	54.0	4.1	0.22	ND	77.3
5	木	35.0	24.6	2.2	6.7	28.5	29.3	52.8	3.6	0.19	ND	76.9
6	金	32.6	24.4	3.1	6.8	27.8	28.9	50.8	4.3	0.25	ND	76.1
7	土	32.9	24.5	0.9	6.9	28.7	29.3	44.8	5.3	0.12	ND	80.6
8	日	34.4	25.3	1.5	7.0	28.8	27.3	40.8	5.1	0.07	ND	80.2
9	月	32.7	25.8	2.0	6.8	29.5	30.2	46.8	5.3	0.24	ND	82.3
10	火	24.9	23.0	23.0	6.8	18.7	22.5	75.6	3.9	0.41	0.15	53.8
11	水	25.8	22.2	23.9	6.7	21.9	25.9	95.2	16.3	0.99	0.06	109.2
12	木	27.3	22.0	7.0	6.9	25.2	31.8	82.4	21.9	0.44	0.02	136.3
13	金	22.0	21.8	4.7	6.8	28.9	34.4	102.4	22.8	0.30	ND	148.3
14	土	24.3	21.5	14.5	6.7	22.4	23.1	75.2	8.5	0.93	0.09	82.9
15	日	26.0	21.0	24.5	6.7	21.0	24.1	74.4	7.4	1.17	0.02	78.7
16	月	26.9	21.1	16.5	6.8	24.2	25.7	83.6	10.0	0.81	0.04	106.4
17	火	23.9	20.4	9.4	6.7	25.6	27.3	74.4	11.1	0.49	0.01	100.7
18	水	25.2	21.3	18.4	6.6	21.9	24.1	82.8	8.3	0.93	0.05	81.8
19	木	29.3	21.0	8.5	6.8	24.7	29.3	77.2	9.7	0.51	0.01	95.2
20	金	29.1	20.4	8.8	6.9	24.4	27.7	78.0	9.6	0.50	0.03	93.2
21	土	28.4	20.1	2.4	6.9	23.7	23.1	44.0	5.4	0.18	ND	67.5
22	日	31.6	20.5	2.1	7.0	25.9	23.9	46.8	4.4	0.20	ND	69.7
23	月	28.4	21.0	6.5	7.0	25.2	28.3	46.4	4.8	0.16	ND	69.2
24	火	26.2	20.7	4.3	6.8	25.5	26.5	48.4	5.7	0.17	ND	67.2
25	水	29.1	20.7	4.0	7.0	25.0	25.7	49.2	5.3	0.31	0.02	67.2
26	木	29.9	20.8	6.9	6.9	23.6	24.1	44.4	6.1	0.35	0.02	64.4
27	金	29.9	21.2	4.1	7.0	25.2	24.5	50.0	5.7	0.30	ND	66.5
28	土	29.9	21.3	1.8	7.0	26.1	26.3	32.4	4.0	0.14	ND	70.2
29	日	27.5	21.0	1.5	7.0	26.2	26.5	37.6	3.4	0.18	ND	73.5
30	月	28.6	22.1	2.2	6.9	27.1	28.7	36.4	4.7	0.24	0.01	74.0
31	火	27.9	20.8	2.9	7.0	26.2	29.7	48.0	4.7	0.25	ND	69.5
最大値		35.0	25.8	24.5	7.0	31.7	34.4	102.4	22.8	1.17	0.15	148.3
最小値		22.0	20.1	0.9	6.6	18.7	22.5	32.4	3.4	0.07	ND	53.8
平均値		29.0	22.2	7.0	6.9	25.9	27.6	59.0	7.2	0.37	0.02	82.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2021年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	31.3	25.0	0.6	7.1	31.3	31.4	44.8	4.8	0.08	ND	86.2
2	月	32.5	25.4	0.6	7.0	30.4	32.4	54.4	5.0	0.04	ND	84.5
3	火	32.1	25.0	0.6	6.9	29.0	29.7	48.8	5.7	0.08	ND	81.7
4	水	32.5	24.4	0.6	6.9	28.8	28.9	56.0	5.2	0.04	ND	79.3
5	木	35.0	25.2	0.3	6.8	27.8	27.5	50.8	5.1	0.03	ND	78.7
6	金	32.6	25.0	0.4	6.8	26.5	27.3	44.0	4.9	0.04	ND	76.7
7	土	32.9	25.0	0.3	7.0	27.2	27.9	40.4	4.6	0.02	ND	81.1
8	日	34.4	26.2	0.2	7.1	29.2	28.3	45.6	4.6	0.04	ND	82.6
9	月	32.7	26.1	0.1	6.9	29.3	28.1	50.4	4.9	0.01	ND	80.8
10	火	24.9	24.3	0.8	6.9	25.2	27.7	48.8	5.1	0.04	ND	77.1
11	水	25.8	23.2	1.1	6.7	18.8	26.1	74.0	18.5	0.04	ND	117.3
12	木	27.3	22.7	0.6	6.8	23.1	32.0	75.2	23.9	0.03	ND	140.1
13	金	22.0	22.3	0.7	6.8	27.9	35.0	100.0	25.3	0.04	ND	156.8
14	土	24.3	22.0	1.5	6.8	22.4	24.7	60.4	14.2	0.09	0.02	107.3
15	日	26.0	21.7	0.8	6.7	19.1	20.5	48.0	12.2	0.05	ND	94.6
16	月	26.9	21.8	0.5	6.8	21.9	26.7	64.0	15.9	0.02	ND	112.2
17	火	23.9	21.0	0.6	6.7	22.7	27.9	62.8	16.0	0.02	ND	114.2
18	水	25.2	22.0	0.7	6.5	19.0	23.1	65.2	11.7	0.03	ND	92.7
19	木	29.3	21.5	0.6	6.7	23.5	28.3	64.4	11.7	0.04	ND	99.6
20	金	29.1	21.2	0.8	6.5	22.2	27.3	79.6	11.8	0.05	ND	96.9
21	土	28.4	20.9	0.6	6.8	23.2	22.3	34.8	5.5	0.03	ND	68.6
22	日	31.6	21.0	0.4	7.0	25.0	25.1	38.8	4.8	0.02	ND	71.1
23	月	28.4	21.6	0.4	6.9	25.1	27.5	45.6	4.9	ND	ND	70.8
24	火	26.2	21.3	0.8	7.0	23.9	24.3	37.6	6.4	0.02	ND	70.5
25	水	29.1	21.3	0.7	6.8	23.7	25.9	51.6	7.0	0.05	ND	69.2
26	木	29.9	21.1	0.9	6.7	22.5	24.5	45.2	7.4	0.04	ND	66.9
27	金	29.9	22.0	0.5	6.8	23.3	24.7	49.6	7.1	0.03	ND	68.4
28	土	29.9	22.1	0.4	6.9	24.3	24.1	32.0	4.4	0.04	ND	71.1
29	日	27.5	21.5	0.4	7.1	25.9	27.5	36.4	4.8	0.05	ND	73.3
30	月	28.6	22.5	0.4	7.0	26.7	30.2	36.0	5.5	0.05	ND	74.4
31	火	27.9	21.2	0.7	6.9	25.5	26.7	52.8	5.3	0.05	ND	71.9
最大値		35.0	26.2	1.5	7.1	31.3	35.0	100.0	25.3	0.09	0.02	156.8
最小値		22.0	20.9	0.1	6.5	18.8	20.5	32.0	4.4	ND	ND	66.9
平均値		29.0	22.8	0.6	6.8	25.0	27.2	52.8	8.8	0.04	ND	87.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所