

水質試験結果表(取水分)

2021年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	25.1	19.4	1.2	6.9	25.9	26.9	44.0	4.0	0.12	ND	70.7
2	土	28.0	19.0	0.5	7.0	26.9	27.7	36.0	5.2	0.09	ND	75.1
3	日	24.3	19.0	0.6	7.0	28.8	28.1	40.0	4.3	0.04	ND	78.9
4	月	29.0	19.5	3.0	6.9	30.2	28.9	48.0	4.5	0.32	ND	82.0
5	火	25.9	20.0	1.7	6.9	31.2	31.8	54.0	5.1	0.17	ND	85.7
6	水	21.8	19.1	1.7	6.9	29.8	30.2	40.4	3.7	0.15	ND	78.4
7	木	26.5	18.9	1.2	6.8	28.3	28.7	56.0	4.3	0.07	ND	76.9
8	金	26.7	19.6	1.4	6.9	28.7	29.9	54.0	3.3	0.05	ND	78.9
9	土	26.1	20.0	0.5	7.2	29.4	31.4	45.6	3.5	0.06	ND	81.7
10	日	28.8	20.1	0.5	7.1	30.4	31.4	50.8	3.2	0.08	ND	85.2
11	月	27.8	20.5	1.9	7.0	30.9	34.2	56.0	4.6	0.14	ND	83.8
12	火	20.6	20.0	1.4	6.9	30.4	33.0	56.0	2.3	0.07	ND	82.6
13	水	21.3	19.6	2.1	6.9	29.8	32.0	55.2	2.8	0.10	ND	82.1
14	木	22.7	19.3	1.3	6.9	33.2	37.2	56.0	4.1	0.08	ND	89.3
15	金	22.1	19.0	1.2	7.0	33.5	35.2	57.6	1.9	0.13	ND	90.1
16	土	23.2	18.9	0.6	7.2	33.9	37.0	56.8	3.5	0.05	ND	92.9
17	日	14.5	18.5	0.7	7.0	33.7	41.4	48.8	3.1	0.07	ND	90.3
18	月	20.4	17.0	2.0	7.0	35.0	39.2	58.4	3.1	0.23	ND	95.8
19	火	20.0	16.5	1.0	7.1	35.1	39.2	60.0	1.1	0.06	ND	98.7
20	水	15.2	16.5	2.6	7.0	34.3	38.4	57.6	4.7	0.18	ND	97.1
21	木	15.6	15.0	2.1	6.9	28.5	37.0	48.4	5.4	0.17	ND	87.5
22	金	17.7	14.7	1.1	7.0	30.7	36.2	50.8	7.0	0.08	ND	90.6
23	土	21.2	15.0	0.7	7.1	32.1	37.4	48.0	7.2	0.09	ND	94.0
24	日	15.0	14.5	0.7	7.1	32.7	39.0	49.6	7.7	0.09	ND	93.5
25	月	12.7	14.9	1.0	7.0	34.7	40.6	45.6	7.3	0.13	ND	99.4
26	火	20.5	14.5	1.4	7.1	34.7	38.4	57.6	5.2	0.11	ND	98.1
27	水	15.2	15.2	0.8	7.1	35.6	39.0	60.0	4.4	0.12	ND	96.6
28	木	17.9	14.9	0.8	7.1	35.8	39.0	61.6	4.3	0.11	ND	99.6
29	金	18.7	14.9	0.9	7.1	37.3	41.2	65.2	6.1	0.08	ND	104.1
30	土	16.0	14.2	0.4	7.1	37.7	44.0	44.4	6.8	0.07	ND	108.1
31	日	16.1	15.0	0.5	7.2	38.1	42.0	51.6	3.1	0.09	ND	109.2
最大値		29.0	20.5	3.0	7.2	38.1	44.0	65.2	7.7	0.32	ND	109.2
最小値		12.7	14.2	0.4	6.8	25.9	26.9	36.0	1.1	0.04	ND	70.7
平均値		21.2	17.5	1.2	7.0	32.2	35.3	52.1	4.4	0.11	ND	89.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2021年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	25.1	20.0	0.9	6.8	25.8	26.5	36.0	4.0	0.04	ND	71.2
2	土	28.0	19.5	0.6	7.0	26.7	25.5	35.2	5.0	0.04	ND	74.7
3	日	24.3	19.6	0.3	7.1	28.8	28.3	36.4	4.7	0.03	ND	78.6
4	月	29.0	20.2	0.7	7.0	29.4	30.2	48.8	4.7	0.03	ND	81.3
5	火	25.9	20.5	1.0	7.0	30.2	30.6	58.0	5.3	0.08	ND	85.2
6	水	21.8	19.8	1.1	6.9	29.7	29.1	48.0	4.3	0.07	ND	79.6
7	木	26.5	19.5	0.6	7.0	28.4	28.3	52.8	3.8	0.04	ND	77.4
8	金	26.7	20.2	0.7	7.0	28.7	27.9	49.2	4.0	0.04	ND	79.7
9	土	26.1	20.5	0.3	7.2	28.8	28.7	46.8	5.1	0.04	ND	81.9
10	日	28.8	20.9	0.3	7.1	31.0	32.0	52.4	4.6	0.04	ND	84.5
11	月	27.8	21.1	0.4	7.1	30.4	31.6	51.2	5.2	0.07	ND	84.7
12	火	20.6	20.3	0.6	7.0	29.8	33.8	49.2	4.8	0.06	ND	83.5
13	水	21.3	20.0	0.7	7.0	30.5	32.4	52.0	4.0	0.08	ND	84.4
14	木	22.7	19.9	0.8	7.1	32.3	35.4	40.8	4.9	0.06	ND	90.3
15	金	22.1	19.6	0.7	7.0	33.2	36.6	48.8	3.8	0.03	ND	91.5
16	土	23.2	19.3	0.3	7.3	34.5	37.0	46.8	3.5	0.03	ND	93.8
17	日	14.5	19.0	0.5	7.2	34.9	34.0	46.8	1.1	0.03	ND	90.2
18	月	20.4	18.0	0.6	7.2	34.9	37.6	56.0	4.5	0.10	ND	95.0
19	火	20.0	17.1	0.7	7.1	35.5	38.0	54.0	5.2	0.04	ND	98.8
20	水	15.2	17.0	0.9	7.1	32.1	34.8	48.4	7.3	0.05	ND	95.6
21	木	15.6	15.8	1.6	7.0	28.4	36.2	52.8	7.2	0.11	ND	88.5
22	金	17.7	15.0	0.9	7.0	30.4	35.2	49.6	7.8	0.02	ND	90.2
23	土	21.2	15.2	0.4	7.3	32.3	38.0	51.6	7.6	0.06	ND	94.1
24	日	15.0	15.0	0.5	7.1	32.6	38.8	38.0	7.2	0.08	ND	94.3
25	月	12.7	15.3	0.5	7.1	34.0	41.0	48.4	7.8	0.05	ND	99.7
26	火	20.5	15.1	0.9	7.0	34.6	39.2	58.4	7.2	0.08	ND	100.5
27	水	15.2	15.7	0.5	7.2	34.1	38.4	55.2	5.6	0.08	ND	95.9
28	木	17.9	15.4	0.6	7.1	35.6	38.4	52.0	6.7	0.08	ND	99.5
29	金	18.7	15.5	0.6	7.1	36.6	41.4	63.6	6.4	0.07	ND	104.2
30	土	16.0	14.8	0.3	7.3	37.5	43.2	40.4	4.3	0.04	ND	108.7
31	日	16.1	15.7	0.2	7.2	38.0	42.8	43.2	7.1	0.08	ND	109.6
最大値		29.0	21.1	1.6	7.3	38.0	43.2	63.6	7.8	0.11	ND	109.6
最小値		12.7	14.8	0.2	6.8	25.8	25.5	35.2	1.1	0.02	ND	71.2
平均値		21.2	18.1	0.6	7.1	31.9	34.5	48.7	5.3	0.06	ND	89.9

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所