

水質試験結果表(取水分)

2022年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	火	8.8	6.0	1.5	6.9	28.6	33.4	40.4	6.6	0.12	ND	88.8
2	水	3.7	6.0	2.6	7.0	27.9	31.4	49.2	7.3	0.18	ND	88.7
3	木	7.6	6.4	1.9	6.9	27.5	32.6	38.0	6.7	0.14	ND	86.9
4	金	6.4	6.2	2.3	6.9	26.4	31.2	46.4	7.2	0.13	ND	85.1
5	土	10.4	6.8	1.0	7.0	26.5	30.6	40.8	7.8	0.09	ND	86.0
6	日	4.2	6.5	1.4	7.0	27.2	31.2	40.0	8.6	0.08	ND	87.3
7	月	7.1	6.0	1.7	7.0	27.2	33.6	41.6	8.3	0.15	ND	90.6
8	火	5.9	6.3	1.7	6.9	28.4	32.0	56.4	7.4	0.12	ND	90.0
9	水	6.7	6.5	1.7	7.0	28.2	34.2	51.2	7.4	0.12	ND	87.1
10	木	6.6	6.8	1.8	6.8	27.3	32.4	50.8	6.2	0.16	ND	85.4
11	金	11.9	7.2	1.8	6.8	27.4	32.4	45.6	6.4	0.13	ND	85.4
12	土	13.6	7.9	1.3	7.0	27.1	31.6	42.4	6.6	0.11	ND	82.1
13	日	16.0	8.1	2.2	7.0	21.7	29.1	39.6	6.2	0.13	ND	76.8
14	月	12.5	7.3	5.7	6.8	18.7	26.1	42.8	7.7	0.37	0.03	71.5
15	火	12.4	8.9	27.8	6.7	16.4	23.3	70.4	10.2	1.08	0.21	81.3
16	水	12.9	8.3	36.1	6.7	16.9	22.3	90.8	10.0	1.32	0.27	80.3
17	木	12.6	9.3	18.5	6.7	18.9	25.9	70.0	11.0	0.80	0.03	87.8
18	金	7.5	9.2	11.1	6.8	20.6	26.3	57.2	11.0	0.55	0.03	93.6
19	土	9.0	8.2	15.4	6.8	16.7	23.9	56.4	8.2	0.83	0.13	71.1
20	日	8.1	8.1	10.6	6.9	17.1	23.1	55.6	9.4	0.50	ND	80.3
21	月	6.3	8.9	5.4	7.0	19.4	26.7	52.0	10.2	0.30	ND	88.0
22	火	6.1	9.2	7.5	6.7	21.3	28.3	63.2	10.9	0.40	ND	92.8
23	水	5.0	8.2	6.6	6.9	22.0	28.5	60.4	11.1	0.37	0.02	100.4
24	木	9.4	9.0	4.9	6.8	24.4	29.1	69.6	11.6	0.31	0.02	107.4
25	金	11.5	9.3	4.6	6.7	25.1	32.6	65.6	10.7	0.30	0.02	103.3
26	土	14.2	10.2	5.1	6.9	24.3	28.3	58.4	10.6	0.34	0.02	103.3
27	日	11.8	9.7	20.7	6.9	17.4	22.1	69.6	8.0	1.03	0.14	72.3
28	月	14.7	10.2	24.2	6.8	18.0	22.5	57.2	8.2	1.03	0.20	73.9
29	火	8.8	10.0	12.0	6.9	21.1	25.7	68.0	9.7	0.60	0.02	90.8
30	水	18.3	10.2	7.8	6.7	22.8	28.1	62.8	10.6	0.44	0.02	97.7
31	木	12.1	11.3	8.2	6.8	21.1	25.1	51.2	8.3	0.40	0.03	83.0
最大値		18.3	11.3	36.1	7.0	28.6	34.2	90.8	11.6	1.32	0.27	107.4
最小値		3.7	6.0	1.0	6.7	16.4	22.1	38.0	6.2	0.08	ND	71.1
平均値		9.7	8.1	8.2	6.9	23.0	28.5	55.0	8.7	0.41	0.04	87.1

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2022年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	火	8.8	6.7	0.5	6.9	27.2	32.2	36.8	8.3	0.07	ND	90.8
2	水	3.7	6.5	0.7	6.9	26.2	33.2	48.0	8.2	0.04	ND	90.8
3	木	7.6	7.0	0.7	6.9	26.3	33.0	33.6	8.2	0.04	ND	88.4
4	金	6.4	7.0	0.7	6.9	25.1	32.6	42.4	7.6	0.03	ND	87.0
5	土	10.4	7.6	0.5	7.0	25.6	31.8	35.2	8.0	0.02	ND	88.4
6	日	4.2	7.0	0.3	7.0	26.0	33.6	38.4	7.3	0.03	ND	87.8
7	月	7.1	6.8	0.7	7.0	25.4	30.6	43.2	8.7	0.03	ND	91.0
8	火	5.9	7.0	0.7	6.9	26.8	32.4	60.0	8.1	0.04	ND	91.3
9	水	6.7	7.2	0.7	6.9	27.4	36.6	40.8	8.0	0.04	ND	89.9
10	木	6.6	7.4	0.7	6.9	27.0	32.0	43.6	8.1	0.04	ND	88.6
11	金	11.9	7.9	0.7	6.7	26.1	31.8	44.0	8.4	0.04	ND	88.2
12	土	13.6	8.5	0.4	6.9	25.4	31.4	44.4	7.4	0.02	ND	85.5
13	日	16.0	9.0	0.3	6.9	22.0	29.3	34.4	8.2	0.02	ND	81.7
14	月	12.5	8.0	0.4	6.8	18.8	26.7	42.8	8.5	0.01	ND	76.2
15	火	12.4	9.3	1.9	6.6	13.5	22.7	48.4	14.9	0.07	ND	93.8
16	水	12.9	9.0	1.3	6.6	13.8	21.9	44.0	14.9	0.05	ND	93.9
17	木	12.6	10.1	0.8	6.7	16.9	25.3	41.6	15.4	0.02	ND	99.2
18	金	7.5	9.6	0.7	6.7	19.2	27.1	45.2	14.3	0.03	ND	103.7
19	土	9.0	8.9	0.5	6.7	15.8	22.1	37.2	11.0	0.02	ND	93.5
20	日	8.1	8.6	0.6	6.7	15.6	24.9	49.2	14.0	0.02	ND	93.4
21	月	6.3	9.3	0.6	6.8	18.1	24.3	41.6	14.4	0.01	ND	98.7
22	火	6.1	9.6	0.5	6.8	20.2	27.1	56.0	13.4	0.01	ND	102.4
23	水	5.0	8.7	1.2	6.7	21.0	30.2	58.0	14.2	0.05	ND	107.0
24	木	9.4	9.2	0.6	6.7	23.1	29.9	69.6	13.7	0.03	ND	112.7
25	金	11.5	9.8	0.7	6.8	22.6	31.2	56.8	13.4	0.04	ND	111.9
26	土	14.2	10.6	0.3	6.8	23.8	30.8	48.4	13.5	0.02	ND	112.7
27	日	11.8	10.2	0.6	6.7	17.1	23.9	33.6	11.3	0.02	ND	87.5
28	月	14.7	10.8	0.8	6.6	15.3	23.5	35.2	11.0	0.03	ND	79.1
29	火	8.8	10.4	1.3	6.7	18.1	26.1	56.4	11.8	0.03	ND	93.1
30	水	18.3	10.5	0.7	6.6	20.3	29.3	53.6	12.4	0.03	ND	100.7
31	木	12.1	11.7	0.8	6.7	20.2	25.1	48.0	10.9	0.03	ND	90.9
最大値		18.3	11.7	1.9	7.0	27.4	36.6	69.6	15.4	0.07	ND	112.7
最小値		3.7	6.5	0.3	6.6	13.5	21.9	33.6	7.3	0.01	ND	76.2
平均値		9.7	8.7	0.7	6.8	21.6	28.8	45.5	10.9	0.03	ND	93.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所