

県営第一工業用水道 水質試験結果表

2025年10月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	21.4	22.4	5.2	6.4						16.0	13	
2	晴	20.8	21.7	5.5	6.4						15.8	12	
3	曇	21.5	21.6	3.5	6.3						16.3	5	
4	雨	19.8	21.5	3.4	6.3						16.6	15	
5	雨	21.5	21.3	7.6	6.3						15.2	15	
6	晴	22.5	21.6	6.5	6.3						14.9	50	13時間25分
7	晴	23.2	21.6	6.8	6.4						15.2	30	1時間55分
8	曇	23.5	22.3	4.3	6.4	31.3	33.2	79.5	9.4	0.10	15.6	6	
9	晴	21.7	22.1	3.6	6.4						16.0	5	
10	晴	19.5	21.4	3.0	6.4						16.1	4	
11	曇	21.9	21.4	1.8	6.4						16.3	15	
12	晴	24.2	21.8	1.5	6.4						16.6	5	
13	曇	22.6	22.3	1.7	6.4						16.8	9	
14	曇	20.0	21.7	3.3	6.4						17.0	37	2時間40分
15	曇	21.2	21.2	3.9	6.4	32.4	35.6	120.0	10.0	0.10	15.6	6	
16	曇	21.3	21.1	3.1	6.4						15.7	10	
17	晴	19.9	20.9	9.1	6.3						15.2	43	14時間40分
18	晴	21.5	20.9	4.6	6.4						15.8	21	
19	曇	19.4	20.7	2.5	6.4						15.6	7	
20	晴	17.7	20.1	3.3	6.4						15.6	12	
21	曇	14.6	18.2	3.2	6.5						15.7	33	
22	曇	13.7	17.4	2.4	6.4	32.4	34.6	77.5	9.4	0.10	15.6	3	
23	晴	13.9	17.1	2.3	6.4						15.7	3	
24	晴	13.9	17.2	2.3	6.4						15.5	3	
25	晴	15.3	17.1	1.7	6.4						15.6	2	
26	雨	17.0	17.5	4.3	6.3						13.8	42	11時間00分
27	曇	15.5	17.4	6.8	6.3						13.7	52	19時間31分
28	曇	12.1	16.3	6.0	6.5						13.4	19	5時間14分
29	晴	11.2	15.2	4.3	6.5						13.7	6	
30	晴	12.8	14.9	3.6	6.5						13.9	4	
31	曇	12.7	15.2	3.4	6.5						14.2	4	
最大	——	24.2	22.4	9.1	6.5	32.4	35.6	120.0	10.0	0.10	17.0	52	——
最小	——	11.2	14.9	1.5	6.3	31.3	33.2	77.5	9.4	0.10	13.4	2	
平均	——	18.6	19.8	4.0	6.4	32.0	34.5	92.3	9.6	0.10	15.4	16	68時間25分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、p H（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定