

県営第一工業用水道 水質試験結果表

2025年11月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	14.3	15.2	4.8	6.4						13.1	22	
2	晴	14.2	15.4	5.4	6.4						13.1	43	14時間57分
3	雨	10.9	14.9	4.1	6.4						12.9	75	14時間49分
4	晴	10.2	13.9	5.0	6.5						12.4	43	12時間19分
5	晴	12.7	13.9	5.5	6.5	24.9	27.6	70.0	8.2	0.10	12.6	9	
6	晴	13.8	14.3	4.2	6.4						12.8	5	
7	晴	13.8	14.5	3.9	6.4						13.0	5	
8	晴	11.6	13.8	2.7	6.4						13.0	13	
9	雨	13.4	14.2	2.0	6.4						13.0	5	
10	雨	12.1	14.3	5.9	6.4						12.8	11	
11	晴	10.7	13.5	5.9	6.5						12.7	21	
12	晴	9.3	12.6	3.4	6.4	26.8	29.5	77.5	8.1	0.10	13.0	4	
13	曇	12.0	12.9	3.1	6.4						13.2	5	
14	晴	11.6	13.1	2.6	6.4						13.3	3	
15	晴	10.1	12.7	2.2	6.5						13.3	2	
16	晴	10.9	12.3	1.8	6.4						13.6	13	
17	晴	12.7	12.6	2.3	6.4						13.7	4	
18	曇	9.0	12.6	3.1	6.4						13.8	12	
19	曇	7.9	11.6	4.6	6.4	27.7	31.2	77.0	8.7	0.10	13.2	10	
20	晴	9.0	11.4	2.8	6.4						13.3	4	
21	曇	10.9	11.7	2.8	6.4						13.3	5	
22	曇	10.6	11.9	4.6	6.4						12.8	8	
23	晴	9.3	11.5	2.1	6.4						13.3	2	
24	晴	10.2	11.4	2.2	6.4						13.3	3	
25	雨	10.1	11.7	2.3	6.4						13.4	3	
26	雨	9.5	11.6	5.4	6.3						13.1	51	13時間06分
27	晴	10.1	11.4	5.8	6.5						12.7	20	2時間44分
28	雨	10.3	12.0	5.8	6.4						13.0	26	4時間32分
29	晴	7.9	11.4	5.1	6.5						12.7	14	
30	晴	8.5	10.9	2.5	6.5						12.8	7	
最大	—	14.3	15.4	5.9	6.5	27.7	31.2	77.5	8.7	0.10	13.8	75	—
最小	—	7.9	10.9	1.8	6.3	24.9	27.6	70.0	8.1	0.10	12.4	2	
平均	—	10.9	12.8	3.8	6.4	26.5	29.4	74.8	8.3	0.10	13.1	15	62時間27分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場

水温、濁度、p H（3項目ともに日平均）は配水池管理棟

他項目は日野川地区水道管理事務所にて測定