

県営第一工業用水道 水質試験結果表

2026年5月分

日	天候	気温 [°C]	水温 [°C]	日平均濁度 [mg/L]	pH	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	雨	15.2	15.4	9.3	6.4						14.0	36	4時間32分
2	晴	17.1	15.1	8.2	6.3						13.8	91	23時間47分
3	曇	18.6	15.4	8.7	6.4						13.2	49	4時間37分
4	曇	15.7	15.4	9.6	6.4						12.8	13	
5	晴	16.3	14.7	8.1	6.4						12.3	10	
6	晴	19.2	15.7	6.8	6.5						12.3	10	
7	晴	21.2	16.7	8.4	6.5						12.2	17	
8	曇	17.6	17.0	7.4	6.4	23.2	25.8	65.5	8.9	0.10	12.8	7	
9	曇	15.4	15.9	8.6	6.3						12.9	10	
10	晴	16.7	15.8	6.0	6.3						13.3	6	
11	晴	21.1	16.9	6.8	6.3						13.5	8	
12	晴	21.6	18.2	7.7	6.3						13.8	9	
13	晴	21.3	18.8	7.0	6.3	24.8	28.3	64.5	10.1	0.10	14.2	66	
14	晴	20.2	19.0	6.2	6.3						14.0	5	
15	曇	20.2	19.0	6.2	6.3						14.6	5	
16	晴	21.8	18.9	4.4	6.3						15.6	11	
17	晴	20.3	19.2	3.2	6.2						17.0	4	
18	晴	24.7	19.8	5.1	6.2						17.7	6	
19	晴	25.7	20.4	5.2	6.2						17.4	14	
20	晴	24.7	20.6	5.3	6.2	30.5	33.5	95.5	13.9	0.10	17.6	4	
21	雨	22.8	20.4	5.5	6.2						15.8	7	
22	雨	19.5	19.6	7.0	6.3						14.2	9	
23	曇	21.9	19.0	5.9	6.3						14.2	10	
24	曇	24.2	19.7	3.5	6.3						14.6	3	
25	晴	24.5	20.3	3.5	6.2						16.5	3	
26	曇	26.5	21.0	3.8	6.2						19.4	2	
27	曇	26.2	21.2	3.9	6.3						22.2	2	
28	曇	24.3	21.2	3.7	6.4						28.1	2	
29	曇	20.7	20.7	5.5	6.3						15.8	5	
30	晴	22.6	20.0	4.5	6.2						17.0	10	
31	晴	25.1	20.9	2.9	6.4						27.5	3	
最大	——	26.5	21.2	9.6	6.5	30.5	33.5	95.5	13.9	0.10	28.1	91	——
最小	——	15.2	14.7	2.9	6.2	23.2	25.8	64.5	8.9	0.10	12.2	2	
平均	——	21.1	18.4	6.1	6.3	26.2	29.2	75.2	11.0	0.10	15.8	14	32時間56分

標準値 20以下 6.5~8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、pH（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定