

県営第一工業用水道 水質試験結果表

2026年6月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	晴	27.4	21.6	4.1	6.5						29.1	5	
2	雨	22.8	21.1	4.4	6.4						24.4	9	0時間13分
3	曇	21.7	20.4	7.1	6.3	25.6	29.8	76.5	10.9	0.10	14.2	39	11時間54分
4	曇	22.4	20.2	8.4	6.3						14.1	12	0時間26分
5	曇	23.2	20.6	6.1	6.3						14.9	5	
6	曇	23.6	20.9	3.7	6.2						15.8	9	
7	曇	21.5	21.2	2.8	6.2						17.0	3	
8	曇	21.9	20.6	6.0	6.3						14.1	7	
9	曇	20.4	20.5	6.5	6.3						14.2	6	
10	晴	21.2	20.8	6.2	6.4	27.4	29.3	74.0	9.6	0.10	14.1	6	
11	晴	23.9	21.5	4.8	6.1						15.9	22	
12	晴	24.7	22.3	5.0	6.3						27.4	276	0時間59分
13	晴	24.5	22.6	3.3	6.2						17.3	9	
14	曇	25.0	22.8	2.3	6.3						21.3	5	
15	曇	24.4	23.1	3.8	6.3						28.4	5	
16	曇	24.6	23.2	4.8	6.4						20.3	13	
17	晴	26.9	23.7	3.6	6.4	33.8	37.6	95.0	14.9	0.10	18.5	2	
18	晴	27.0	24.3	3.1	6.5						41.9	2	
19	晴	27.4	24.5	3.2	6.4						22.7	10	0時間18分
20	雨	23.7	24.1	2.5	6.3						22.3	6	
21	曇	23.3	22.9	4.8	6.2						14.7	5	
22	雨	21.1	22.2	5.6	6.3						14.0	8	
23	曇	22.1	21.6	4.9	6.4						14.5	5	
24	曇	23.7	21.7	4.3	6.3						14.9	3	
25	曇	22.5	21.9	4.0	6.3						15.6	3	
26	雨	23.3	21.5	10.8	6.3						13.6	14	
27	曇	23.0	21.2	7.0	6.2						13.8	11	
28	曇	23.7	21.0	3.8	6.3						13.2	4	
29	曇	25.9	22.2	4.7	6.4						13.2	5	
30	曇	26.6	23.2	4.9	6.4						13.9	5	
最大	——	27.4	24.5	10.8	6.5	33.8	37.6	95.0	14.9	0.10	41.9	276	——
最小	——	20.4	20.2	2.3	6.1	25.6	29.3	74.0	9.6	0.10	13.2	2	
平均	——	23.8	22.0	4.9	6.3	28.9	32.2	81.8	11.8	0.10	18.3	17	13時間50分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場

水温、濁度、p H（3項目ともに日平均）は配水池管理棟

他項目は日野川地区水道管理事務所にて測定