

県営第一工業用水道 水質試験結果表

2026年8月分

日	天候	気温 [℃]	水温 [℃]	日平均濁度 [mg/L]	p H	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	電気伝導率 [mS/m]	原水最高濁度 [mg/L]	ろ過装置 運転時間
1	曇	30.0	26.7	4.3	6.5						22.9	13	
2	曇	31.2	27.4	3.5	6.4						20.7	6	
3	晴	30.8	27.8	6.6	6.4						28.1	10	
4	晴	30.6	28.3	10.5	6.4						15.1	45	1時間36分
5	晴	31.0	28.6	5.8	6.3	31.1	37.8	104.5	14.8		19.2	6	
6	晴	31.5	28.6	4.6	6.5						33.1	3	
7	晴	33.0	28.7	4.1	6.5						24.6	2	
8	晴	28.7	28.3	2.8	6.4						27.3	6	
9	晴	28.2	27.4	4.2	6.4						14.3	6	
10	曇	27.2	26.8	5.9	6.5						14.7	7	
11	曇	25.5	26.0	5.1	6.4						14.9	5	
12	曇	28.0	25.7	4.1	6.3	30.0	33.6	80.0	10.3		15.4	60	1時間35分
13	晴	29.3	25.5	2.8	6.3						15.6	12	
14	晴	28.8	25.9	2.3	6.3						16.2	4	
15	晴	27.8	26.4	2.5	6.2						15.8	6	
16	曇	28.6	26.3	2.3	6.3						16.0	2	
17	晴	29.8	26.4	5.4	6.3						16.1	12	
18	晴	30.3	26.9	4.0	6.5						26.0	2	
19	晴	30.4	27.1	3.7	6.7	60.6	53.1	206.0	40.3		49.2	62	1時間34分
20	晴	30.5	27.6	3.3	6.7						38.6	2	
21	晴	30.5	27.6	2.9	6.8						47.3	1	
22	晴	29.8	27.4	1.8	6.7						48.9	6	
23	晴	31.0	27.6	1.5	6.5						35.7	1	
24	晴	31.6	28.3	3.0	6.7						41.8	4	
25	晴	31.9	28.4	2.9	6.9						50超	2	
26	晴	31.8	28.3	2.7	6.8						50超	2	
27	曇	26.8	27.5	3.1	6.5						31.8	4	
28	曇	26.9	25.6	8.2	6.2						19.0	262	19時間26分
29	雨	26.4	25.4	6.0	6.3						17.8	32	7時間15分
30	雨	26.3	25.1	7.1	6.2						17.2	70	20時間20分
31	晴	27.6	25.6	4.1	6.4						16.4	49	19時間43分
最大	——	33.0	28.7	10.5	6.9	60.6	53.1	206.0	40.3		49.2	262	——
最小	——	25.5	25.1	1.5	6.2	30.0	33.6	80.0	10.3		14.3	1	
平均	——	29.4	27.1	4.2	6.5	40.6	41.5	130.2	21.8		24.8	23	71時間29分

標準値 20以下 6.5～8.0 75以下 120以下 250以下 80以下 0.3以下 参考値

測定項目中、気温（日平均）、電気伝導率（9時）は県営第一工業用水道取水場
水温、濁度、p H（3項目ともに日平均）は配水池管理棟
他項目は日野川地区水道管理事務所にて測定