

平成29年度 週検査結果総括表その1

検査月			4月				5月				6月				7月				8月				9月				
項目	水質基準等	地点	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	
気 温	℃	原水	4	18.6	11.2	13.7	5	25.8	13.0	19.9	4	24.6	19.3	21.6	4	32.4	26.4	28.7	5	31.9	23.3	27.6	4	24.2	21.5	22.9	
		浄水	4	18.6	11.2	13.7	5	25.8	13.0	19.9	4	24.6	19.3	21.6	4	32.4	26.4	28.7	5	31.9	23.3	27.6	4	24.2	21.5	22.9	
		清水	4	24.5	11.0	17.6	5	31.8	19.7	24.9	4	30.5	21.7	26.5	4	34.8	26.1	30.3	5	34.4	24.2	29.2	4	31.2	23.5	28.9	
		鯖江	4	21.2	12.1	15.6	5	28.4	16.3	22.4	4	28.4	21.4	25.4	4	33.8	26.7	29.1	5	33.7	24.0	28.8	4	28.9	23.8	26.1	
		南条	4	19.9	11.1	14.5	5	27.5	15.3	21.5	4	27.8	20.1	24.3	4	33.5	26.0	28.8	5	31.2	23.3	27.6	4	26.9	22.6	24.3	
		朝日	1	14.6	14.6	14.6	1	20.2	20.2	20.2	1	32.1	32.1	32.1	1	33.1	33.1	33.1	1	26.2	26.2	26.2	1	23.8	23.8	23.8	
		今立	1	12.8	12.8	12.8	1	20.5	20.5	20.5	1	28.1	28.1	28.1	1	32.6	32.6	32.6	1	24.2	24.2	24.2	1	23.0	23.0	23.0	
水 温	℃	原水	4	11.8	7.8	9.9	5	15.8	10.9	13.7	4	16.8	15.3	15.9	4	22.1	20.7	21.2	5	22.2	20.1	21.4	4	20.1	18.0	18.8	
		浄水	4	12.3	8.9	10.4	5	17.3	12.0	14.8	4	17.8	16.7	17.3	4	22.7	21.1	21.9	5	23.2	20.5	22.2	4	20.8	19.2	20.1	
		清水	4	12.3	8.5	10.7	5	17.6	13.2	15.9	4	18.8	17.8	18.4	4	23.1	20.8	22.0	5	24.8	21.6	22.8	4	21.5	19.3	20.6	
		鯖江	4	12.7	9.2	10.7	5	17.4	12.2	15.3	4	18.2	16.6	17.3	4	22.3	20.3	21.5	5	23.5	20.1	22.0	4	21.3	18.7	20.0	
		南条	4	13.6	8.8	11.3	5	18.5	13.5	16.5	4	19.5	18.3	19.0	4	23.5	21.9	22.5	5	24.3	21.7	23.2	4	21.8	19.8	20.8	
		朝日	1	11.7	11.7	11.7	1	15.9	15.9	15.9	1	19.0	19.0	19.0	1	21.8	21.8	21.8	1	24.3	24.3	24.3	1	21.3	21.3	21.3	
		今立	1	11.2	11.2	11.2	1	15.2	15.2	15.2	1	17.8	17.8	17.8	1	21.8	21.8	21.8	1	22.9	22.9	22.9	1	20.6	20.6	20.6	
濁度	比濁	2度	原水	4	28	1.7	10	5	3.5	2.3	3.0	4	2.5	1.8	2.1	4	29	1.5	13	5	250	2.1	55	4	15	2.2	6.1
		以下	浄水	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2
		清水	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	
		鯖江	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	
		南条	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	
		朝日	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	
		今立	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	
	積分	2度	原水	4	22.7	1.2	8.1	5	3.9	2.2	3.0	4	2.1	1.9	1.9	4	20.1	1.6	9.9	5	220.0	2.0	48.0	4	16.2	1.6	5.9
		以下	浄水	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1
		清水	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	
		鯖江	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	
		南条	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	
		朝日	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	
		今立	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	
色度	比色	5度	原水	4	4.5	1.6	2.7	5	3.0	2.2	2.6	4	3.0	2.0	2.4	4	9.0	2.0	4.7	5	18.4	2.5	5.9	4	3.5	2.5	3.0
		以下	浄水	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	0.5	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5
		清水	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		鯖江	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		南条	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		朝日	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	
		今立	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	
	透過	5度	原水	4	3.0	1.1	1.7	5	1.8	1.5	1.6	4	1.6	1.4	1.5	4	5.7	1.9	3.2	5	11.6	2.0	4.0	4	2.5	1.6	1.9
		以下	浄水	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5
		清水	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		鯖江	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		南条	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	
		朝日	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	
		今立	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	
pH	5.8～8.6	原水	4	7.31	7.02	7.14	5	7.18	7.05	7.10	4	7.26	7.15	7.22	4	7.25	7.14	7.19	5	7.27	7.01	7.19	4	7.32	7.11	7.24	
		浄水	4	7.21	7.06	7.12	5	7.14	7.02	7.09	4	7.19	7.06	7.12	4	7.30	7.17	7.25	5	7.24	7.10	7.16	4	7.21	7.12	7.15	
		清水	4	7.29	7.18	7.22	5	7.31	7.19	7.23	4	7.39	7.22	7.30	4	7.47	7.35	7.40	5	7.46	7.27	7.36	4	7.37	7.25	7.30	
		鯖江	4	7.26	7.13	7.18	5	7.21	7.11	7.18	4	7.29	7.14	7.21	4	7.35	7.28	7.33	5	7.34	7.20	7.28	4	7.27	7.21	7.25	
		南条	4	7.25	7.09	7.17	5	7.23	7.09	7.17	4	7.28	7.14	7.20	4	7.33	7.27	7.31	5	7.37	7.17	7.26	4	7.26	7.22	7.24	
		朝日	1	7.15	7.15	7.15	1	7.24	7.24	7.24	1	7.29	7.29	7.29	1	7.39	7.39	7.39	1	7.32	7.32	7.32	1	7.28	7.28	7.28	
		今立	1	7.14	7.14	7.14	1	7.23	7.23	7.23	1	7.26	7.26	7.26	1	7.35	7.35	7.35	1	7.30	7.30	7.30	1	7.24	7.24	7.24	
残留塩素	0.1～1mg/l	原水	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
		浄水	4	0.33	0.32	0.33	5	0.36	0.32	0.34	4	0.36	0.36	0.36	4	0.42	0.35	0.38	5	0.39	0.34	0.36	4	0.37	0.35	0.36	
		清水	4	0.31	0.29	0.30	5	0.31	0.29	0.30	4	0.31	0.30	0.31	4	0.32	0.28	0.30	5	0.32	0.29	0.30	4	0.32	0.29	0.30	
		鯖江	4	0.31	0.30	0.30	5	0.32	0.30	0.31	4	0.33	0.32	0.33	4	0.38	0.29	0.32	5	0.33	0.29	0.31	4	0.32	0.31	0.32	
		南条	4	0.31	0.30	0.30	5	0.32	0.30	0.31	4	0.32	0.30	0.31	4	0.35	0.30	0.32	5	0.35	0.29	0.32	4	0.32	0.31	0.31	
		朝日	1	0.																							

10月				11月				12月				1月				2月				3月				年間			
回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
5	22.8	11.1	16.7	4	13.6	6.0	9.6	4	6.2	1.5	4.0	5	3.5	1.4	2.3	4	3.6	0.3	2.1	4	10.3	2.5	6.4	52	32.4	0.3	14.8
5	22.8	11.1	16.7	4	13.6	6.0	9.6	4	6.2	1.5	4.0	5	3.5	1.4	2.3	4	3.6	0.3	2.1	4	10.3	2.5	6.4	52	32.4	0.3	14.8
5	29.9	16.9	21.3	4	24.3	12.2	15.8	4	9.8	3.6	6.5	5	8.3	0.8	4.0	4	10.2	2.0	6.5	4	21.3	7.5	14.2	52	34.8	0.8	18.9
5	25.8	14.8	18.6	4	18.6	7.6	12.3	4	8.1	1.7	4.3	5	4.4	0.5	2.6	4	5.0	1.3	3.3	4	16.4	5.7	11.1	52	33.8	0.5	16.7
5	25.3	13.8	18.5	4	20.2	6.5	12.9	4	6.5	1.2	3.5	5	4.5	0.8	2.7	4	5.3	-0.5	3.4	4	14.7	3.7	9.5	52	33.5	-0.5	16.1
1	28.5	28.5	28.5	1	12.2	12.2	12.2	1	1.9	1.9	1.9	1	7.0	7.0	7.0	1	9.8	9.8	9.8	1	19.2	19.2	19.2	12	33.1	1.9	19.1
1	24.8	24.8	24.8	1	12.7	12.7	12.7	1	1.2	1.2	1.2	1	4.3	4.3	4.3	1	3.6	3.6	3.6	1	11.4	11.4	11.4	12	32.6	1.2	16.6
5	17.8	12.8	15.6	4	12.2	9.4	10.8	4	9.0	6.1	7.1	5	6.0	2.5	5.0	4	4.6	2.3	3.7	4	8.8	5.3	6.8	52	22.2	2.3	12.6
5	18.8	13.3	16.1	4	13.0	9.8	11.2	4	9.1	6.9	7.6	5	5.9	2.6	4.9	4	5.2	1.9	3.8	4	9.0	5.2	7.0	52	23.2	1.9	13.2
5	19.1	15.7	17.5	4	14.4	10.3	12.6	4	10.8	7.2	8.9	5	7.2	4.7	6.2	4	5.1	3.8	4.4	4	8.4	6.1	7.3	52	24.8	3.8	14.1
5	18.4	13.6	16.1	4	13.2	10.3	11.5	4	9.8	6.4	7.9	5	6.4	3.0	5.3	4	6.0	2.2	4.4	4	9.4	5.8	7.5	52	23.5	2.2	13.4
5	18.7	14.6	16.9	4	13.5	10.4	11.6	4	10.0	6.3	7.8	5	6.5	3.8	5.6	4	5.8	2.7	4.3	4	9.4	6.4	7.8	52	24.3	2.7	14.0
1	18.3	18.3	18.3	1	12.7	12.7	12.7	1	8.6	8.6	8.6	1	5.2	5.2	5.2	1	5.5	5.5	5.5	1	6.8	6.8	6.8	12	24.3	5.2	14.3
1	18.2	18.2	18.2	1	12.1	12.1	12.1	1	7.6	7.6	7.6	1	5.4	5.4	5.4	1	6.0	6.0	6.0	1	7.2	7.2	7.2	12	22.9	5.4	13.8
5	400	1.8	94	4	24	3.1	10	4	100	2.5	31	5	70	2.6	17	4	1.8	0.9	1.3	4	300	8.0	88	52	400	0.9	29
5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	52	ND	ND	<0.2
5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	52	ND	ND	<0.2
5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	52	ND	ND	<0.2
5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	5	ND	ND	<0.2	4	ND	ND	<0.2	4	ND	ND	<0.2	52	ND	ND	<0.2
1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	12	ND	ND	<0.2
1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	1	ND	ND	<0.2	12	ND	ND	<0.2
5	320.0	1.4	77.3	4	13.8	2.5	6.8	4	72.6	1.7	23.3	5	58.4	1.7	13.9	4	2	0.9	1	4	200.0	5.8	60.4	52	320	0.9	23.0
5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	52	ND	ND	<0.1
5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	52	ND	ND	<0.1
5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	52	ND	ND	<0.1
5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	5	ND	ND	<0.1	4	ND	ND	<0.1	4	ND	ND	<0.1	52	ND	ND	<0.1
1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	12	ND	ND	<0.1
1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	1	ND	ND	<0.1	12	ND	ND	<0.1
5	5.0	1.9	3.3	4	3.0	1.5	2.1	4	3.5	2.0	2.5	5	2.0	1.1	1.5	4	1.3	0.8	1.1	4	2.0	1.2	1.8	52	18.4	0.8	2.8
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	0.5	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	12	ND	ND	<0.5
1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	12	ND	ND	<0.5
5	3.4	1.6	2.6	4	2.1	1.4	1.6	4	1.5	1.1	1.3	5	1.4	0.8	1.0	4	0.9	0.7	0.8	4	2.2	0.9	1.5	52	11.6	0.7	1.9
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	5	ND	ND	<0.5	4	ND	ND	<0.5	4	ND	ND	<0.5	52	ND	ND	<0.5
1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	12	ND	ND	<0.5
1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	1	ND	ND	<0.5	12	ND	ND	<0.5
5	7.33	6.94	7.20	4	7.50	7.34	7.42	4	7.44	7.20	7.33	5	7.42	7.22	7.35	4	7.45	7.38	7.41	4	7.30	7.10	7.24	52	7.50	6.94	7.25
5	7.13	7.01	7.10	4	7.22	7.07	7.16	4	7.21	7.14	7.17	5	7.16	7.05	7.12	4	7.27	7.13	7.20	4	7.26	7.15	7.20	52	7.30	7.01	7.15
5	7.29	7.19	7.24	4	7.33	7.18	7.25	4	7.26	7.18	7.23	5	7.22	7.13	7.17	4	7.30	7.17	7.25	4	7.25	7.23	7.24	52	7.47	7.13	7.26
5	7.27	7.05	7.18	4	7.27	7.12	7.22	4	7.21	7.17	7.18	5	7.20	7.11	7.15	4	7.27	7.17	7.23	4	7.23	7.19	7.22	52	7.35	7.05	7.22
5	7.24	7.02	7.15	4	7.25	7.09	7.19	4	7.23	7.15	7.18	5	7.18	7.09	7.13	4	7.26	7.16	7.22	4	7.21	7.19	7.20	52	7.37	7.02	7.20
1	7.29	7.29	7.29	1	7.25	7.25	7.25	1	7.18	7.18	7.18	1	7.18	7.18	7.18	1	7.26	7.26	7.26	1	7.23	7.23	7.23	12	7.39	7.15	7.26
1	7.27	7.27	7.27	1	7.27	7.27	7.27	1	7.17	7.17	7.17	1	7.17	7.17	7.17	1	7.24	7.24	7.24	1	7.23	7.23	7.23	12	7.35	7.14	7.24
—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
5	0.36	0.34	0.35	4	0.34	0.33	0.34	4	0.34	0.31	0.33	5	0.33	0.28	0.31	4	0.31	0.29	0.30	4	0.34	0.32	0.33	52	0.42	0.28	0.34
5	0.32	0.30	0.31	4	0.33	0.29	0.31	4	0.31	0.31	0.31	5	0.32	0.28	0.30	4	0.31	0.28	0.30	4	0.33	0.32	0.32	52	0.33	0.28	0.30
5	0.32	0.29	0.31	4	0.33	0.31	0.32	4	0.34	0.30	0.32	5	0.32	0.28	0.31	4	0.31	0.29	0.30	4	0.33	0.31	0.32	52	0.38	0.28	0.31
5	0.32	0.29	0.30	4	0.32	0.31	0.32	4	0.33	0.30	0.32	5	0.32	0.28	0.30	4	0.31	0.28	0.30	4	0.34	0.31	0.33	52	0.35	0.28	0.31
1	0.31	0.31	0.31	1	0																						

平成29年度 週検査結果総括表その2

検査月			4月				5月				6月				7月				8月				9月			
項目	水質基準等	地点	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
過マンガン酸 カリウム 消費量	3mg/l	原水	4	8.2	1.6	3.4	5	2.8	1.5	2.3	4	2.5	1.8	2.1	4	9.7	2.2	5.8	5	37.0	2.3	9.9	4	4.6	2.3	2.9
	以下	浄水	4	0.5	0.4	0.4	5	0.5	0.4	0.5	4	0.6	0.3	0.5	4	1.4	0.7	1.0	5	1.2	0.5	0.7	4	0.7	0.4	0.5
		清水	4	0.5	0.4	0.4	5	0.6	0.4	0.5	4	0.6	0.4	0.5	4	1.1	0.7	0.9	5	0.8	0.4	0.6	4	0.6	0.4	0.5
		鯖江	4	0.5	0.4	0.4	5	0.6	0.4	0.5	4	0.7	0.3	0.5	4	1.1	0.7	0.9	5	0.8	0.5	0.6	4	0.6	0.4	0.5
		南条	4	0.5	0.4	0.4	5	0.6	0.4	0.5	4	0.6	0.4	0.5	4	1.0	0.7	0.8	5	0.9	0.5	0.6	4	0.7	0.5	0.6
		朝日	1	0.4	0.4	0.4	1	0.6	0.6	0.6	1	0.6	0.6	0.6	1	0.7	0.7	0.7	1	0.8	0.8	0.8	1	0.4	0.4	0.4
		今立	1	0.4	0.4	0.4	1	0.6	0.6	0.6	1	0.6	0.6	0.6	1	0.7	0.7	0.7	1	0.8	0.8	0.8	1	0.5	0.5	0.5
TOC	3mg/l	原水	4	1.0	0.4	0.6	5	0.8	0.5	0.6	4	0.9	0.6	0.7	4	1.7	0.7	1.1	5	3.3	0.6	1.2	4	0.9	0.4	0.6
	以下	浄水	4	0.2	0.2	0.2	5	0.4	0.3	0.3	4	0.4	0.4	0.4	4	0.6	0.3	0.5	5	0.6	0.3	0.4	4	0.4	0.3	0.3
		清水	4	0.3	0.2	0.2	5	0.4	0.3	0.4	4	0.4	0.4	0.4	4	0.4	0.4	0.4	5	0.5	0.3	0.3	4	0.4	0.3	0.3
		鯖江	4	0.2	0.2	0.2	5	0.4	0.3	0.3	4	0.5	0.4	0.4	4	0.6	0.4	0.5	5	0.8	0.3	0.4	4	0.4	0.3	0.3
		南条	4	0.3	0.2	0.2	5	0.4	0.3	0.4	4	0.4	0.4	0.4	4	0.5	0.4	0.4	5	0.7	0.3	0.4	4	0.4	0.3	0.3
		朝日	1	0.2	0.2	0.2	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.5	0.5	0.5	1	0.7	0.7	0.7	1	0.3	0.3	0.3
		今立	1	0.2	0.2	0.2	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.5	0.5	0.5	1	0.7	0.7	0.7	1	0.3	0.3	0.3
電気伝導率	mS/m	原水	4	7.08	5.31	6.28	5	7.87	7.13	7.43	4	8.76	8.22	8.46	4	9.37	7.85	8.59	5	8.69	5.39	7.42	4	8.52	7.48	8.19
	浄水	4	7.85	6.33	7.03	5	8.60	7.56	8.15	4	9.52	8.87	9.16	4	####	8.92	9.65	5	9.72	8.28	8.97	4	9.36	8.48	9.10	
	清水	4	7.79	6.52	7.04	5	8.56	7.71	8.13	4	9.40	8.83	9.06	4	####	8.89	9.64	5	9.80	8.41	9.04	4	9.30	8.55	9.06	
	鯖江	4	7.89	6.47	7.09	5	8.77	7.78	8.26	4	9.55	8.94	9.19	4	####	9.02	9.74	5	9.76	8.37	9.12	4	9.40	8.55	9.15	
	南条	4	7.80	6.49	7.05	5	8.78	7.75	8.22	4	9.52	8.87	9.13	4	####	8.94	9.68	5	9.76	8.32	9.09	4	9.33	8.63	9.13	
	朝日	1	6.51	6.51	6.51	1	8.86	8.86	8.86	1	9.19	9.19	9.19	1	####	####	####	1	9.42	9.42	9.42	1	9.38	9.38	9.38	
	今立	1	6.49	6.49	6.49	1	8.81	8.81	8.81	1	9.22	9.22	9.22	1	####	####	####	1	9.49	9.49	9.49	1	9.40	9.40	9.40	
アルカリ度	mg/l	原水	4	19.8	14.5	17.1	5	23.4	20.8	22.0	4	27.2	24.5	25.7	4	30.5	20.1	25.0	5	28.0	18.2	23.4	4	27.1	22.7	25.3
	浄水	4	18.7	14.3	16.7	5	23.0	19.5	21.6	4	28.1	24.4	25.6	4	25.6	16.5	22.1	5	26.7	21.1	23.7	4	24.0	19.7	22.6	
	清水	4	18.6	14.2	16.7	5	22.7	19.5	21.4	4	26.1	23.2	24.7	4	26.1	15.4	21.8	5	26.0	21.2	24.4	4	24.2	18.4	22.4	
	鯖江	4	18.7	14.0	16.7	5	25.0	19.7	22.1	4	27.2	23.8	25.7	4	25.9	17.3	22.3	5	26.2	22.3	24.4	4	24.4	19.5	22.9	
	南条	4	18.4	14.0	16.6	5	22.7	20.3	21.6	4	26.4	23.7	24.9	4	26.1	17.0	22.2	5	26.0	21.0	24.1	4	24.0	19.1	22.7	
	朝日	1	15.4	15.4	15.4	1	22.8	22.8	22.8	1	25.0	25.0	25.0	1	22.9	22.9	22.9	1	26.7	26.7	26.7	1	24.2	24.2	24.2	
	今立	1	15.5	15.5	15.5	1	23.3	23.3	23.3	1	25.4	25.4	25.4	1	22.9	22.9	22.9	1	25.2	25.2	25.2	1	24.5	24.5	24.5	
紫外線 吸光度 E260	ABS	原水	4	0.115	0.047	0.068	5	0.068	0.056	0.064	4	0.068	0.063	0.065	4	0.229	0.073	0.128	5	0.426	0.079	0.154	4	0.104	0.065	0.077
	浄水	4	0.020	0.018	0.019	5	0.028	0.023	0.026	4	0.031	0.028	0.030	4	0.053	0.026	0.038	5	0.054	0.023	0.031	4	0.032	0.023	0.026	
	清水	4	0.022	0.017	0.019	5	0.030	0.024	0.028	4	0.032	0.029	0.031	4	0.037	0.027	0.034	5	0.037	0.024	0.028	4	0.036	0.022	0.028	
	鯖江	4	0.021	0.017	0.019	5	0.029	0.023	0.026	4	0.030	0.028	0.029	4	0.046	0.025	0.036	5	0.049	0.022	0.030	4	0.033	0.022	0.027	
	南条	4	0.021	0.016	0.018	5	0.029	0.023	0.026	4	0.031	0.027	0.029	4	0.038	0.026	0.034	5	0.040	0.023	0.028	4	0.034	0.022	0.027	
	朝日	1	0.019	0.019	0.019	1	0.029	0.029	0.029	1	0.029	0.029	0.029	1	0.036	0.036	0.036	1	0.035	0.035	0.035	1	0.025	0.025	0.025	
	今立	1	0.019	0.019	0.019	1	0.029	0.029	0.029	1	0.030	0.030	0.030	1	0.037	0.037	0.037	1	0.044	0.044	0.044	1	0.025	0.025	0.025	
紫外線 吸光度 E220	ABS	原水	4	0.571	0.482	0.520	5	0.478	0.392	0.432	4	0.445	0.426	0.435	4	1.067	0.469	0.766	5	1.847	0.496	0.804	4	0.916	0.400	0.609
	浄水	4	0.457	0.405	0.425	5	0.410	0.313	0.349	4	0.367	0.358	0.364	4	0.865	0.337	0.572	5	0.623	0.380	0.467	4	0.865	0.298	0.519	
	清水	4	0.443	0.382	0.409	5	0.391	0.270	0.320	4	0.350	0.338	0.346	4	0.932	0.314	0.523	5	0.507	0.330	0.390	4	0.987	0.245	0.524	
	鯖江	4	0.450	0.398	0.416	5	0.402	0.309	0.343	4	0.364	0.353	0.359	4	0.873	0.328	0.548	5	0.538	0.361	0.443	4	0.886	0.288	0.517	
	南条	4	0.449	0.392	0.412	5	0.398	0.305	0.337	4	0.361	0.346	0.354	4	0.889	0.323	0.534	5	0.508	0.351	0.422	4	0.910	0.274	0.516	
	朝日	1	0.409	0.409	0.409	1	0.342	0.342	0.342	1	0.357	0.357	0.357	1	0.393	0.393	0.393	1	0.419	0.419	0.419	1	0.405	0.405	0.405	
	今立	1	0.414	0.414	0.414	1	0.351	0.351	0.351	1	0.362	0.362	0.362	1	0.401	0.401	0.401	1	0.487	0.487	0.487	1	0.421	0.421	0.421	
アンモニア性 窒素	mg/l	原水	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02
	浄水	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	
	清水	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	
	鯖江	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	
	南条	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	
	朝日	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	
	今立	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	
全窒素	mg/l	原水	4	0.3	0.3	0.3	5	0.3	0.2	0.3	4	0.3	0.3	0.3	4	0.6	0.3	0.4	5	0.9	0.3	0.4	4	0.6	0.2	0.4
	浄水	4	0.3	0.3	0.3	5	0.3	0.2	0.2	4	0.2	0.2	0.2	4	0.6	0.2	0.4									

10月				11月				12月				1月				2月				3月				年間			
回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
5	11.1	2.0	4.8	4	2.6	1.3	1.8	4	3.1	1.7	2.3	5	3.3	1.2	1.7	4	1.4	0.9	1.1	4	9.1	1.5	3.8	52	37.0	0.9	3.6
5	1.0	0.4	0.6	4	0.4	0.3	0.4	4	0.5	0.3	0.4	5	0.4	0.2	0.3	4	0.4	0.3	0.4	4	0.5	0.2	0.4	52	1.4	0.2	0.5
5	1.1	0.4	0.6	4	0.4	0.3	0.3	4	0.5	0.3	0.4	5	0.4	0.3	0.3	4	0.4	0.3	0.4	4	0.4	0.2	0.3	52	1.1	0.2	0.5
5	1.0	0.5	0.7	4	0.4	0.3	0.4	4	0.5	0.3	0.4	5	0.4	0.3	0.3	4	0.4	0.3	0.3	4	0.4	0.2	0.3	52	1.1	0.2	0.5
5	1.0	0.5	0.7	4	0.4	0.3	0.4	4	0.5	0.3	0.4	5	0.4	0.2	0.3	4	0.4	0.3	0.3	4	0.4	0.2	0.3	52	1.0	0.2	0.5
1	0.5	0.5	0.5	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.2	0.2	0.2	12	0.8	0.2	0.5
1	0.5	0.5	0.5	1	0.3	0.3	0.3	1	0.3	0.3	0.3	1	0.3	0.3	0.3	1	0.3	0.3	0.3	1	0.3	0.3	0.3	12	0.8	0.3	0.5
5	1.6	0.5	0.9	4	0.7	0.4	0.5	4	0.6	0.5	0.6	5	0.7	0.3	0.5	4	0.6	0.4	0.5	4	0.8	0.4	0.6	52	3.3	0.3	0.7
5	0.4	0.2	0.3	4	0.3	0.2	0.2	4	0.2	0.1	0.2	5	0.2	0.1	0.1	4	0.2	0.0	0.1	4	0.2	0.1	0.1	52	0.6	0.0	0.3
5	0.5	0.3	0.3	4	0.2	0.2	0.2	4	0.3	0.2	0.2	5	0.2	0.1	0.2	4	0.2	ND	0.1	4	0.2	0.1	0.1	52	0.5	ND	0.3
5	0.4	0.3	0.3	4	0.3	0.2	0.2	4	0.3	0.1	0.2	5	0.2	0.1	0.2	4	0.2	0.1	0.2	4	0.2	0.1	0.1	52	0.8	0.1	0.3
5	0.4	0.3	0.3	4	0.3	0.2	0.2	4	0.3	0.1	0.2	5	0.2	0.1	0.2	4	0.2	0.1	0.2	4	0.2	0.1	0.1	52	0.7	0.1	0.3
1	0.3	0.3	0.3	1	0.2	0.2	0.2	1	0.3	0.3	0.3	1	0.1	0.1	0.1	1	0.2	0.2	0.2	1	0.1	0.1	0.1	12	0.7	0.1	0.3
1	0.3	0.3	0.3	1	0.2	0.2	0.2	1	0.3	0.3	0.3	1	0.1	0.1	0.1	1	0.2	0.2	0.2	1	0.1	0.1	0.1	12	0.7	0.1	0.3
5	8.45	5.93	7.51	4	8.27	7.21	7.66	4	7.70	6.47	7.16	5	7.88	6.69	7.36	4	8.53	8.02	8.37	4	6.57	5.61	6.01	52	9.37	5.31	7.53
5	9.30	7.43	8.59	4	9.15	8.01	8.66	4	9.00	8.01	8.58	5	8.76	8.07	8.48	4	9.40	9.07	9.30	4	7.34	6.72	7.08	52	10.18	6.33	8.56
5	9.36	7.40	8.63	4	9.12	8.35	8.64	4	8.63	7.98	8.24	5	8.66	7.64	8.22	4	9.38	8.84	9.18	4	7.89	7.10	7.42	52	10.10	6.52	8.52
5	9.34	7.39	8.61	4	9.15	8.20	8.59	4	8.67	7.82	8.22	5	8.62	7.70	8.22	4	9.38	8.96	9.23	4	7.61	6.78	7.19	52	10.26	6.47	8.55
5	9.25	7.34	8.57	4	9.11	8.04	8.50	4	8.67	7.40	8.10	5	8.61	7.63	8.20	4	9.35	8.85	9.18	4	7.76	6.84	7.25	52	10.17	6.49	8.51
1	9.29	9.29	9.29	1	9.15	9.15	9.15	1	7.98	7.98	7.98	1	8.57	8.57	8.57	1	9.38	9.38	9.38	1	7.44	7.44	7.44	12	10.05	6.51	8.77
1	9.32	9.32	9.32	1	9.15	9.15	9.15	1	7.98	7.98	7.98	1	8.53	8.53	8.53	1	9.38	9.38	9.38	1	7.41	7.41	7.41	12	10.14	6.49	8.78
5	25.9	14.9	21.8	4	24.3	18.9	21.4	4	20.3	14.6	17.9	5	20.3	13.9	18.0	4	21.1	19.9	20.4	4	15.3	9.5	13.3	52	30.5	9.5	21.0
5	23.9	13.1	20.1	4	21.4	16.5	18.8	4	18.7	11.8	15.8	5	18.0	11.7	15.8	4	21.4	17.9	18.9	4	14.0	9.1	12.4	52	28.1	9.1	19.6
5	24.2	11.8	19.9	4	22.0	16.8	19.0	4	18.2	11.9	15.6	5	17.2	11.2	15.6	4	18.4	17.4	18.0	4	14.5	10.5	13.2	52	26.1	10.5	19.5
5	24.2	12.3	19.9	4	21.2	16.5	18.6	4	18.8	12.2	15.9	5	17.6	11.1	15.4	4	18.3	17.7	18.1	4	14.3	9.6	12.8	52	27.2	9.6	19.6
5	24.0	12.9	20.0	4	21.2	16.2	18.5	4	18.6	11.8	15.7	5	17.2	11.3	15.2	4	18.3	17.4	17.8	4	14.3	9.5	12.6	52	26.4	9.5	19.4
1	24.4	24.4	24.4	1	21.5	21.5	21.5	1	16.0	16.0	16.0	1	17.2	17.2	17.2	1	17.9	17.9	17.9	1	13.9	13.9	13.9	12	26.7	13.9	20.7
1	24.4	24.4	24.4	1	21.3	21.3	21.3	1	16.2	16.2	16.2	1	17.5	17.5	17.5	1	17.8	17.8	17.8	1	13.7	13.7	13.7	12	25.4	13.7	20.6
5	0.129	0.062	0.096	4	0.079	0.052	0.061	4	0.058	0.045	0.053	5	0.052	0.038	0.044	4	0.044	0.035	0.040	4	0.074	0.042	0.056	52	0.426	0.035	0.076
5	0.036	0.018	0.027	4	0.019	0.016	0.018	4	0.017	0.008	0.014	5	0.014	0.005	0.010	4	0.016	0.004	0.011	4	0.016	0.008	0.011	52	0.054	0.004	0.022
5	0.040	0.022	0.028	4	0.022	0.017	0.020	4	0.019	0.012	0.016	5	0.016	0.006	0.012	4	0.014	0.004	0.011	4	0.010	0.009	0.010	52	0.040	0.004	0.022
5	0.036	0.020	0.027	4	0.019	0.016	0.018	4	0.016	0.008	0.014	5	0.014	0.006	0.011	4	0.015	0.003	0.011	4	0.011	0.009	0.010	52	0.049	0.003	0.022
5	0.035	0.020	0.027	4	0.020	0.016	0.019	4	0.017	0.009	0.014	5	0.014	0.006	0.011	4	0.014	0.004	0.011	4	0.011	0.009	0.010	52	0.040	0.004	0.021
1	0.021	0.021	0.021	1	0.018	0.018	0.018	1	0.019	0.019	0.019	1	0.006	0.006	0.006	1	0.014	0.014	0.014	1	0.009	0.009	0.009	12	0.036	0.006	0.022
1	0.022	0.022	0.022	1	0.020	0.020	0.020	1	0.019	0.019	0.019	1	0.005	0.005	0.005	1	0.012	0.012	0.012	1	0.009	0.009	0.009	12	0.044	0.005	0.023
5	0.874	0.638	0.710	4	0.666	0.511	0.573	4	0.666	0.529	0.598	5	0.663	0.485	0.546	4	0.596	0.464	0.530	4	0.720	0.468	0.556	52	1.847	0.392	0.592
5	0.799	0.490	0.593	4	0.581	0.439	0.500	4	0.606	0.443	0.524	5	0.606	0.410	0.486	4	0.488	0.375	0.445	4	0.588	0.394	0.465	52	0.865	0.298	0.476
5	0.917	0.469	0.613	4	0.584	0.449	0.509	4	0.649	0.415	0.516	5	0.617	0.398	0.487	4	0.483	0.353	0.428	4	0.548	0.402	0.458	52	0.987	0.245	0.459
5	0.830	0.480	0.594	4	0.580	0.438	0.499	4	0.618	0.435	0.522	5	0.609	0.400	0.484	4	0.476	0.366	0.433	4	0.580	0.389	0.461	52	0.886	0.288	0.468
5	0.846	0.474	0.596	4	0.582	0.440	0.500	4	0.626	0.426	0.519	5	0.610	0.397	0.482	4	0.474	0.361	0.427	4	0.562	0.392	0.458	52	0.910	0.274	0.463
1	0.544	0.544	0.544	1	0.441	0.441	0.441	1	0.581	0.581	0.581	1	0.394	0.394	0.394	1	0.446	0.446	0.446	1	0.450	0.450	0.450	12	0.581	0.342	0.432
1	0.542	0.542	0.542	1	0.438	0.438	0.438	1	0.591	0.591	0.591	1	0.396	0.396	0.396	1	0.461	0.461	0.461	1	0.447	0.447	0.447	12	0.591	0.351	0.443
5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	52	ND	ND	<0.02
5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	52	ND	ND	<0.02
5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	52	ND	ND	<0.02
5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	52	ND	ND	<0.02
5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	5	ND	ND	<0.02	4	ND	ND	<0.02	4	ND	ND	<0.02	52	ND	ND	<0.02
1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	12	ND	ND	<0.02
1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	1	ND	ND	<0.02	12	ND	ND	<0.02
5	0.5	0.4	0.4	4	0.4	0.3	0.4	4	0.4	0.3	0.4	5	0.4	0.3	0.3	4	0.4	0.3	0.3	4	0.4	0.3	0.3	52	0.9	0.2	0.3
5	0.6	0.3	0.4	4	0.4	0.3	0.3	4	0.4	0.3	0.3	5	0.4	0.3	0.3	4	0.3	0.2	0.3	4	0.4	0.3	0.3	52	0.6	0.2	0.3
5	0.6	0.3	0.4	4	0																						