

検査月		4月				5月				6月				7月				8月				9月					
項目	水質基準等	地点	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	
気温 (°C)	—	原水	4	17.0	11.0	13.8	4	22.3	16.9	19.8	5	27.8	21.7	25.2	4	32.0	25.0	29.1	5	31.7	24.6	27.8	4	26.0	21.8	24.5	
		浄水	4	17.0	11.0	13.8	4	22.3	16.9	19.8	5	27.8	21.7	25.2	4	32.0	25.0	29.1	5	31.7	24.6	27.8	4	26.0	21.8	24.5	
		清水	4	22.8	13.6	18.9	4	24.5	18.4	21.8	5	28.8	24.2	26.2	4	33.2	25.2	30.6	5	30.2	24.8	28.0	4	31.2	25.5	27.7	
		鯖江	4	20.8	12.6	17.4	4	21.4	18.4	20.2	5	29.8	23.8	26.5	4	31.9	26.2	29.6	5	31.8	24.3	27.5	4	28.1	23.5	25.9	
		南条	4	18.5	11.2	15.5	4	22.8	16.4	19.4	5	26.8	22.8	24.9	4	31.4	24.8	28.9	5	30.9	24.2	27.2	4	27.0	20.6	24.6	
		朝日	1	21.1	21.1	21.1	1	23.2	23.2	23.2	1	29.4	29.4	29.4	1	29.0	29.0	29.0	1	23.9	23.9	23.9	1	25.8	25.8	25.8	
		今立	1	19.5	19.5	19.5	1	19.9	19.9	19.9	1	27.4	27.4	27.4	1	27.9	27.9	27.9	1	23.8	23.8	23.8	1	21.7	21.7	21.7	
		今立	1	19.5	19.5	19.5	1	19.9	19.9	19.9	1	27.4	27.4	27.4	1	27.9	27.9	27.9	1	23.8	23.8	23.8	1	21.7	21.7	21.7	
水温 (°C)	—	原水	4	10.9	8.8	9.5	4	15.0	12.0	13.4	5	19.2	14.8	17.3	4	21.8	19.2	20.6	5	22.3	19.6	21.0	4	20.0	19.3	19.7	
		浄水	4	11.9	10.0	11.0	4	15.8	12.8	14.2	5	20.1	16.1	18.5	4	23.0	19.8	21.3	5	22.8	20.1	21.9	4	22.2	21.0	21.6	
		清水	4	13.0	11.1	11.9	4	16.5	13.2	14.8	5	20.7	16.7	19.1	4	23.9	20.2	22.1	5	23.9	21.1	22.7	4	21.8	21.1	21.4	
		鯖江	4	12.0	10.3	11.1	4	15.7	12.5	14.0	5	20.1	16.2	18.6	4	22.7	19.2	20.8	5	22.1	19.2	21.3	4	21.7	20.9	21.3	
		南条	4	13.5	11.3	12.3	4	16.9	13.3	15.1	5	21.7	17.7	20.0	4	24.3	20.5	22.6	5	24.0	20.8	22.9	4	22.4	21.7	22.0	
		朝日	1	11.4	11.4	11.4	1	16.5	16.5	16.5	1	20.3	20.3	20.3	1	20.2	20.2	20.2	1	23.4	23.4	23.4	1	21.5	21.5	21.5	
		今立	1	10.7	10.7	10.7	1	15.8	15.8	15.8	1	19.5	19.5	19.5	1	19.3	19.3	19.3	1	22.2	22.2	22.2	1	21.0	21.0	21.0	
		今立	1	10.7	10.7	10.7	1	15.8	15.8	15.8	1	19.5	19.5	19.5	1	19.3	19.3	19.3	1	22.2	22.2	22.2	1	21.0	21.0	21.0	
濁度 (度)	比濁 法	2(度)	原水	4	2.3	1.5	2.0	4	8.0	2.5	4.5	5	2.2	1.6	1.9	4	14	1.8	5.1	5	45	1.4	11	4	2.0	1.2	1.7
		以下	浄水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		清水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		鯖江	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		南条	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		朝日	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
	積分 法	2(度)	原水	4	2.7	1.6	2.0	4	9.1	2.9	4.8	5	2.7	1.7	2.0	4	12	1.4	4.6	5	46	1.3	11	4	2.0	1.2	1.6
		以下	浄水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		清水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		鯖江	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		南条	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		朝日	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
色度 (度)	比色 法	5(度)	原水	4	2.8	2.3	2.5	4	6.5	3.3	4.3	5	4.0	3.0	3.3	4	8.5	2.7	4.6	5	17	3.0	6.2	4	3.5	3.0	3.3
		以下	浄水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		清水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		鯖江	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		南条	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		朝日	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
	透過 光法	5(度)	原水	4	1.3	1.2	1.2	4	3.4	1.6	2.2	5	1.7	1.5	1.6	4	4.2	1.4	2.3	5	7.8	1.4	2.9	4	1.9	1.6	1.7
		以下	浄水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		清水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		鯖江	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		南条	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	
		朝日	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	
pH値 (a.u.)	5.8~ 8.6 (a.u.)	原水	4	7.49	7.42	7.45	4	7.45	7.31	7.40	5	7.49	7.43	7.46	4	7.49	7.31	7.41	5	7.80	7.33	7.49	4	7.52	7.48	7.50	
		浄水	4	7.12	7.09	7.11	4	7.12	7.10	7.11	5	7.12	7.09	7.10	4	7.15	7.11	7.13	5	7.15	7.10	7.12	4	7.19	7.13	7.16	
		清水	4	7.26	7.18	7.22	4	7.24	7.12	7.18	5	7.24	7.18	7.22	4	7.28	7.24	7.25	5	7.26	7.20	7.24	4	7.28	7.20	7.24	
		鯖江	4	7.18	7.12	7.15	4	7.16	7.12	7.14	5	7.20	7.15	7.17	4	7.22	7.17	7.19	5	7.21	7.17	7.19	4	7.24	7.17	7.21	
		南条	4	7.18	7.16	7.17	4	7.18	7.10	7.14	5	7.21	7.14	7.18	4	7.24	7.16	7.20	5	7.23	7.16	7.20	4	7.26	7.17	7.21	
		朝日	1	7.20	7.20	7.20	1	7.15	7.15	7.15	1	7.22	7.22	7.22	1	7.19	7.19	7.19	1	7.22	7.22	7.22	1	7.23	7.23	7.23	
		今立	1	7.16	7.16	7.16	1	7.13	7.13	7.13	1	7.21	7.21	7.21	1	7.18	7.18	7.18	1	7.19	7.19	7.19	1	7.21	7.21	7.21	
		今立	1	7.16	7.16	7.16	1	7.13	7.13	7.13	1	7.21	7.21	7.21	1	7.18	7.18	7.18	1	7.19	7.19	7.19	1	7.21	7.21	7.21	
残留塩素 (mg/L)	0.1~1 (mg/L)	原水	0																								

10月				11月				12月				1月				2月				3月				年間							
回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
4	24.9	16.0	19.1	5	15.9	10.6	13.2	4	9.4	2.9	5.4	4	3.0	0.2	1.3	4	7.5	2.1	3.9	5	10.0	4.3	7.0	52	32.0	0.2	16.0				
4	24.9	16.0	19.1	5	15.9	10.6	13.2	4	9.4	2.9	5.4	4	3.0	0.2	1.3	4	7.5	2.1	3.9	5	10.0	4.3	7.0	52	32.0	0.2	16.0				
4	27.3	19.1	21.9	5	18.4	14.1	15.4	4	11.4	3.0	7.1	4	5.8	1.3	3.8	4	9.2	2.8	6.2	5	14.5	4.2	9.4	52	33.2	1.3	18.2				
4	26.5	16.8	20.8	5	17.0	13.0	14.5	4	10.5	2.5	5.9	4	3.8	1.6	2.4	4	10.1	1.1	5.2	5	13.8	3.7	8.2	52	31.9	1.1	17.2				
4	27.6	16.5	20.7	5	16.6	12.5	14.2	4	9.5	2.8	5.3	4	2.8	1.3	2.0	4	8.4	2.7	4.6	5	12.7	4.2	7.6	52	31.4	1.3	16.4				
1	22.4	22.4	22.4	1	13.5	13.5	13.5	1	11.6	11.6	11.6	1	1.4	1.4	1.4	1	4.8	4.8	4.8	1	8.7	8.7	8.7	12	29.4	1.4	17.9				
1	20.2	20.2	20.2	1	10.6	10.6	10.6	1	2.6	2.6	2.6	1	0.8	0.8	0.8	1	2.4	2.4	2.4	1	5.0	5.0	5.0	12	27.9	0.8	15.2				
4	20.2	14.1	17.5	5	14.8	9.3	12.6	4	10.3	4.8	7.9	4	7.0	4.8	5.6	4	5.1	4.1	4.6	5	7.8	5.0	6.5	52	22.3	4.1	13.1				
4	21.9	16.0	19.2	5	16.0	10.2	13.5	4	10.8	4.9	8.3	4	7.4	5.0	5.9	4	6.8	4.5	5.5	5	8.8	6.0	7.4	52	23.0	4.5	14.1				
4	21.3	16.2	19.3	5	15.8	11.2	13.7	4	10.9	7.1	9.3	4	6.5	5.1	5.9	4	5.7	4.5	5.1	5	8.7	5.1	7.0	52	23.9	4.5	14.4				
4	21.5	14.4	18.7	5	15.7	10.1	13.2	4	10.3	4.1	7.8	4	6.1	4.5	5.5	4	6.4	4.0	5.1	5	8.3	5.9	7.0	52	22.7	4.0	13.8				
4	22.1	15.3	19.3	5	15.8	10.3	13.4	4	10.2	5.3	8.2	4	6.0	4.8	5.5	4	6.0	4.1	5.0	5	8.9	5.6	7.1	52	24.3	4.1	14.6				
1	21.5	21.5	21.5	1	13.6	13.6	13.6	1	10.4	10.4	10.4	1	5.3	5.3	5.3	1	4.4	4.4	4.4	1	5.8	5.8	5.8	12	23.4	4.4	14.5				
1	21.4	21.4	21.4	1	13.1	13.1	13.1	1	9.4	9.4	9.4	1	4.6	4.6	4.6	1	4.3	4.3	4.3	1	5.8	5.8	5.8	12	22.2	4.3	13.9				
4	2.3	1.1	1.7	5	2.0	0.8	1.4	4	2.5	1.7	2.1	4	8.0	1.2	3.1	4	3.0	0.9	1.7	5	4.0	1.0	1.1	52	4.5	0.8	4.1				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
4	2.8	1.1	1.6	5	2.1	0.7	1.3	4	2.4	1.6	2.0	4	8.5	1.0	3.1	4	2.3	0.8	1.3	5	3.1	1.2	9.8	52	4.6	0.7	4.0				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
4	4.5	2.0	2.9	5	2.5	2.2	2.4	4	2.5	2.0	2.2	4	2.8	1.2	2.1	4	3.0	1.0	2.0	5	3.0	1.0	2.1	52	1.7	1.0	3.2				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
4	2.6	1.5	1.8	5	1.8	1.2	1.5	4	1.6	1.1	1.4	4	1.5	1.0	1.2	4	1.0	0.8	0.9	5	1.5	0.9	1.1	52	7.8	0.8	1.6				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
4	7.59	7.53	7.56	5	7.59	7.45	7.53	4	7.43	7.29	7.37	4	7.40	7.23	7.31	4	7.45	7.37	7.41	5	7.43	7.21	7.33	52	7.80	7.21	7.44				
4	7.13	7.12	7.13	5	7.12	7.08	7.10	4	7.11	7.00	7.05	4	7.12	6.99	7.06	4	7.14	7.07	7.11	5	7.14	7.09	7.12	52	7.19	6.99	7.11				
4	7.30	7.15	7.22	5	7.18	7.12	7.14	4	7.15	7.04	7.10	4	7.17	7.05	7.11	4	7.20	7.11	7.16	5	7.18	7.10	7.15	52	7.30	7.04	7.19				
4	7.21	7.12	7.16	5	7.12	7.10	7.11	4	7.15	6.99	7.07	4	7.14	7.03	7.09	4	7.16	7.07	7.13	5	7.15	7.09	7.12	52	7.24	6.99	7.14				
4	7.22	7.12	7.17	5	7.13	7.11	7.12	4	7.14	6.99	7.08	4	7.13	7.03	7.08	4	7.17	7.05	7.13	5	7.15	7.08	7.11	52	7.26	6.99	7.15				
1	7.20	7.20	7.20	1	7.12	7.12	7.12	1	7.11	7.11	7.11	1	7.06	7.06	7.06	1	7.20	7.20	7.20	1	7.16	7.16	7.16	12	7.23	7.06	7.17				
1	7.17	7.17	7.17	1	7.11	7.11	7.11	1	7.11	7.11	7.11	1	7.06	7.06	7.06	1	7.17	7.17	7.17	1	7.14	7.14	7.14	12	7.21	7.06	7.15				
0	-	-	-	0	-	-	-	0	-	-	-	0	-	-	-	0	-	-	-	0	-	-	-	0	-	-	-				
4	0.37	0.35	0.36	5	0.36	0.33	0.35	4	0.36	0.32	0.35	4	0.33	0.32	0.32	4	0.36	0.32	0.34	5	0.34	0.33	0.33	52	0.41	0.32	0.35				
4	0.31	0.30	0.30	5	0.31	0.29	0.30	4	0.32	0.29	0.31	4	0.33	0.28	0.31	4	0.34	0.30	0.32	5	0.31	0.30	0.31	52	0.34	0.27	0.30				
4	0.34	0.31	0.32	5	0.33	0.31	0.32	4	0.35	0.31	0.33	4	0.32	0.30	0.31	4	0.35	0.29	0.32	5	0.33	0.32	0.32	52	0.36	0.29	0.32				
4	0.33	0.30	0.32	5	0.32	0.30	0.31	4	0.34	0.31	0.33	4	0.31	0.30	0.31	4	0.34	0.30	0.32	5	0.32	0.31	0.32	52	0.34	0.27	0.31				
1	0.30	0.30	0.30	1	0.33	0.33	0.33	1	0.33	0.33	0.33	1	0.32	0.32	0.32	1	0.32	0.32	0.32	1	0.32	0.32	0.32	12	0.34	0.28	0.32				
1	0.33	0.33	0.33	1	0.33	0.33	0.33	1	0.33	0.33	0.33	1	0.31	0.31	0.31	1	0.29	0.29	0.29	1	0.32	0.32	0.32	12	0.33	0.29	0.32				

令和3年度

週検査結果総括表 その2

検査月		4月				5月				6月				7月				8月				9月				
項目	水質基準等	地点	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
有機物等 (過マンガン酸 カリウム消費量) (mg/L)	3 (mg/L) 以下	原水	4	2.1	1.8	1.9	4	6.7	2.4	3.7	5	2.4	1.9	2.2	4	9.6	2.6	4.6	5	29.5	2.1	8.2	4	3.0	2.0	2.4
		浄水	4	0.4	0.3	0.4	4	0.7	0.3	0.5	5	0.6	0.4	0.5	4	0.7	0.3	0.4	5	0.9	0.2	0.5	4	0.4	0.3	0.4
		清水	4	0.4	0.3	0.4	4	0.8	0.3	0.5	5	0.9	0.4	0.6	4	1.2	0.3	0.6	5	0.8	0.2	0.5	4	0.4	0.3	0.4
		鯖江	4	0.4	0.3	0.4	4	0.7	0.3	0.5	5	0.6	0.4	0.5	4	0.5	0.3	0.4	5	0.8	0.2	0.5	4	0.4	0.3	0.4
		南条	4	0.4	0.3	0.4	4	0.6	0.3	0.4	5	0.6	0.4	0.5	4	0.7	0.3	0.4	5	0.8	0.2	0.5	4	0.4	0.3	0.4
		朝日	1	0.4	0.4	0.4	1	0.8	0.8	0.8	1	0.4	0.4	0.4	1	0.3	0.3	0.3	1	0.8	0.8	0.8	1	0.4	0.4	0.4
		今立	1	0.4	0.4	0.4	1	0.9	0.9	0.9	1	0.4	0.4	0.4	1	0.3	0.3	0.3	1	0.8	0.8	0.8	1	0.4	0.4	0.4
有機物 (全有機炭素 (TOC)の量) (mg/L)	3 (mg/L) 以下	原水	4	0.5	0.4	0.5	4	1.1	0.6	0.8	5	0.8	0.5	0.7	4	1.4	0.6	0.8	5	2.5	0.6	1.0	4	0.7	0.5	0.6
		浄水	4	0.2	0.2	0.2	4	0.5	0.3	0.3	5	0.4	0.3	0.3	4	0.5	0.2	0.3	5	0.6	0.2	0.3	4	0.2	0.2	0.2
		清水	4	0.3	0.2	0.3	4	0.5	0.3	0.3	5	0.4	0.3	0.4	4	0.6	0.3	0.4	5	0.4	0.2	0.3	4	0.3	0.2	0.3
		鯖江	4	0.3	0.2	0.2	4	0.5	0.3	0.3	5	0.4	0.3	0.4	4	0.5	0.3	0.3	5	0.5	0.2	0.3	4	0.3	0.2	0.3
		南条	4	0.3	0.2	0.2	4	0.5	0.3	0.3	5	0.4	0.3	0.4	4	0.6	0.3	0.4	5	0.5	0.2	0.3	4	0.3	0.2	0.3
		朝日	1	0.3	0.3	0.3	1	0.5	0.5	0.5	1	0.4	0.4	0.4	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.3	0.3	0.3
		今立	1	0.2	0.2	0.2	1	0.5	0.5	0.5	1	0.4	0.4	0.4	1	0.3	0.3	0.3	1	0.5	0.5	0.5	1	0.2	0.2	0.2
電気伝導率 (mS/m)	-	原水	4	7.51	6.52	7.09	4	7.36	6.77	7.06	5	8.70	7.47	8.27	4	8.42	6.94	7.86	5	8.63	6.92	7.89	4	9.23	8.17	8.82
		浄水	4	8.37	7.26	7.88	4	8.25	7.58	7.88	5	9.83	8.26	9.28	4	9.67	8.66	9.17	5	9.87	8.74	9.47	4	10.48	9.70	10.15
		清水	4	8.33	7.21	7.85	4	8.35	7.76	8.08	5	9.97	8.35	9.37	4	9.70	8.75	9.23	5	10.15	8.68	9.54	4	10.54	9.90	10.22
		鯖江	4	8.41	7.27	7.90	4	8.31	7.54	7.92	5	9.89	8.33	9.33	4	9.70	8.73	9.21	5	9.98	8.74	9.55	4	10.54	9.84	10.23
		南条	4	8.38	7.23	7.88	4	8.32	7.52	7.97	5	9.90	8.32	9.31	4	9.68	8.67	9.18	5	10.00	8.69	9.53	4	10.51	9.85	10.19
		朝日	1	8.05	8.05	8.05	1	7.98	7.98	7.98	1	9.75	9.75	9.75	1	9.06	9.06	9.06	1	10.09	10.09	10.09	1	10.04	10.04	10.04
		今立	1	8.05	8.05	8.05	1	7.78	7.78	7.78	1	9.64	9.64	9.64	1	9.05	9.05	9.05	1	10.02	10.02	10.02	1	10.09	10.09	10.09
アルカリ度 (mg/L)	-	原水	4	21.0	17.3	19.1	4	20.4	18.2	19.1	5	26.5	20.9	24.5	4	25.8	20.3	23.3	5	27.1	19.2	23.5	4	29.2	25.0	27.8
		浄水	4	17.6	14.5	16.1	4	17.5	15.3	16.2	5	22.4	17.8	20.8	4	21.9	18.3	20.3	5	22.7	18.5	20.6	4	23.9	21.8	23.2
		清水	4	17.3	14.1	15.9	4	17.3	15.6	16.7	5	22.8	17.8	20.5	4	21.8	18.4	20.4	5	22.7	18.1	20.9	4	24.1	21.9	23.1
		鯖江	4	16.9	14.5	16.0	4	17.2	15.1	16.0	5	22.8	17.8	20.8	4	21.8	18.8	20.4	5	22.6	18.2	20.9	4	23.9	22.1	23.1
		南条	4	17.1	14.2	15.8	4	17.3	15.0	16.2	5	22.1	17.4	20.4	4	21.7	18.2	20.2	5	22.6	17.9	20.9	4	23.9	21.7	22.8
		朝日	1	15.7	15.7	15.7	1	16.0	16.0	16.0	1	21.4	21.4	21.4	1	19.7	19.7	19.7	1	22.4	22.4	22.4	1	22.5	22.5	22.5
		今立	1	15.8	15.8	15.8	1	15.4	15.4	15.4	1	21.3	21.3	21.3	1	19.8	19.8	19.8	1	21.7	21.7	21.7	1	22.7	22.7	22.7
紫外線 吸光度 (E260) (ABS)	-	原水	4	0.058	0.049	0.053	4	0.148	0.069	0.094	5	0.076	0.066	0.071	4	0.187	0.071	0.103	5	0.330	0.069	0.126	4	0.079	0.068	0.071
		浄水	4	0.020	0.016	0.018	4	0.041	0.022	0.029	5	0.030	0.022	0.027	4	0.041	0.019	0.026	5	0.042	0.012	0.021	4	0.021	0.018	0.019
		清水	4	0.023	0.018	0.020	4	0.036	0.021	0.026	5	0.032	0.024	0.028	4	0.051	0.020	0.029	5	0.024	0.014	0.019	4	0.021	0.019	0.020
		鯖江	4	0.020	0.016	0.018	4	0.038	0.021	0.028	5	0.029	0.022	0.026	4	0.042	0.017	0.025	5	0.034	0.013	0.020	4	0.020	0.017	0.018
		南条	4	0.021	0.016	0.019	4	0.038	0.020	0.027	5	0.031	0.022	0.027	4	0.045	0.018	0.026	5	0.030	0.013	0.019	4	0.020	0.018	0.019
		朝日	1	0.020	0.020	0.020	1	0.038	0.038	0.038	1	0.027	0.027	0.027	1	0.018	0.018	0.018	1	0.029	0.029	0.029	1	0.018	0.018	0.018
		今立	1	0.021	0.021	0.021	1	0.039	0.039	0.039	1	0.028	0.028	0.028	1	0.017	0.017	0.017	1	0.031	0.031	0.031	1	0.018	0.018	0.018
紫外線 吸光度 (E220) (ABS)	-	原水	4	0.655	0.439	0.522	4	0.890	0.549	0.682	5	0.644	0.504	0.549	4	1.126	0.496	0.704	5	1.711	0.487	0.841	4	0.629	0.582	0.604
		浄水	4	0.602	0.366	0.453	4	0.627	0.458	0.539	5	0.547	0.416	0.456	4	0.834	0.397	0.551	5	0.709	0.394	0.537	4	0.508	0.448	0.475
		清水	4	0.588	0.305	0.415	4	0.508	0.425	0.469	5	0.523	0.367	0.413	4	0.827	0.356	0.528	5	0.729	0.352	0.489	4	0.479	0.425	0.449
		鯖江	4	0.599	0.359	0.445	4	0.593	0.459	0.526	5	0.540	0.405	0.448	4	0.849	0.389	0.549	5	0.707	0.388	0.518	4	0.496	0.430	0.462
		南条	4	0.589	0.328	0.424	4	0.525	0.436	0.492	5	0.527	0.392	0.436	4	0.853	0.382	0.546	5	0.711	0.386	0.511	4	0.479	0.421	0.453
		朝日	1	0.590	0.590	0.590	1	0.518	0.518	0.518	1	0.439	0.439	0.439	1	0.551	0.551	0.551	1	0.537	0.537	0.537	1	0.425	0.425	0.425
		今立	1	0.598	0.598	0.598	1	0.572	0.572	0.572	1	0.446	0.446	0.446	1	0.555	0.555	0.555	1	0.567	0.567	0.567	1	0.439	0.439	0.439
アンモニア態 窒素 (mg/L)	-	原水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		浄水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		清水	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		鯖江	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		南条	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	4	0.04	ND	ND	5	ND	ND	ND	4	ND	ND	ND
		朝日	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND
		今立	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND
全窒素 (mg/L)	-	原水	4	0.4	0.3	0.3	4	0.5	0.3	0.4	5	0.4	0.3	0.3	4	0.6	0.3	0.4	5	0.9	0.3	0.5	4	0.4	0.4	0.4
		浄水	4	0.4	0.2	0.3	4	0.4	0.3	0.4	5	0.4	0.3	0.3	4	0.6	0.3	0.4	5	0.5	0.3	0.4	4	0.3	0.3	0.3

10月				11月				12月				1月				2月				3月				年間							
回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均	回	最高	最低	平均
4	3.3	1.8	2.2	5	2.0	1.5	1.7	4	2.2	2.0	2.1	4	4.3	1.4	2.4	4	2.2	1.3	1.7	5	6.5	1.5	2.9	52	29.5	1.3	3.0				
4	0.5	0.3	0.4	5	0.7	0.3	0.5	4	0.3	0.3	0.3	4	0.5	0.3	0.4	4	0.6	0.2	0.4	5	0.3	0.3	0.3	52	0.9	0.2	0.4				
4	0.4	0.3	0.4	5	0.6	0.3	0.5	4	0.4	0.3	0.3	4	0.5	0.3	0.4	4	0.6	0.3	0.4	5	0.3	0.3	0.3	52	1.2	0.2	0.4				
4	0.4	0.3	0.4	5	0.6	0.3	0.5	4	0.4	0.3	0.3	4	0.4	0.3	0.4	4	0.4	0.2	0.3	5	0.3	0.2	0.3	52	0.8	0.2	0.4				
4	0.4	0.3	0.4	5	0.6	0.3	0.5	4	0.4	0.3	0.3	4	0.5	0.3	0.4	4	0.4	0.2	0.3	5	0.3	0.3	0.3	52	0.8	0.2	0.4				
1	0.4	0.4	0.4	1	0.6	0.6	0.6	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.4	0.4	0.4	1	0.3	0.3	0.3	12	0.8	0.3	0.5				
1	0.4	0.4	0.4	1	0.6	0.6	0.6	1	0.3	0.3	0.3	1	0.4	0.4	0.4	1	0.4	0.4	0.4	1	0.3	0.3	0.3	12	0.9	0.3	0.5				
4	0.8	0.4	0.6	5	0.6	0.4	0.5	4	0.5	0.4	0.4	4	0.6	0.4	0.5	4	0.5	0.4	0.5	5	0.7	0.4	0.5	52	2.5	0.4	0.6				
4	0.3	0.2	0.2	5	0.3	0.2	0.3	4	0.2	0.2	0.2	4	0.2	0.2	0.2	4	0.3	0.2	0.2	5	0.2	ND	0.1	52	0.6	ND	0.3				
4	0.3	0.2	0.3	5	0.4	0.2	0.3	4	0.3	0.2	0.2	4	0.2	0.2	0.2	4	0.2	0.2	0.2	5	0.3	ND	0.2	52	0.6	ND	0.3				
4	0.3	0.2	0.3	5	0.4	0.2	0.3	4	0.2	0.2	0.2	4	0.3	0.2	0.2	4	0.2	0.2	0.2	5	0.2	ND	0.2	52	0.5	ND	0.3				
4	0.3	0.2	0.3	5	0.3	0.2	0.3	4	0.2	0.2	0.2	4	0.3	0.2	0.2	4	0.3	0.2	0.2	5	0.2	ND	0.2	52	0.6	ND	0.3				
1	0.2	0.2	0.2	1	0.3	0.3	0.3	1	0.2	0.2	0.2	1	0.2	0.2	0.2	1	0.2	0.2	0.2	1	0.2	0.2	0.2	12	0.5	0.2	0.3				
1	0.2	0.2	0.2	1	0.4	0.4	0.4	1	0.2	0.2	0.2	1	0.2	0.2	0.2	1	0.2	0.2	0.2	1	0.2	0.2	0.2	12	0.5	0.2	0.3				
4	9.40	9.11	9.30	5	9.65	8.41	9.31	4	7.83	7.51	7.66	4	8.42	7.41	8.06	4	8.87	8.73	8.80	5	8.80	6.17	7.30	52	9.65	6.17	8.12				
4	10.64	10.11	10.46	5	10.68	9.40	10.28	4	8.64	7.81	8.38	4	9.16	8.43	8.87	4	10.06	9.50	9.74	5	9.82	6.94	8.34	52	10.68	6.94	9.17				
4	10.62	10.43	10.50	5	10.57	9.35	10.18	4	8.71	8.02	8.46	4	9.38	8.72	9.00	4	10.03	9.47	9.69	5	9.60	6.98	8.43	52	10.62	6.98	9.22				
4	10.70	10.37	10.57	5	10.68	9.40	10.32	4	8.71	8.05	8.48	4	9.26	8.71	8.99	4	10.15	9.55	9.82	5	9.71	7.01	8.37	52	10.70	7.01	9.24				
4	10.65	10.43	10.53	5	10.60	9.35	10.25	4	8.64	8.02	8.47	4	9.26	8.79	9.01	4	10.13	9.50	9.80	5	9.61	7.07	8.38	52	10.65	7.07	9.22				
1	10.55	10.55	10.55	1	10.42	10.42	10.42	1	8.60	8.60	8.60	1	9.11	9.11	9.11	1	9.81	9.81	9.81	1	9.23	9.23	9.23	12	10.55	7.98	9.39				
1	10.59	10.59	10.59	1	10.45	10.45	10.45	1	8.63	8.63	8.63	1	9.11	9.11	9.11	1	9.69	9.69	9.69	1	9.26	9.26	9.26	12	10.59	7.78	9.36				
4	30.0	28.1	29.5	5	31.3	22.6	28.4	4	20.1	17.6	18.8	4	20.7	14.4	17.6	4	21.7	20.2	21.2	5	20.0	12.3	16.0	52	31.3	12.3	22.5				
4	24.5	23.1	24.1	5	24.9	18.7	23.0	4	16.8	14.8	15.8	4	18.0	13.4	15.4	4	18.6	17.5	18.0	5	17.0	10.8	13.9	52	24.9	10.8	19.0				
4	24.6	24.2	24.4	5	24.6	18.6	22.7	4	16.7	14.8	15.8	4	17.7	15.2	16.2	4	18.3	16.6	17.7	5	16.5	10.9	13.7	52	24.6	10.9	19.0				
4	25.0	24.0	24.4	5	24.7	18.8	22.9	4	17.0	14.6	15.8	4	17.7	13.3	15.4	4	18.2	17.3	17.8	5	16.7	10.5	13.6	52	25.0	10.5	19.0				
4	24.1	24.0	24.1	5	24.6	18.5	22.7	4	16.8	14.6	15.7	4	17.5	13.6	15.3	4	17.9	17.0	17.6	5	16.9	10.4	13.6	52	24.6	10.4	18.8				
1	24.5	24.5	24.5	1	22.8	22.8	22.8	1	16.9	16.9	16.9	1	15.1	15.1	15.1	1	18.0	18.0	18.0	1	15.7	15.7	15.7	12	24.5	15.1	19.2				
1	24.6	24.6	24.6	1	23.0	23.0	23.0	1	17.5	17.5	17.5	1	15.0	15.0	15.0	1	17.8	17.8	17.8	1	15.8	15.8	15.8	12	24.6	15.0	19.2				
4	0.112	0.062	0.075	5	0.067	0.056	0.061	4	0.063	0.052	0.060	4	0.073	0.046	0.057	4	0.052	0.041	0.046	5	0.066	0.045	0.053	52	0.330	0.041	0.073				
4	0.028	0.014	0.020	5	0.027	0.019	0.023	4	0.020	0.015	0.018	4	0.018	0.014	0.016	4	0.017	0.012	0.015	5	0.014	0.005	0.011	52	0.042	0.005	0.020				
4	0.022	0.015	0.019	5	0.027	0.020	0.022	4	0.020	0.015	0.018	4	0.019	0.014	0.016	4	0.019	0.015	0.017	5	0.014	0.006	0.011	52	0.051	0.006	0.020				
4	0.024	0.015	0.019	5	0.026	0.020	0.022	4	0.019	0.014	0.017	4	0.017	0.014	0.016	4	0.018	0.013	0.016	5	0.014	0.005	0.011	52	0.042	0.005	0.020				
4	0.023	0.015	0.020	5	0.026	0.020	0.023	4	0.020	0.014	0.018	4	0.018	0.014	0.017	4	0.020	0.014	0.016	5	0.015	0.005	0.011	52	0.045	0.005	0.020				
1	0.018	0.018	0.018	1	0.026	0.026	0.026	1	0.019	0.019	0.019	1	0.015	0.015	0.015	1	0.018	0.018	0.018	1	0.012	0.012	0.012	12	0.038	0.012	0.022				
1	0.018	0.018	0.018	1	0.026	0.026	0.026	1	0.019	0.019	0.019	1	0.014	0.014	0.014	1	0.018	0.018	0.018	1	0.014	0.014	0.014	12	0.039	0.014	0.022				
4	0.798	0.566	0.633	5	0.972	0.587	0.766	4	0.876	0.697	0.799	4	0.969	0.653	0.793	4	0.686	0.645	0.661	5	0.898	0.654	0.753	52	1.711	0.439	0.695				
4	0.622	0.431	0.496	5	0.914	0.503	0.688	4	0.819	0.629	0.720	4	0.789	0.577	0.682	4	0.613	0.530	0.576	5	0.818	0.593	0.667	52	0.914	0.366	0.571				
4	0.578	0.414	0.477	5	0.936	0.505	0.693	4	0.848	0.637	0.719	4	0.668	0.578	0.636	4	0.596	0.545	0.578	5	0.875	0.601	0.681	52	0.936	0.305	0.547				
4	0.611	0.421	0.486	5	0.918	0.495	0.680	4	0.820	0.623	0.716	4	0.745	0.571	0.666	4	0.604	0.518	0.568	5	0.826	0.595	0.665	52	0.918	0.359	0.562				
4	0.598	0.410	0.483	5	0.917	0.493	0.678	4	0.837	0.625	0.718	4	0.705	0.567	0.652	4	0.601	0.518	0.566	5	0.836	0.596	0.665	52	0.917	0.328	0.554				
1	0.405	0.405	0.405	1	0.838	0.838	0.838	1	0.671	0.671	0.671	1	0.659	0.659	0.659	1	0.574	0.574	0.574	1	0.678	0.678	0.678	12	0.838	0.405	0.574				
1	0.416	0.416	0.416	1	0.837	0.837	0.837	1	0.674	0.674	0.674	1	0.664	0.664	0.664	1	0.574	0.574	0.574	1	0.679	0.679	0.679	12	0.837	0.416	0.585				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	ND	ND	ND				
4	ND	ND	ND	5	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	4	ND	ND	ND	5	ND	ND	ND	52	0.04	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	1	ND	ND	ND	12	ND	ND	ND				
4	0.5	0.3	0.4	5	0.7	0.4	0.5	4	0.6	0.4	0.5	4	0.6	0.4	0.5	4	0.4	0.3	0.4	5	0.6	0.4	0.5	52	0.9	0.3	0.4				
4	0.4	0.3	0.3	5	0.7	0.3	0.5	4	0.6	0.4	0.5	4	0.6	0.4	0.5	4	0.4	0.3	0.4	5	0.6	0.4	0.4	52	0.7	0.2	0.4				
4	0.4	0.3	0.3	5	0.7	0.3	0.5	4	0.6	0.5	0.5	4	0.5	0.4	0.5	4	0.4	0.4	0.4	5	0.6	0.4	0.5	52	0.7	0.2	0.4				
4	0.4	0.3	0.3	5	0.7	0.3	0.5	4	0.6	0.4	0.5	4	0.5	0.4	0.5	4	0.4	0.3	0.4	5	0.6	0.4	0.4	52	0.7</						