

水質試験結果表(取水分)

2025年2月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	4.2	5.7	0.7	7.2	27.3	29.3	48.4	8.2	0.04	ND	80.9
2	日	6.7	6.9	0.8	7.3	29.1	31.4	46.8	8.1	0.05	ND	83.1
3	月	6.7	7.3	0.8	7.3	29.0	31.8	46.4	8.5	0.06	ND	84.1
4	火	1.7	6.5	2.5	6.8	28.6	33.8	56.8	14.9	0.16	ND	116.3
5	水	2.3	4.2	2.6	6.9	28.9	33.4	58.8	14.3	0.15	ND	111.9
6	木	0.8	3.4	1.8	7.1	27.6	28.9	56.8	10.4	0.09	ND	93.7
7	金	4.9	3.8	1.1	7.1	26.7	28.5	46.8	8.6	0.05	ND	83.4
8	土	3.2	2.8	1.6	7.2	32.6	37.4	79.2	17.3	0.16	ND	134.9
9	日	2.1	2.9	1.7	7.1	33.6	40.4	92.0	19.2	0.17	ND	145.1
10	月	3.5	3.3	1.8	7.2	33.7	39.0	91.2	21.5	0.19	ND	151.6
11	火	4.5	4.3	1.0	7.1	28.6	32.0	57.6	10.1	0.04	ND	89.6
12	水	4.5	4.7	1.0	7.1	29.2	32.8	52.0	9.3	0.04	ND	90.8
13	木	5.3	4.5	1.7	7.2	28.8	32.0	50.4	12.8	0.11	ND	107.0
14	金	3.8	4.4	1.8	6.9	24.9	29.1	42.4	8.6	0.08	ND	82.2
15	土	5.7	5.0	0.7	7.1	26.9	28.7	38.0	8.5	0.04	ND	80.7
16	日	9.0	6.4	0.8	7.3	29.1	33.2	41.2	9.4	0.07	ND	88.3
17	月	8.1	6.5	2.4	7.0	24.6	31.0	54.0	14.3	0.15	ND	104.1
18	火	3.4	5.3	1.9	7.0	25.8	29.7	46.8	10.3	0.08	ND	90.0
19	水	4.3	4.9	1.6	7.2	26.1	29.1	42.4	9.0	0.07	ND	84.4
20	木	1.9	4.6	1.1	7.2	26.8	27.1	38.8	9.2	0.05	ND	83.4
21	金	3.2	4.6	1.3	7.2	26.6	28.7	38.4	8.3	0.06	ND	82.6
22	土	1.8	5.1	0.7	7.1	27.4	29.7	38.8	8.0	0.04	ND	79.8
23	日	1.7	4.5	0.7	7.1	29.0	33.0	54.8	8.9	0.04	ND	90.5
24	月	3.0	5.0	0.9	7.2	29.5	32.4	46.0	8.7	0.05	ND	90.7
25	火	3.4	4.9	1.4	7.2	29.1	31.8	52.4	8.6	0.07	ND	90.6
26	水	4.5	5.9	1.5	7.1	30.0	31.8	44.4	8.3	0.07	ND	87.7
27	木	2.9	5.3	2.0	7.0	28.4	29.9	49.6	10.3	0.09	ND	92.9
28	金	5.3	6.7	3.1	7.2	29.8	31.8	50.4	8.9	0.09	ND	88.7
最大値		9.0	7.3	3.1	7.3	33.7	40.4	92.0	21.5	0.19	ND	151.6
最小値		0.8	2.8	0.7	6.8	24.6	27.1	38.0	8.0	0.04	ND	79.8
平均値		4.0	5.0	1.5	7.1	28.5	31.7	52.2	10.8	0.08	ND	96.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2025年2月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8～8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	4.2	5.6	0.8	7.3	26.9	29.5	51.2	9.9	0.05	ND	87.5
2	日	6.7	6.5	0.6	7.3	28.4	30.6	43.2	8.5	0.04	ND	82.4
3	月	6.7	7.2	0.8	7.4	28.7	31.4	50.4	8.3	0.05	ND	84.1
4	火	1.7	6.4	1.2	7.0	28.2	32.6	47.6	11.8	0.07	ND	100.6
5	水	2.3	4.1	1.5	7.0	27.6	33.6	55.2	13.8	0.07	ND	108.1
6	木	0.8	3.0	1.6	7.1	28.1	32.4	58.0	13.3	0.09	ND	106.5
7	金	4.9	3.6	1.1	7.2	26.7	29.9	42.0	9.5	0.05	ND	84.8
8	土	3.2	2.6	1.4	7.2	31.3	35.0	76.8	16.1	0.08	ND	125.1
9	日	2.1	2.5	1.1	7.2	32.9	39.8	87.2	19.5	0.08	ND	142.9
10	月	3.5	2.9	1.1	7.1	32.8	38.6	92.0	20.5	0.10	ND	148.1
11	火	4.5	4.5	0.8	7.2	29.0	31.0	59.2	9.7	0.04	ND	92.1
12	水	4.5	4.8	0.9	7.3	29.0	31.6	54.0	9.6	0.04	ND	91.6
13	木	5.3	4.4	1.2	7.0	28.5	33.8	54.0	12.6	0.08	ND	107.1
14	金	3.8	4.4	1.3	7.0	24.1	28.3	44.4	10.3	0.05	ND	87.9
15	土	5.7	5.2	0.8	7.1	25.8	28.5	39.2	8.4	0.04	ND	81.5
16	日	9.0	6.3	0.6	7.3	28.4	33.0	44.0	8.6	0.06	ND	86.8
17	月	8.1	6.4	1.0	7.2	25.8	32.2	48.4	10.2	0.08	ND	91.8
18	火	3.4	5.5	1.3	7.0	24.8	32.0	53.2	12.2	0.04	ND	96.0
19	水	4.3	4.9	1.2	7.1	25.8	28.5	43.2	9.6	0.05	ND	86.3
20	木	1.9	4.6	1.1	7.2	26.6	27.9	35.6	8.9	0.05	ND	84.6
21	金	3.2	4.5	1.2	7.3	26.8	29.9	41.2	8.7	0.05	ND	84.1
22	土	1.8	5.0	0.6	7.2	26.6	28.9	35.6	7.8	0.04	ND	80.0
23	日	1.7	4.0	0.6	7.1	28.2	32.4	44.8	9.2	0.04	ND	87.2
24	月	3.0	4.9	0.7	7.3	28.8	32.4	48.4	8.6	0.04	ND	89.7
25	火	3.4	4.9	1.2	7.3	28.6	31.6	49.6	8.5	0.06	ND	89.2
26	水	4.5	6.0	1.2	7.3	29.9	32.8	47.6	8.3	0.06	ND	88.4
27	木	2.9	5.3	1.4	7.1	28.0	32.2	52.0	10.0	0.06	ND	91.6
28	金	5.3	6.7	1.4	7.3	28.7	33.2	50.8	8.9	0.07	ND	89.1
最大値		9.0	7.2	1.6	7.4	32.9	39.8	92.0	20.5	0.10	ND	148.1
最小値		0.8	2.5	0.6	7.0	24.1	27.9	35.6	7.8	0.04	ND	80.0
平均値		4.0	4.9	1.1	7.2	28.0	31.9	51.7	10.8	0.06	ND	95.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
濁度およびpH以外の基準については参考値とする。
本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所